


**FINAL**

# **RADIOLOGICAL SURVEY REPORT FOR FORMER BUILDING D LOCKHEED MARTIN MIDDLE RIVER COMPLEX**

**2323 Eastern Boulevard  
Middle River, Maryland**



**LOCKHEED MARTIN**



**Tetra Tech**

Environmental Engineers & Scientists  
TC#13724-01/April 2004

---


**Final  
Radiological Survey Report for Former Building D  
Lockheed Martin Middle River Complex  
2323 Eastern Boulevard  
Middle River, Maryland**

Prepared for:

Lockheed Martin Corporation

Prepared by:


Tetra Tech, Inc.



Nisha Bansal  
Program Manager



Michael Martin  
Project Manager, P.G.



Lawson Bailey  
Senior Health Physicist


**TETRA TECH, INC.**

3475 East Foothill Blvd.

Pasadena CA 91107

(626) 351-4664

FAX (626) 351-5291



---

## TABLE OF CONTENTS

Section		Page
1	INTRODUCTION .....	1
2	HISTORY OF FORMER BUILDING D .....	1
3	SURVEY DESCRIPTION.....	2
4	SURVEY RESULTS.....	4
5	CONCLUSIONS.....	6
6	RECOMMENDATIONS .....	7

## LIST OF TABLES

		Page
Table 1	Floor Monitor Static Measurements and Standard Deviation .....	5

## LIST OF ATTACHMENTS

Attachment A	Figures
Attachment B	Instrument Checks
Attachment C	Photographs

---

## 1.0 Introduction

On behalf of Lockheed Martin Corporation (LMC), Tetra Tech has prepared the following Radiological Survey Report documenting the screening level radiological survey conducted at former Building D of the Lockheed Martin Middle River Complex located at 2323 Eastern Boulevard in Middle River, Maryland. The survey focused on the remaining foundation slab of former Building D, where it is suspected that past nuclear activities might have involved the use of radioactive materials. These activities may have potentially involved the use of uranium, plutonium, and strontium, including the possibility that other unknown isotopes may have been used. The radiological survey was conducted in areas where isotope usage was known to have occurred. These areas were identified by facility personnel who were present during the radiological operations conducted from the late 1950's through the 1960's. The radiological survey was conducted in accordance with the Radiological Survey Work Plan for Former Building D dated March 10, 2004.

## 2.0 History of Former Building D

Building D was formerly located in the southern portion of the Middle River Complex. The building encompassed approximately 400,000 square feet (ft<sup>2</sup>) of floor space and was used for aircraft construction. Specifically, the building was used for the final assembly of metal carcasses and riveting of carcasses onto aircraft frames. Building D was demolished in the early 1970's.

According to the Phase I Environmental Site Assessment prepared by Earth Tech, unknown nuclear activities were previously conducted in Building D (Earth Tech, February 2003). No specific details regarding the scope of these activities were identified. Follow-up investigation by Tetra Tech, consisting of personnel interviews indicated that nuclear activities began in the 1950's and were conducted in the southwestern and western end of Building D. The nuclear activities conducted in included the preparation of uranium-aluminum and uranium-stainless steel fuel elements and the construction of thermo-electric generators known as Systems for

---

Nuclear Auxiliary Power (SNAP) generators. Additionally, a Cobalt-60 source was located in the wet lab. It is possible that other isotopes were used in radiological operations in Building D.

The nuclear activities began in the early to mid-1950's and were focused on research involving the uranium-aluminum fuel elements. The location of these operations is identified as the secondary area of concern and is shown in Figure 1 included in Attachment A. Figure 1 was generated using a 1969 building plat of the Building D basement. A pilot manufacturing lab was opened in the late 1950's (called the New Nuclear Labs) where activities involving the uranium-aluminum fuel elements reportedly occurred. This area is identified as the main area of concern in Figure 1.

### **3.0 Survey Description**

A radiological scoping survey was performed at former Building D from March 16 through March 19, 2004. The purpose of the survey was to determine if radioactivity was present on building surfaces in quantities elevated above background levels. Surveys were performed using alpha ( $\alpha$ ) and beta ( $\beta$ ) contamination monitors and a gamma ( $\gamma$ ) radiation survey instrument. This instrumentation was determined to be appropriate for detecting the suspected radioisotopes of concern. Survey instrumentation for these activities consisted of a  $\beta$ - $\gamma$  frisker (Bicron Surveyor with Ludlum Model 44-9 probe), a micro-R meter (Ludlum Model 19) and a gas-flow proportional detector-based floor monitor (Model 239-1F with Ludlum Model 2221 scaler and Model 43-5 detector). The  $\alpha$  scintillation detector (Ludlum Model 2221 scaler and Ludlum Model 43-34B detector) was determined to be defective and was not used. The alpha detector from the floor monitor was used to take alpha readings in place of the defective 43.34B detector. Calibration certificates and daily inspection and source check information for each instrument are included in Attachment B.

---

A radiological scan survey of the exposed concrete building slab surfaces was performed. This was accomplished by performing the following steps:

1. A 10-foot by 10-foot area was identified and surveyed using the beta-gamma frisker to verify that contamination/radiation levels were at background. This background area is identified in Figure 1 included in Attachment A. Since the alpha detector was defective, the determination of alpha background was modified by placing a sheet of paper between the floor monitor detector and the slab. This would shield all of the alpha radiation if present and the net difference in counts would be attributed to alpha contamination. A difference in counts was not observed, so the alpha background was determined to be zero. Once this area had been surveyed, 15 static one-minute measurements were made using the floor monitor. Gamma background measurements were also taken using the Ludlum model 19.
2. The standard deviation ( $\sigma$ ) of the static floor monitor counts was determined.
3. Areas of known isotope use were identified for focused scanning surveys. The foundation slab was comprised of smaller slabs, typically 40 to 90 ft<sup>2</sup>. There were approximately 25 large individual slabs in the main area of concern. Slabs that had good surface integrity were chosen to be surveyed and accessible portions of these slabs were scanned with the floor monitor. The selection of 8 large slabs and 3 smaller slabs in the main area of concern was approximately 30% of the surface area of the foundation slab in the main area of concern. These 11 locations are identified in Figure 2 included in Attachment B. Beta-gamma spot check static counts were also performed using the Bicon Surveyor. Static measurements were acquired with the floor monitor for any area exceeding the standard deviation of the background count. There were no instances where the static measurement consistently exceeded the standard deviation of the background count. If the static measurement had exceeded the standard deviation of the background count it would have been surveyed with the Bicon Surveyor, and any area with elevated count rates would have been designated with marking paint. Alpha and beta-gamma readings could not be obtained in the secondary area of concern due to standing water. The secondary area of

---

concern is a low area and standing water was present at various depths from one to approximately four inches throughout the entire area.

4. Walkover gamma surveys were performed over most of the former Building D floor surface, for both impacted and non-impacted areas, using the Ludlum Model 19 to identify any areas of elevated background. The area covered is identified in Attachment Figure 3 included Attachment B. The extreme eastern area of the foundation slab had many parked flatbed trailers and was not easily accessible for surveying. The northeast corner of the foundation slab had a fenced area with a large shed and building materials/debris and was not easily accessible for surveying. All other areas of the slab were surveyed with the gamma walkover.
5. Survey results were documented on a survey map in  $\mu\text{R/hr}$  – see *Figure 3 in Attachment A*. Photographic documentation was also obtained and is included in Attachment C.

## 4.0 Survey Results

The background area was surveyed with the beta-gamma frisker, the floor monitor, and the micro-R meter verifying that the contamination levels were at background. Fifteen static measurements were then acquired with the floor monitor and the standard deviation of these counts was determined, as shown Table 1. The floor monitor was then used to survey eleven selected concrete slabs in the main area of concern. There were no areas in these eleven slabs that exhibited elevated count rates over the background count rate. Spot checks on these selected slabs were also made with the beta-gamma frisker and all count rates were consistent with the background count rate.



**Table 1**  
**Floor Monitor Static Measurements and Standard Deviation**

Number (n)	Measurement ( $x_i$ )	Difference from Mean ( $x_i - \text{mean}$ )	Difference from Mean Squared ( $(x_i - \text{mean})^2$ )	Variance $\sqrt{\sum(x_i - \text{mean})^2/n-1}$	Standard Deviation (2 x Variance)
1	994	7.93	62.94	34.37	69
2	991	10.93	119.54		
3	1003	1.07	1.14		
4	1064	62.07	3852.27		
5	1038	36.07	1300.80		
6	942	59.93	3592.00		
7	1019	17.07	291.27		
8	1004	2.07	4.27		
9	996	5.93	35.20		
10	929	72.93	5319.27		
11	994	7.93	62.94		
12	997	4.93	24.34		
13	994	7.93	62.94		
14	1032	30.07	904.00		
15	1032	30.07	904.00		
Average	1001.93	Total	16536.93		

A walkover survey was then completed for all of the accessible areas of the foundation slab including the secondary area of concern. The secondary area of concern was a low area and standing water was present at various depths from one to approximately four inches. Although the water could shield gamma radiation, there was not enough water present to significantly impact the survey results.

Three areas on the foundation slab were identified as having elevated gamma readings above background. These areas are identified in Figure 3 included in Attachment A. Two of these areas were identified with marking paint, and were located in areas where the concrete was either removed or deteriorated to the point where grass was growing. The third area was above brick tiles on top of the foundation slab. These three areas do not appear to be associated with any particular source or activity. All other areas of the foundation slab were found to be consistent with background measurements.

---

### Area #1

The first area of elevated readings was found in a grassy area within the main area of concern in the former Pilot Manufacturing Area. The 1-meter exposure rate was 5 to 6  $\mu\text{R/hr}$  and the highest contact exposure rate was 11 to 12  $\mu\text{R/hr}$ . The 1-meter and contact background exposure rates were 4 to 5  $\mu\text{R/hr}$ . The elevated readings were concentrated in a 4-square foot area and were painted with orange marking paint.

### Area #2

The second area of elevated readings was found above the brick tiles at the fence line running north to south near the middle of the foundation slab (the historical location of the "Cleaning/Plating" Room). The 1-meter and contact exposure rate was 6 to 7  $\mu\text{R/hr}$ . The 1-meter and contact background exposure rates were 4 to 5  $\mu\text{R/hr}$ . This area was approximately 50-foot long by 10-foot wide. Because of the size of the area, it was not marked with marking paint.

### Area #3

The third area of elevated reading was found in a grassy area near the middle of the foundation slab on the northern edge, adjacent to the former Cafeteria. The 1-meter exposure rate was 5 to 6  $\mu\text{R/hr}$  and the highest contact exposure rate was 7 to 8  $\mu\text{R/hr}$ . The 1-meter and contact background exposure rate was 4 to 5  $\mu\text{R/hr}$ . The grassy area was approximately 30-foot long by 20-foot wide and the elevated readings were fairly constant over the entire area. This area was identified with marking paint.

## **5.0 Conclusions**

In general, a majority of the surveyed areas do not appear to be impacted. Alpha and beta measurements obtained with the floor monitor did not indicate any areas that were significantly above background. In addition, walkover gamma surveys did not identify any areas where exposure rates were significantly above background. The three areas in Section 4 represent elevated readings, but do not appear to present an exposure risk. Exposures to members of the public are limited to 100 mrem per year. The observed elevated readings are approximately an

---

order of magnitude below this limit, assuming a conservative full year (2000 hour) occupancy. It is common for naturally occurring radioactive material (NORM) to be present in building materials, such as the tile bricks. This could account for the elevated reading in Area #2. Elevated readings in the two grassy areas might also be attributable to NORM; however this was not indicated by background readings taken at a location of similar soil type.

The secondary area of concern, located at the west end of the survey area, was underwater, which resulted in only gamma exposure rates being obtained. No gamma measurements above background were observed.

## **6.0 Recommendations**

The following recommendations are presented as follow-up actions to this survey. Execution of these recommendations may be dependent on the future use of the former Building D lot.

- (1) Perform a review of any historical decommissioning information for the Middle River Complex. This should include a review of all survey records and applicable release criteria used to make area release determinations.
- (2) Obtain soil and brick samples from the three areas where elevated gamma readings were observed and perform laboratory analysis to determine if radioactive constituents are present.
- (3) Pump the standing water from the secondary area of concern, clear the slab of mud and debris, and perform spot checks for alpha and beta contamination to determine if this area was impacted from previous operations.

**Attachment A**

**Figures**

Figure 1 Middle River Radiological Survey – Building D  
 Areas of Concern





Figure 2 Middle River Radiological Survey – Building D  
Alpha and Beta Survey Areas



**Attachment B**  
**Instrument Records**



**CALIBRATION  
CERTIFICATE**

Duratek Instrument Services  
628 Gallaher Road  
Kingston, TN 37763  
Phone: (865) 376-8337.  
Fax: (865) 376-8331

This Certificate will be accompanied by Calibration Charts or Readings where applicable

CUSTOMER INFORMATION				DETECTOR INFORMATION	
Customer Name: Duratek Instrument Services				Manufacturer: Ludlum	
Address: 628 Gallaher Rd Kingston, TN 37763				Detector Model: 43-37B	
Contact Name: Thomas Scott				Serial Number: 093965	
Customer Purchase Order Number: N/A		Work Order Number: 2004-01309		Evaluation Method: Source	
DETECTOR EFFICIENCY/RESPONSE/PRECISION INFORMATION					
Source Nuclide: Tc <sup>99</sup>		Serial Number: 069605		Activity (dpm): 25,200	
				Certification Date: 06/20/96	
Parameter	As Found	As Left	Precision Test		CPM
Count 1	6,630	6,630	Count 1 (Heel)		6,657
Count 2	6,658	6,658	Count 2 (Center)		6,584
Count 3	6,372	6,372	Count 3 (Toe)		6,431
Count 4	6,592	6,592	Average		6,557
Count 5	6,656	6,656	Tolerance		±10%
Count 6	6,555	6,555	Pass/Fail		Pass
Average	6,577	6,577			
Background (CPM)	1,031	1,031			
Net Counts	5,546	5,546			
Efficiency	22.0%	22.0%			
Low Sample Activity: Source #: N/A		High Sample Activity: Source #: N/A		Dead Time (DT): N/A	Calibration Constant (CC): N/A
SCALER INFORMATION			DETECTOR INFORMATION		
Model	Serial Number	Due Date	Background (cpm)	Operating Voltage	Threshold
2221	97799	01/19/05	1,031	1825V	40 = 4mV
Detector Setup Report		YES NO ✓	Barcode Report		YES NO ✓
			Voltage Plateau		YES ✓ NO
COMMENTS					
Calibrated in accordance with RP-INS-I-245 10 minute background performed			Efficiency performed on contact with 5ft. cable		
STATEMENT OF CERTIFICATION					
We Certify that the detector listed above was evaluated for proper operation prior to shipment and that it met all the Manufacturers published operating specifications. We further certify that our Calibration Measurements are traceable to the National Institute of Standards and Technology. (We are not responsible for damage incurred during shipment or use of this detector).					
Detector		Certified By: Mike Paul		Reviewed By: Thomas G. Scott	
				Date: 1-20-04	
Certification Date: 01/20/04			Certification Due: 01/20/05		



BACKGROUND PLATEAU 43-37#093965 5FT CABLE 1/19/2004

900	0
950	0
1000	0
1050	1
1100	0
1150	0
1200	2
1250	1
1300	6
1350	4
1400	1
1450	3
1500	6
1550	32
1600	77
1650	175
1700	314
1750	699
1800	1028
1850	1395
1900	106437

→ 1825V

BETA PLATEAU TC-99#119715 21,900DFM

1400	6
1450	15
1500	130
1550	698
1600	1822
1650	3072
1700	4468
1750	5502
1800	5961
1850	6268
1900	8923

→ 1825V

*Thomas G. Scott*

1-20-04



Designer and Manufacturer  
of  
Scientific and Industrial  
Instruments

# CERTIFICATE OF CALIBRATION

**LUDLUM MEASUREMENTS, INC.**  
POST OFFICE BOX 810 PH. 325-235-5494  
501 OAK STREET FAX NO. 325-235-4672  
SWEETWATER, TEXAS 79556, U.S.A.

CUSTOMER AUTOMATED ENG & ELECT SERVICES

ORDER NO. 206417/276916

Ludlum Measurements, Inc. Model 19 Serial No. 109994

Model \_\_\_\_\_ Serial No. \_\_\_\_\_

Cal. Date 19-Nov-03 Cal Due Date 19-Nov-04 Cal. Interval 1 Year Meterface 202-016

mark  applies to applicable Instr. and/or detector IAW mfg. spec. T. 73 °F RH 33 % Alt 708.8 mm Hg

New Instrument  Instrument Received  Within Toler. +10%  10-20%  Out of Tol.  Requiring Repair  Other-See comments

Mechanical ck.  Meter Zeroed  Background Subtract  Input Sens. Linearity

F/S Resp. ck.  Reset ck.  Window Operation  Geotropism

Audio ck.  Alarm Setting ck.  Batt. ck. (Min. Volt) 2.2 VDC

Calibrated in accordance with LMI SOP 14.8 rev 12/05/89.  Calibrated in accordance with LMI SOP 14.9 rev 02/07/97.

Instrument Volt Set 900 V Input Sens. 32 mV Det. Oper. \_\_\_\_\_ V at \_\_\_\_\_ mV Threshold Dial Ratio \_\_\_\_\_ = \_\_\_\_\_ mV

HV Readout (2 points) Ref./Inst. \_\_\_\_\_ / \_\_\_\_\_ V Ref./Inst. \_\_\_\_\_ / \_\_\_\_\_ V

## COMMENTS:

Calibration: GM detectors positioned perpendicular to source except for M 44-9 in which the front of probe faces source.

RANGE/MULTIPLIER	REFERENCE CAL. POINT	INSTRUMENT REC'D "AS FOUND READING"	INSTRUMENT METER READING*
5000	4000 $\mu$ R/hr	3800	4000
5000	1000 $\mu$ R/hr	900	1000
500	400 $\mu$ R/hr = 10,600 cpm	320	400
500	100 $\mu$ R/hr	80	100
250	200 $\mu$ R/hr = 35,100 cpm	160	200
250	100 $\mu$ R/hr	85	100
50	7060 cpm	32	40
50	1710 cpm	8	10
25	3510 cpm	16	20
25	876 cpm	4	5

\*Uncertainty within  $\pm 10\%$  C.F. within  $\pm 20\%$

50, 25 Range(s) Calibrated Electronically

REFERENCE CAL. POINT	INSTRUMENT RECEIVED	INSTRUMENT METER READING*	REFERENCE CAL. POINT	INSTRUMENT RECEIVED	INSTRUMENT METER READING*
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Ludlum Measurements, Inc. certifies that the above instrument has been calibrated by standards traceable to the National Institute of Standards and Technology, or to the calibration facilities of International Standards Organization members, or have been derived from accepted values of natural physical constants or have been derived by the ratio type of calibration techniques. This calibration system conforms to the requirements of ANSI/NCSL Z540-1-1994 and ANSI N323-1978. State of Texas Calibration License No. LO-1963

## Reference Instruments and/or Sources:

7 Gamma S/N  1162  G112  M565  5105  T1008  T879  E552  E551  Neutron Am-241 Be S/N T-304

Alpha S/N \_\_\_\_\_  Beta S/N \_\_\_\_\_  Other \_\_\_\_\_

\_\_\_\_\_ m 500 S/N 189509  Oscilloscope S/N \_\_\_\_\_  Multimeter S/N 80820360

Calibrated By: Mess Campbell Date 19-Nov-03

Reviewed By: WJ Robin Date 19 Nov 03

# Automated Engineering & Electronic Services Inc.

AEES Inc. 165 Deer Run Ridge Road Kingston TN 1-865-376-0229 www.aeesinc.com

## Calibration Certificate

Received Within Tolerance

Instrument Model No. 2221	Instrument Serial No. 81301	Misc1 EDI	Misc2 MB
---------------------------	-----------------------------	-----------	----------

Battery Check  Batt.Voltage: 5.9

Test Range	As Found				As Left	
	100	200	400	100	200	400
1	100	200	400	100	200	400
10	1000	2000	4000	1000	2000	4000
100	10000	20000	40000	10000	20000	40000
1000	100000	200000	400000	100000	200000	400000
10000						

High Voltage Test		
Test Point	As Found	As Left
500	505	505
1000	991	991
1500	1491	1491
2000	1995	1995

Logarithmic Meter Test				
Range	1	10	100	1000
As Found	400	3750	40000	360000
As Left	400	3750	40000	360000

Time Tests	
Test Point	Count Results
0.1	100
0.2	200
0.5	500
1	1000
2	2000
5	5000
Time base testing default = 1000 CPM	

Functional Tests	
<input checked="" type="checkbox"/> Fast/Slow	<input type="checkbox"/> Thermo Dynamic
<input checked="" type="checkbox"/> Reset	<input checked="" type="checkbox"/> Geotropism
<input checked="" type="checkbox"/> Lights	<input checked="" type="checkbox"/> HV Push Button
<input checked="" type="checkbox"/> Zero Push	<input type="checkbox"/> Over Range
<input checked="" type="checkbox"/> Count Push	<input type="checkbox"/> Alarm Ack
<input checked="" type="checkbox"/> Hold Push	

Electronic Checks / Set Points		
	As Found	As Left
Mechanical Zero:	0	0
High Voltage:	685	800
Threshold 1	7.5	10
Threshold 2	na	na
Threshold 3:	na	na
Over Load	na	na

Parts Replaced during Calibration and or Repair.

Audio Tests	
<input checked="" type="checkbox"/> AudioTest	
<input checked="" type="checkbox"/> Audio Divide	
<input checked="" type="checkbox"/> Audio Volume	
<input type="checkbox"/> Audio Alarm	
<input checked="" type="checkbox"/> HeadPhone	

Calibration Date: 8/1/03 Cal Cycle / Months 12

Callbration Due Date: 8/1/04

Calibrated By: K. Murphy

Signature: *Ken Murphy*

Remarks: ESV #917231 Due 3-3-04

# Automated Engineering & Electronic Services Inc.

AEES Inc. 165 Deer Run Ridge Road Kingston TN 1-865-376-0229 www.aeesinc.com

## Calibration Certificate

Received Within Tolerance

Instrument Model No. Surveyor M Instrument Serial No. C926B Misc1 EDI Misc2 MB

Battery Check  Batt.Voltage: Good

Test Range	Scale Range Testing					
	As Found 200	As Found 400	As Found 800	As Found 200	As Left 400	As Left 800
1	200	400	800	200	400	800
10	2000	4000	8000	2000	4000	8000
100	20000	40000	80000	20000	40000	80000
1000	200000	400000	800000	200000	400000	800000
10000						

High Voltage Test		
Test Point	As Found	As Left
500	500	500
1000	1000	1000
1500	1500	1500
2000	1950	1950

Logarithmic Meter Test				
Range	1	10	100	1000
As Found	0	0	0	0
As Left	0	0	0	0

Time Tests	
Test Point	Count Results
0.1	100
1	1000
10	10000
0	0
0	0
0	0

Time base testing  
default = 1000  
CPM

Functional Tests	
<input checked="" type="checkbox"/> Fast/Slow	<input type="checkbox"/> Thermo Dynamic
<input checked="" type="checkbox"/> Reset	<input checked="" type="checkbox"/> Geotropism
<input type="checkbox"/> Lights	<input type="checkbox"/> HV Push Button
<input type="checkbox"/> Zero Push	<input type="checkbox"/> Over Range
<input checked="" type="checkbox"/> Count Push	<input type="checkbox"/> Alarm Ack
<input type="checkbox"/> Hold Push	

Electronic Checks / Set Points		
	As Found	As Left
Mechanical Zero:	0	0
High Voltage:	900	900
Threshold 1	10	10
Threshold 2	na	na
Threshold 3:	na	na
Over Load	na	na

Parts Replaced during Calibration and or Repair.

Audio Tests	
<input type="checkbox"/>	AudioTest
<input type="checkbox"/>	Audio Divide
<input type="checkbox"/>	Audio Volume
<input type="checkbox"/>	Audio Alarm
<input type="checkbox"/>	HeadPhone

Calibration Date: 8/1/03 Cal Cycle / Months 12

Calibration Due Date: 8/1/04

Calibrated By: K Murphy

Signature: *Ken Murphy*

Remarks: ESV #917231 Due 3-3-04

# Automated Engineering & Electronic Services Inc.

AEES Inc. 165 Deer Run Ridge Road Kingston TN 1-865-376-0229 www.aeesinc.com

## Calibration Certificate

Probe Model No. 44-9      Probe Serial No. 000251      Misc1 EDI      Misc2 MB

**Probe Type**

Proportional Flow Rate / LPM 0     
  Scintillation     
  Geiger Muller

**Detector Mode Operating Voltage**

Gross Mode Operating Voltage     
 Alpha / Beta Operating Voltage     
 GM HV Set @ 900

Thresholds MV	
Threshold 1	35
Threshold 2	0
Threshold 3	0
Window Set @	0

**Cable Length:** 5 feet  
**Area:** 15.5 cm sq.  
**Dead Time:** 1 uSec  
**Temp:** 78 F. RH 78 %  
**Pressure** 762 mm/hg

**Linearity Test**  
 Heel: Mid: Toe:  
 0      0      0  
 Uniformity:(%)

**Other Tests**

Repairs Required  
 CHI sq  
 Control Chart

Source Calibrations      Results In: Efficiency

Source 1 SN. 0438      Minutes	Source 2 SN. 0439      Minutes
Background 212      Count Time: 5      cpm: 42.4	Background 212      Count Time: 5      cpm: 42.4
Source Count: 13229      Count Time: 5      cpm: 2645.8	Source Count: 19403      Count Time: 5      cpm: 3880.6
Net Counts: 2603.4      Results <span style="border: 1px solid black; padding: 2px;">11.89</span>	Net Counts: 3838.2      Results <span style="border: 1px solid black; padding: 2px;">29.04</span>
Source 3 SN. 0      Minutes	Source 4 SN. 0      Minutes
Background 0      Count Time: 0      cpm: 0	Background 0      Count Time: 0      cpm: 0
Source Count: 0      Count Time: 0      cpm: 0	Source Count: 0      Count Time: 0      cpm: 0
Net Counts: 0      Results <span style="border: 1px solid black; padding: 2px;">0</span>	Net Counts: 0      Results <span style="border: 1px solid black; padding: 2px;">0</span>

**Plateau Data**

**Source Data**

HV	Background Plot			Source Plot #1			Source Plot #2			Type	Serial#	Activity	Units	Cal Due Date
	Alpha	Beta	Gross	Alpha	Beta	Gross	Alpha	Beta	Gross					
										Source 1	TC-99 0438	21900	DPM	3/1/06
										Source 2	SRY-90 0439	15900	DPM	3/1/06
										Source 3				
										Source 4				

Calibration Date: 8/1/03 Cal Cycle / Months 12

Calibration Due Date: 8/1/04

Calibrated By:: K Murphy

Signature: *Ken Murphy*

Remarks:

# Automated Engineering & Electronic Services Inc.

AEES Inc. 165 Deer Run Ridge Road Kingston TN 1-865-376-0229 www.aeesinc.com

## Calibration Certificate

Probe Model No. 43-5      Probe Serial No. 018081      Misc1 EDI      Misc2 MB

### Probe Type

Proportional Flow Rate / LPM 0       Scintillation       Geiger Muller

### Detector Mode Operating Voltage

Gross Mode Operating Voltage 800      Alpha / Beta Operating Voltage      GM HV Set @ 0

### Thresholds MV

Threshold 1 10  
Threshold 2 0  
Threshold 3 0  
Window Set @ 0

Cable Length: 5 feet

Area: 50 cm sq.

Dead Time: 1 uSec

Temp: 78 F, RH 78 %

Pressure 762 mm/hg

Linearity Test

Heel: Mid: Toe:

0      0      0

Uniformity:(%)

### Other Tests

Repairs Required

CHI sq

Control Chart

### Source Calibrations

Results In:

Source 1 SN. 0440	Minutes	Source 2 SN. 0	Minutes
Background 8	Count Time: 5	Background 0	Count Time: 0
Source Count: 10552	Count Time: 5	Source Count: 0	Count Time: 0
Net Counts: 2108.8	Results <input type="text" value="10.99"/>	Net Counts: 0	Results <input type="text" value="0"/>
cpm: 1.6		cpm: 0	
cpm: 2110.4		cpm: 0	
Source 3 SN. 0	Minutes	Source 4 SN. 0	Minutes
Background 0	Count Time: 0	Background 0	Count Time: 0
Source Count: 0	Count Time: 0	Source Count: 0	Count Time: 0
Net Counts: 0	Results <input type="text" value="0"/>	Net Counts: 0	Results <input type="text" value="0"/>
cpm: 0		cpm: 0	
cpm: 0		cpm: 0	

### Plateau Data


### Source Data

HV	Background Plot			Source Plot #1		Source Plot #2			Type	Serial#	Activity	Units	Cal Due Date
	Alpha	Beta	Gross	Alpha	Beta	Alpha	Beta	Gross					
500			0						Source 1	TH230 0440	19200	DPM	3/11/06
550			0						Source 2				
600			0			62			Source 3				
650			0			1338			Source 4				
700			3			1951							
750			2			2089							
800			0			2159							
850			0			2131							
900			0			2178							
950			6			2228							
1000			525			2503							

Calibration Date: 8/1/03 Cal Cycle / Months 12

Calibration Due Date: 8/1/04

Callibrated By: K Murphy

Signature: 

Remarks:

# Automated Engineering & Electronic Services Inc.

AEES Inc. 165 Deer Run Ridge Road Kingston TN 1-865-376-0229 www.aeesinc.com

## Calibration Certificate

Received Within Tolerance

Instrument Model No. 2221 Misc1 EDI

Probe Model No. 43-37 Misc1 EDI

Instrument Serial No. 81328 Misc2

Probe Serial No. 093965 Misc2 Duratel Lease

Battery Check  Batt. Voltage: 6.1

Prop Flow Rate/LPM 50  Scintillation  Geiger Muller

Scale Range Testing						
Test Range	As Found			As Left		
1	100	200	400	100	200	400
10	1000	2000	4000	1000	2000	4000
100	10000	20000	40000	10000	20000	40000
1000	100000	200000	400000	100000	200000	400000
10000						

Gross Mode Op Voltg 1825 Alpha / Beta Op Volta GM HV @ 0

**Thresholds MV**  
 Thld 1 4  
 Thld 2 0  
 Thld 3 0  
 Window 0

Cable Length: 5 feet  
 Area: 500 cm sq.  
 Dead Time: 1 uSec  
 Temp: na F, RH: na %  
 Pressure na mmhg

Repairs Required  
 CHI sq  Control Chart  
 Linearity Test  
 Heel: Mid: Toe:  
 0 0 0  
 Uniformity: (%)

Logarithmic Meter Test				
Range	1	10	100	1000
As Found	375	3750	37500	400000
As Left	375	3750	37500	400000

Time Tests	
Test Point	Count Results
0.1	100
0.2	200
0.5	500
1	1000
2	2000
5	4998

Default testing at 1000 cpm

High Voltage Test		
Test HV	As Found	As Left
500	518	518
1000	1005	1005
1500	1509	1509
2000	2011	2001

Source 1 SN. 0440 Minutes Results In: Efficiency  
 Background 87 Count Time: 5 cpm: 13.4  
 Source Count: 14078 Count Time: 5 cpm: 2815.6  
 Net Counts: 2802.2 Results: 14.60

Source 2 SN. 0438  
 Background 5415 Count Time: 5 cpm: 1083  
 Source Count: 27199 Count Time: 5 cpm: 5439.8  
 Net Counts: 4356.8 Results: 19.89

Source 3 SN. 0439  
 Background 5415 Count Time: 5 cpm: 1083  
 Source Count: 30629 Count Time: 5 cpm: 6125.8  
 Net Counts: 5042.8 Results: 38.75

Source 4 SN. 0  
 Background 0 Count Time: 0 cpm: 0  
 Source Count: 0 Count Time: 0 cpm: 0  
 Net Counts: 0 Results: 0

**Functional Tests Performed**

Fast/Slow  Thermo Dynamic  
 Reset  Geotropism  
 Lights  HV Push Button  
 Zero Push  Over Range  
 Count Push  Alarm Ack  
 Hold Push

**Audio Tests**

Audio Test  
 Audio Divide  
 Audio Volume  
 Audio Alarm  
 HeadPhone

Remarks: Efficiency data only. See calibration records from Duratek for HV Cals. Alpha HV @ 1350, Beta @ 1825 V.

HV	Background Plot			Source Plot #1			Source Plot #2		
	Alpha	Beta	Gross	Alpha	Beta	Gross	Alpha	Beta	Gross

Electronic Checks / Set Points		
	As Found	As Left
Mechanical Zero:	0	0
High Voltage:	930	1825
Threshold 1	35	4
Threshold 2	na	na
Threshold 3:	na	na
Over Load	na	na

Source Data	Type	Serial#	Activity	Units	Cal Due Date
Source 1	TH230	0440	19200	DPM	3/11/06
Source 2	TC-99	0438	21900	DPM	3/11/06
Source 3	SRY-90	0439	15900	DPM	3/11/06
Source 4					

Calibration Date: 3/11/04 Cal Cycle / Months 12

Calibration Due Date: 3/11/05

Calibrated By: K Murphy

Signature: *Ken Murphy*

Remarks: ESV #917231

# Floor Monitor Portable Instrument Check Log Sheet

Alpha Frisker switched to Floor Monitor 3/18/04

Instrument Type: Ludlum 2221

Instrument Number: 81301

Cal. Date: 8-1-03

Radiation Detector Type: (α) β-γ γ

Cal. Due: 8-1-04

Date/Time	Source Check	Battery Check	Condition	Zero	Bkgd.	Initials
17 March 04 10:45	Sat. <u>Unsat.</u>	<u>Sat.</u> Unsat. 5.9 V	<u>Sat.</u> Unsat. HV = 935 V	Sat. Unsat. <u>N/A</u>	Not Recorded	<u>LS</u>
18 March 04 0855 <u>(X4B)</u>	<u>Sat.</u> Unsat. K=6.3ac / 8100	<u>Sat.</u> Unsat. 5.8 V	<u>Sat.</u> Unsat. HV=1908 V	Sat. Unsat. N/A		<u>LS</u>
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
18 March 04 Ludlum 43-37 Serial 093965	<u>Sat.</u> Unsat.	Sat. Unsat. <u>NA</u>	<u>Sat.</u> Unsat.	Sat. Unsat. <u>N/A</u>	NA	<u>LS</u>
Cal 1-20-04 Due 1-20-05	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
17 March 04 Probe Ludlum 43-5	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
Serial 018081 Cal 8-1-03 HV @ 900 V	Sat. <u>Unsat.</u>	Sat. Unsat. <u>NA</u>	<u>Sat.</u> Unsat.	Sat. Unsat. <u>N/A</u>	NA	<u>LS</u>

Th-230 = 10.99% efficiency

Reviewed By: LS

Date: 3/22/04



### Portable Instrument Check Log Sheet

Instrument Type: Ludlum Model 19 Instrument Number: 109994

Cal. Date: 11-19-03

Radiation Detector Type:     $\alpha$      $\beta$ - $\gamma$    

Cal. Due: 11-19-04

Date/Time	Source Check	Battery Check	Condition	Zero	Bkgd.	Initials
16 March 04 1430	Sat. Unsat. <u>NA</u>	Sat. Unsat. <u>Sat.</u>	Sat. Unsat. <u>Sat.</u>	Sat. Unsat. <u>N/A</u>	4 $\mu$ R/hr	<u>[Signature]</u>
19 March 04 0950	Sat. Unsat. <u>NA</u>	Sat. Unsat. <u>Sat.</u>	Sat. Unsat. <u>Sat.</u>	Sat. Unsat. <u>N/A</u>	3 $\mu$ R/hr	<u>[Signature]</u>
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		

Reviewed By: LB

Date: 3/22/04

## Portable Instrument Check Log Sheet

Instrument Type: Bicron Surveyor Instrument Number: C926B

Cal. Date: 8-1-03

Radiation Detector Type:     $\alpha$       $\beta$ - $\gamma$      $\gamma$

Cal. Due: 8-1-04

Date/Time	Source Check	Battery Check	Condition	Zero	Bkgd.	Initials
17 March 04 10:30	<input checked="" type="radio"/> Sat. Unsat. <u>Offscale</u>	<input checked="" type="radio"/> Sat. Unsat. <u>2900V</u>	<input checked="" type="radio"/> Sat. Unsat.	Sat. Unsat. <u>N/A</u>	40cpm	<u>ASD</u>
18 March 04 0900	<input checked="" type="radio"/> Sat. Unsat.	<input checked="" type="radio"/> Sat. Unsat.	<input checked="" type="radio"/> Sat. Unsat.	Sat. Unsat. <u>N/A</u>	35cpm	<u>ASD</u>
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
Probe w/ Bicron	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
Model 449 Serial 000251 Cal 8-1-03	<input checked="" type="radio"/> Sat. Unsat.	Sat. Unsat. <u>N/A</u>	<input checked="" type="radio"/> Sat. Unsat.	Sat. Unsat. <u>N/A</u>	NA	<u>ASD</u>

Tc-99 = 11.89%    Sr-90 = 29.04%

Reviewed By: LB

Date: 3/22/04

Do NOT USE Portable Instrument Check Log Sheet

Floor Monitor

Instrument Type: Ludlum 2221

Instrument Number: 81328

Cal. Date: 3-11-04

Radiation Detector Type: α β-γ β

Cal. Due: 3-11-05

Date/Time	Source Check	Battery Check	Condition	Zero	Bkgd.	Initials
17 March 04 11:30	Sat. Unsat. K + β	Sat. Unsat. 6.1 V	Sat. Unsat. Dev	Sat. Unsat. N/A	HV = 1835 V 5000 cpm	(Signature)
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
17 March 04 Probe	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		
Ludlum 43-37 Serial 093965	Sat. Unsat. α + β	Sat. Unsat. N/A	Sat. Unsat.	Sat. Unsat. N/A	N/A	(Signature)
Cal 1-20-04 Cal Due 1-20-05	Sat. Unsat.	Sat. Unsat.	Sat. Unsat.	Sat. Unsat. N/A		

Reviewed By: LB

Date: 3/22/04

**Attachment C**

**Photographs**

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 1

**Date:** March 17, 2004

**Direction:** Northeast

**Comments:** The view of the northeast corner of the lot from the south gate to D Lot. The foreground concrete slab is the old parking area and the building foundation is beyond the small grassy areas. The small portion of the slab where tractor-trailers were parked was not surveyed during the gamma walkover survey.



**Photo No.:** 2

**Date:** March 17, 2004

**Direction:** Northeast

**Comments:** The view of the southeast corner of the lot from the south gate of D Lot. The foreground concrete slab is the old parking area and the building foundation is to the left of the small grassy areas.



**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 3

**Date:** March 17, 2004

**Direction:** North



**Comments:** The view of the north area of the foundation slab from the south gate of D Lot. The foreground concrete slab is the old parking area and the building foundation is beyond the small grassy areas.

**Photo No.:** 4

**Date:** March 17, 2004

**Direction:** Northwest



**Comments:** The view of the northwest area of the foundation slab from the south gate of D Lot. The foreground concrete slab is the old parking area and the building foundation is along the fence line to the left.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 5

**Date:** March 17, 2004

**Direction:** Northwest



**Comments:** The view of the southwest area of the foundation slab from the south gate of D Lot. The foreground concrete slab is the old parking area and the building foundation is along and beyond the fence.



**Photo No.:** 6

**Date:** March 17, 2004

**Direction:** North


**Comments:** The view northward from the southwest corner of the foundation slab. This is the secondary area of concern where radiological operations were known to occur. Beta and alpha measurements were not possible in this area because the slab was not dry. A gamma walkover survey was performed of this area and the observations were consistent with background readings.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 7

**Date:** March 17, 2004

**Direction:** East



**Comments:** The view of the foundation slab from the southwest corner of the foundation slab. The main area of concern is just on the other side of the fence.

**Photo No.:** 8

**Date:** March 17, 2004

**Direction:** South



**Comments:** The view of the south gate of D Lot from the background area.



**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 9

**Date:** March 17, 2004

**Direction:** Southeast

**Comments:** A view of the background area, with the corners marked with white paint.



**Photo No.:** 10

**Date:** March 17, 2004

**Direction:** West

**Comments:** The view of the main area of concern from the background area. The gamma walkover survey of the bricked area near the fence had slightly elevated readings compared to background. The contact exposure rate was 6 to 7  $\mu\text{R/hr}$  and the background rate was 3 to 5  $\mu\text{R/hr}$ .

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 11

**Date:** March 17, 2004

**Direction:** East

**Comments:** The view of the northeast corner of the slab from the middle of the foundation slab at the north edge.



**Photo No.:** 12

**Date:** March 17, 2004

**Direction:** West

**Comments:** The view of the northwest corner of the slab from the middle of the foundation slab at the north edge. The gamma walkover survey of the grassy area in the left foreground of the picture had slightly elevated readings compared to background. The contact exposure rate was 7 to 8  $\mu\text{R/hr}$  and the background rate was 4 to 5  $\mu\text{R/hr}$ .

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 13

**Date:** March 17, 2004

**Direction:** South

**Comments:** The view of the slab looking south from the middle of the foundation slab at the north edge.



**Photo No.:** 14

**Date:** March 17, 2004

**Direction:** South

**Comments:** The view looking south from the northeast corner of the main area of concern.

LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY



**Photo No.:** 15

**Date:** March 17, 2004

**Direction:** Southwest

**Comments:** Pictured is the spray painting of the 5-foot grid on the main area of concern.



**Photo No.:** 16

**Date:** March 17, 2004

**Direction:** West

**Comments:** Pictured is the grid on the main area of concern.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 17

**Date:** March 17, 2004

**Direction:** North

**Comments:** The view looking north from the northeast corner of the main area of concern.



**Photo No.:** 18


**Date:** March 17, 2004

**Direction:** West

**Comments:** The view of the main area of concern from the northeast corner of the main area of concern.



**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 19

**Date:** March 17, 2004

**Direction:** North

**Comments:** The view looking north from the northwest corner of the main area of concern. The tunnel is visible beyond the fence just to the left of the middle of the picture. Brush and debris are blocking the entrance to the tunnel. The secondary area of concern is on the other side of the fence to the left of the photograph.



**Photo No.:** 20

**Date:** March 17, 2004

**Direction:** South

**Comments:** A close-up view of the southwest corner of the main area of concern from the northwest corner of the main area of concern. The secondary area of concern is on the other side of the fence to the right of the photograph.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 21

**Date:** March 17, 2004

**Direction:** East

**Comments:** The view east from the northwest corner of the main area of concern. The majority of the main area of concern is pictured.



**Photo No.:** 22

**Date:** March 17, 2004

**Direction:** Northeast

**Comments:** The view northeast from the northwest corner of the main area of concern.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**




**Photo No.:** 23

**Date:** March 17, 2004

**Direction:** South

**Comments:** The floor monitor is pictured from behind. The detector is in front of the cart. The radiation detection meter and flow meters are located in the back of the cart.



**Photo No.:** 24

**Date:** March 17, 2004

**Direction:** West

**Comments:** The floor monitor is pictured from the side with the regulator and P-10 gas bottle. The detector is located in the front of the cart.



**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 25

**Date:** March 18, 2004

**Direction:** North

**Comments:** The floor monitor is pictured while taking a static measurement of the background in the background area.




**Photo No.:** 26

**Date:** March 18, 2004

**Direction:** South

**Comments:** Many of the individual slabs of the foundation slab in the main area of concern were deteriorating. Grass was growing in the middle of many of the individual slabs that had crumbled. Areas like this could not be surveyed with the floor monitor.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
“D” LOT RADIOLOGICAL SURVEY**



**Photo No.:** 27

**Date:** March 18, 2004

**Direction:** South

**Comments:** Many of the individual slabs of the foundation slab in the main area of concern were starting to crumble. The top few centimeters of this slab were “puffed” and would crumble if stepped on. Areas like this could not be surveyed with the floor monitor.



**Photo No.:** 28

**Date:** March 18, 2004

**Direction:** South

**Comments:** Many of the individual slabs of the foundation slab in the main area of concern were deteriorating from the edges in. The solid portion of this slab could be surveyed with the floor monitor.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 29

**Date:** March 18, 2004

**Direction:** West

**Comments:** Many pallets and other debris were present in the main area of concern. The gamma walkover survey of this area was as close as conditions allowed.



**Photo No.:** 30

**Date:** March 18, 2004

**Direction:** North

**Comments:** The view of the northwest corner of the slab from the middle of the main area of concern. The shed apparently contained sand or salt for adverse weather conditions. Other building materials and debris were located in this area. This area was not surveyed during the gamma walkover survey.


**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 31

**Date:** March 19, 2004

**Direction:** Northeast

**Comments:** The view of all of D Lot from outside of the southwest corner of the gate.



**Photo No.:** 32

**Date:** March 19, 2004

**Direction:** West

**Comments:** The view of all of D Lot from outside of the eastern side of the fence.



**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 33

**Date:** March 19, 2004

**Direction:** North

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 1. Measurements elevated above background were not observed.



**Photo No.:** 34

**Date:** March 19, 2004

**Direction:** North

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 2. Measurements elevated above background were not observed.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 35

**Date:** March 19, 2004

**Direction:** Northeast



**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 3. Measurements elevated above background were not observed.



**Photo No.:** 36

**Date:** March 19, 2004

**Direction:** West

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 11. Measurements elevated above background were not observed.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 37

**Date:** March 19, 2004

**Direction:** North

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 5. Measurements elevated above background were not observed.



**Photo No.:** 38

**Date:** March 19, 2004

**Direction:** West

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 6. Measurements elevated above background were not observed.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 39

**Date:** March 19, 2004

**Direction:** North

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 4. Measurements elevated above background were not observed.



**Photo No.:** 40

**Date:** March 19, 2004

**Direction:** North

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 7. Measurements elevated above background were not observed.



**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**



**Photo No.:** 41

**Date:** March 19, 2004

**Direction:** West

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 8. Measurements elevated above background were not observed.



**Photo No.:** 42

**Date:** March 19, 2004

**Direction:** West

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 9. Measurements elevated above background were not observed.

**LOCKHEED MARTIN MIDDLE RIVER FACILITY  
PHOTOGRAPHIC RECORD  
"D" LOT RADIOLOGICAL SURVEY**

**Photo No.:** 43

**Date:** March 19, 2004

**Direction:** North

**Comments:** This area was surveyed with the floor monitor for alpha and beta contamination, and designated as Area 10. Measurements elevated above background were not observed.

