

**Lockheed Martin Corporation**  
**6801 Rockledge Drive MP: CCT-246**  
**Bethesda, MD 20817**  
**Telephone 301-548-2209**



January 4, 2019

**VIA PRIVATE CARRIER**

Mr. James R. Carroll  
Program Administrator  
Land Restoration Program  
Land Management Administration  
Maryland Department of the Environment  
1800 Washington Boulevard, Suite 625  
Baltimore, Maryland 21230

Subject: Transmittal of the 2018 Block E Storm Drain Monitoring Report  
Lockheed Martin Corporation – Middle River Complex  
2323 Eastern Boulevard, Middle River, Baltimore County, Maryland

Dear Mr. Carroll:

For your information, please find enclosed two hard copies with a CD of the above-referenced document. This report describes the results from the continued monitoring of the storm drain system in Block E in accordance with Lockheed Martin's Submittal entitled *Protecting the Middle River Complex Sediment Remedy from PCBs in Storm Drains* (Lockheed Martin, 2017). The document demonstrates that one manhole in Block E will be cleaned in the spring 2019 to prevent migration of impacted sediment to Dark Head Cove.

I am available for your questions; my office phone is (301) 548-2209.

Sincerely,

A handwritten signature in black ink, appearing to read "Tom D. Blackman".

Thomas D. Blackman  
Project Lead, Environmental Remediation

cc: (via email without enclosure)  
Gary Schold, MDE  
Mark Mank, MDE  
Christine Kline, Lockheed Martin  
Norman Varney, Lockheed Martin  
Michael Martin, Tetra Tech  
Cannon Silver, CDM Smith

cc: (via mail with enclosure)  
Ruth Prince, EPA  
Tom Green, LMCPI  
Mike Musheno, LMCPI

cc: (via Secure Information Exchange)  
Jann Richardson, Lockheed Martin  
Scott Heinlein, LMCPI  
Christopher Keller, LMCPI  
Glen Harriel, LMCPI

Lockheed Martin Corporation  
6801 Rockledge Drive MP: CCT-246  
Bethesda, MD 20817  
Telephone 301-548-2209



January 4, 2019

VIA PRIVATE CARRIER

Ms. Ruth Prince, PhD Toxicologist  
3LC10, Office of Remediation  
Land and Chemicals Division  
U.S. Environmental Protection Agency, Region III  
1650 Arch St.  
Philadelphia, Pennsylvania 19103-2029

Subject: Transmittal of the 2018 Block E Storm Drain Monitoring Report  
Lockheed Martin Corporation – Middle River Complex  
2323 Eastern Boulevard, Middle River, Baltimore County, Maryland

Dear Ms. Prince:

For your information, please find enclosed two hard copies with a CD of the above-referenced document. This report describes the results from the continued monitoring of the storm drain system in Block E in accordance with Lockheed Martin's Submittal entitled *Protecting the Middle River Complex Sediment Remedy from PCBs in Storm Drains* (Lockheed Martin, 2017). The document demonstrates that one manhole in Block E will be cleaned in the spring 2019 to prevent migration of impacted sediment to Dark Head Cove.

I am available for your questions; my office phone is (301) 548-2209.

Sincerely,

A handwritten signature in black ink, appearing to read "Tom D. Blackman".

Thomas D. Blackman  
Project Lead, Environmental Remediation

cc: (via email without enclosure)  
Gary Schold, MDE  
Mark Mank, MDE  
Christine Kline, Lockheed Martin  
Norman Varney, Lockheed Martin  
Michael Martin, Tetra Tech  
Cannon Silver, CDM Smith

cc: (via mail with enclosure)  
Jim Carroll, MDE  
Tom Green, LMCPI  
Mike Musheno, LMCPI

cc: (via Secure Information Exchange)  
Jann Richardson, Lockheed Martin  
Scott Heinlein, LMCPI  
Christopher Keller, LMCPI  
Glen Harriel, LMCPI

**2018 BLOCK E STORM DRAIN MONITORING REPORT  
LOCKHEED MARTIN MIDDLE RIVER COMPLEX  
2323 EASTERN BOULEVARD  
MIDDLE RIVER, MARYLAND**

Prepared for:  
Lockheed Martin Corporation

Prepared by:  
Tetra Tech, Inc.

January 2019

Approved by:  
Lockheed Martin, Inc.

Revision:                0    



---

Michael Martin, P.G.  
Regional Manager



---

Josh Mullis  
Project Geologist

---

# TABLE OF CONTENTS

| <b>Section</b>  | <b>Page</b> |
|---|-------------|
| <b>Table of Contents</b> .....                                | <b>i</b>    |
| <b>List of FIGURES</b> .....                                  | <b>ii</b>   |
| <b>List of TABLES</b> .....                                   | <b>ii</b>   |
| <b>List Appendices</b> .....                                  | <b>ii</b>   |
| <b>Acronyms</b> .....   | <b>iii</b>  |
| <b>Section 1 Introduction</b> .....                           | <b>1-1</b>  |
| <b>Section 2 Background</b> .....                             | <b>2-1</b>  |
| <b>Section 3 Investigation Approach and Methodology</b> ..... | <b>3-1</b>  |
| 3.1 Site Access, Notifications, and Permits .....             | 3-1         |
| 3.2 Field Methodology and Investigation Approach .....        | 3-1         |
| 3.3 Investigation-Derived Waste .....                         | 3-2         |
| 3.4 Sampling Requirements .....                               | 3-2         |
| 3.4.1 Sample Nomenclature and Handling .....                  | 3-2         |
| 3.4.2 Sample Collection and Documentation .....               | 3-3         |
| 3.4.3 Sample Packaging and Shipping .....                     | 3-3         |
| 3.5 Laboratory and Data Validation .....                      | 3-4         |
| <b>Section 4 Results</b> .....                                | <b>4-1</b>  |
| <b>Section 5 References</b> .....                             | <b>5-1</b>  |

---

## **TABLE OF CONTENTS (CONTINUED)**

### **LIST OF FIGURES**

- Figure 1-1 Middle River Complex Location Map  
Figure 2-1 Storm Drain Sediment Accumulation Monitoring Locations, September 2018, Block E  
Figure 4-1 Storm Drain Sampling Results, September 2018, Block E

### **LIST OF TABLES**

- Table 4-1 Comparison of Sediment Accumulation Monitoring and Inspection Results, Block E Storm Drains, June 2016, October 2017, and September 2018 Inspections  
Table 4-2 Block E Storm Drain Sediment Sampling Results, September 2018 – Polychlorinated Biphenyls  
Table 4-3 Block E Manhole (MH-09) Polychlorinated Biphenyl Results, 2013-2018

### **LIST APPENDICES**

- Appendix A—2018 Block E Storm Drain Inspection Logs  
Appendix B—MH-09 Sample Log Sheet and Chain of Custody Form  
Appendix C—Data Validation Report

---

## ACRONYMS

|                 |   |
|-----------------|---|
| ESH             | environment, safety and health                |
| HASP            | health and safety plan                        |
| IDW             | investigation-derived waste                   |
| LMCPI           | LMC Properties, Inc.                          |
| Lockheed Martin | Lockheed Martin Corporation                   |
| mg/kg           | milligrams per kilogram                       |
| MRC             | Middle River Complex                          |
| PCB             | polychlorinated biphenyl                      |
| PPE             | personal protective equipment                 |
| PRG             | preliminary remedial goal                     |
| QA              | quality assurance                             |
| QC              | quality control                               |
| Tetra Tech      | Tetra Tech, Inc.                              |
| TOC             | total organic carbon                          |
| TSS             | total suspended solids                        |
| USDOT           | United States Department of Transportation    |
| USEPA           | United States Environmental Protection Agency |
| WMP             | waste management plan                         |

---

# SECTION 1 INTRODUCTION

On behalf of Lockheed Martin Corporation (Lockheed Martin), Tetra Tech Inc. (Tetra Tech) has prepared this report summarizing additional storm drain monitoring of accumulated sediment in the Block E storm drain system. The project consists of two tasks. First, manholes and inlets along storm drain lines 006 and 008 of the Block E storm drain system were visually inspected and photographed to document the depth of sediment accumulation, influent and effluent pipe characteristics (i.e., material and diameter), and the presence or absence of debris and sediment. Second, in accordance with Lockheed Martin's submittal entitled *Protecting the Middle River Complex Sediment Remedy from PCBs in Storm Drains* (Lockheed Martin, 2017), additional storm drain monitoring of sediment accumulation in IL-1, IL-2, IL-3 (alternately identified as MH-10), and MH-9 was conducted.

The objective of this study was to monitor for sediment accumulation in the storm drain system, and to collect and analyze sediment samples for polychlorinated biphenyls (PCBs) if sufficient sediment had accumulated. Per the plan (Lockheed Martin, 2017), if an increasing trend in polychlorinated biphenyl concentrations is identified, then additional storm drain cleaning will be conducted to prevent their release to Dark Head Cove, which is adjacent to the Middle River Complex (MRC) in Middle, River, Maryland (Figure 1-1).

This report is organized into the following sections: (1) Introduction, (2) Background, (3) Investigation Approach and Methodology, (4) Results, and (5) References. Tables and figures are at the end of the report following Section 5.

---

## SECTION 2 BACKGROUND

Various field activities have been completed to assess sediment transport by stormwater in the Block E storm-drain system, to further develop the area's conceptual site model. The stormwater-management system in this area was originally created during the construction of former Building D, and several significant modifications were made to the drainage system relatively soon thereafter, presumably due to poor stormwater management as designed. The building has since been demolished, and polychlorinated biphenyl (PCB) contamination has been found in subsurface soil. The current configuration of the storm drain system is only marginally effective, and PCB-contaminated sediment and debris have been detected in Block E storm drains. Flow-through piping leading to Outfalls 005E and 005W has been blocked to prevent migration of impacted sediment to Dark Head Cove (Tetra Tech, 2016a). However, stormwater that discharges at Outfalls 006 and 008 continues to flow through the storm drain system(s), prompting studies to determine whether impacted sediment is migrating to Dark Head Cove.

Previous studies have focused on accumulating sediments that may move in the system as stormwater flow increases during storm events. The investigation for the *Block E 2016 Storm Drain Assessment Report* (Tetra Tech, 2017a) entailed the following activities:

- visual inspected manholes and inlets along storm-drain lines leading to Outfalls 006 and 008
- collected water samples at inlets and manholes, and subsequently analyzed them for total suspended solids (TSS) by United States Environmental Protection Agency (USEPA) SW846 Method 2540, and for total organic carbon (TOC) by USEPA Method 9060
- installed Hach FL900-series flow meters, initiated 30-day monitoring at IL-1, IL-5, IL-9, IL-12, IL-15, IL-25, and MH-09, and installed a rain gauge near IL-5 to record rain over one month
- installed sandbag sediment traps in CB-04, CB-06, CB-08, IL-1, IL-2, IL-7, IL-8, IL-9, IL-12, IL-21, IL-24, and IL-25 to promote sediment deposition and facilitate future collection and analysis of sediment samples



- 
- collected 16 samples from manholes and inlets having sufficient sediment, and from locations where sandbags had been placed
  - sent samples to TestAmerica for PCB Aroclor analysis by United States Environmental Protection Agency (USEPA) Method 8082A

Previous study (Tetra Tech 2017a, 2017b) results led to the development of a sampling strategy to be conducted until Block E remediation was implemented. This sampling strategy is defined in the March 2017 document *Protecting the Middle River Complex Sediment Remedy from PCBs in Storm Drains* (Lockheed Martin, 2017). In October 2017, Tetra Tech inspected the manholes and inlets of the storm-drain systems in and around Block E. Storm-drain system components for Outfalls 006 and 008 were inspected, and sediment samples were collected from the features mentioned above (if a sufficient quantity of sediment was present) and analyzed for PCBs. Figure 2-1 illustrates the location of the inspected manholes and inlets in Block E. The following tasks were completed during the October 2017 investigation:

- inspected locations of 30 storm drain manholes and inlets to determine accessibility
  - accessed 27 storm-drain manholes and inlets that could be opened
  - recorded stormwater and sediment depths, observations, and photographed conditions
- collected sediment samples (at designated manholes and inlets), and submitted sediment samples to an offsite laboratory for PCB analysis by USEPA Method 8082A:
  - sampled sediment in one manhole designated for sampling (MH-09) where accumulated sediment was sufficient
  - no samples were collected from the remaining four designated manholes and inlets proposed for sampling in the downstream end of the storm drain system, either because they lacked sufficient sediment for sampling (i.e., inlets IL-1, IL-2, and IL-3) or because they were found to be influenced by tidal water fluctuations (and therefore possible sediment backflow from Dark Head Cove; [i.e., new manhole, MH-1A])

Approximately two inches of accumulated sediment was observed in manhole MH-09 in October 2017. Sample concentrations of Aroclor-1260 at MH-09 were an order of magnitude higher than its preliminary remedial goal (PRG) of 10 milligrams per kilogram (mg/kg), a screening level established for industrial exposure to Block E soil. The PCB concentrations at MH-09 also exceeded the 0.676 mg/kg action level established for sediment remediation in Dark Head Cove. Sediment accumulation in MH-09 since the last clean out (December 2016), and PCB

---

exceedances detected in October 2017, prompted the cleaning of this manhole to prevent further sediment migration to the cove. Cleaning of MH-09 conducted on April 11, 2018 included the removal of water, sediment, and debris; the removed material was placed into drums that were subsequently removed by Clean Harbors. The drums were then transported to the Clean Harbors facility in La Porte, Texas. The April 2018 cleaning of MH-09 is fully documented in the *Block E MH-09 Storm Drain Cleaning Report* (Tetra Tech, 2018b). The information reported herein details the subsequent round of storm drain monitoring and inspections, completed in September 2018.

---

## **SECTION 3 INVESTIGATION APPROACH AND METHODOLOGY**

### **3.1 SITE ACCESS, NOTIFICATIONS, AND PERMITS**

Before starting any field work, the assigned Tetra Tech field personnel became familiar with the site-specific health and safety plan (HASP) and the respective “Safe Work” permits and emergency response plan included in the HASP. Tetra Tech conducted mandatory health and safety tailgate meetings before each day’s fieldwork. The Tetra Tech site health and safety officer also documented the topics covered and personnel in attendance. Safety requirements are addressed in detail in the site-specific Tetra Tech HASP (Tetra Tech, 2016b). Tetra Tech also followed the Middle River Complex (MRC) site waste management plan (WMP) (Tetra Tech, 2017c) that conforms to *Lockheed Martin Energy, Environment, Safety, and Health (EESH) Remediation Waste Management Procedure No. EROP 03, Revision 4* (Lockheed Martin, 2009).

Tetra Tech provided notification and coordinated access arrangements through Lockheed Martin Security and EMCOR (site maintenance). MRC tenants were informed and updated about the proposed investigation activities at the LMC Properties, Inc., (LMCPI) bi-weekly meetings. Site access and documentation conformed to the provisions of Lockheed Martin’s *Remediation Contractor’s Environment, Safety and Health (ESH) Handbook* (Lockheed Martin, 2016).

### **3.2 FIELD METHODOLOGY AND INVESTGATION APPROACH**

Catch basins, inlets, and manholes illustrated in Figure 2-1 were visually inspected on September 19, 2018 to record their present condition; these features were monitored from outside the inlet structure to identify sediment accumulation. Twenty-nine storm-drain features were accessible; inspection involved measuring dimensions of the features, classifying construction material, and evaluating sediment accumulation. IL-4 and IL-14, two inlets previously inaccessible due to cemented on lids, were able to be inspected due to the dislodging of each inlet cover using a sledgehammer. Both protective lids were not damaged and successfully put back in place after inspections were complete. “Storm Drain Inspection Forms” (Appendix A) were completed to

---

document conditions at each storm-drain feature and outfall; these forms contain photographs, the date and time of the inspection, the personnel completing the inspection, and any other notable observations.

The scope included sample collection at downstream locations IL-1, IL-2, IL-3 (alternately identified as MH-10), and/or MH-09, where sufficient sediment volume (i.e., four ounces) was present for laboratory analysis of polychlorinated biphenyls (PCBs). Upon inspection, only MH-09 contained the required sediment volume; therefore, a parent sample and corresponding duplicate sample were collected from sediment within MH-09. Tidal surface water from Outfall 008 inundates the storm drain system as far upgradient as MH-1A; therefore, although this sampling point was originally scoped for sample collection (Lockheed Martin, 2017) and had accumulated sediment, it was eliminated from the monitoring program due to its tidal influence (Lockheed Martin, 2018).

The samples were collected on September 19, 2018 by lowering a clean stainless-steel spoon with an extended handle into the manhole and transferring the sediment directly to laboratory-supplied glass jars. Samples were submitted to TestAmerica, Inc. (Test America) for PCB analysis under a standard, 21-day turn-around time. Chain-of-custody forms and sediment sample log sheets created during the sampling event are in Appendix B.

### **3.3 INVESTIGATION-DERIVED WASTE**

Investigation-derived waste (IDW) was not generated during this field effort. Personal protective equipment (PPE) worn by sampling personnel was placed in trash bags that were placed in a facility trash receptacle to be disposed of as general refuse.

### **3.4 SAMPLING REQUIREMENTS**

#### **3.4.1 Sample Nomenclature and Handling**

The sediment sample collected from manhole location MH-09 during this investigation was identified using a unique sample identification tag. The sample identification tag consisted of the location (MH-09, for the manhole location), followed by the six-digit date of collection (-091818). The duplicate sample collected carried a similar identification tag: MH for manhole, followed by

---

“DUP” for duplicate, and the six-digit date of collection (-091918). All sampling information was recorded on a field log form (see Appendix B).

Proper chain of custody procedures were followed throughout all phases of sample collection and handling to establish the evidentiary integrity of sample containers. These protocols were used to demonstrate that the samples were handled and transferred in a manner that would eliminate (or detect) possible tampering. Sample containers were released under signature from the laboratory and were accepted under signature by the sampler(s) or responsible individual who maintains custody until the sample containers were transferred to the sampler(s). Transport containers returning to the laboratory were sealed with strapping tape and a tamper-proof custody seal. The custody seal contained the signature of the individual releasing the transport container, along with the date and time.

### **3.4.2 Sample Collection and Documentation**

Log sheets were used in the field to document sample collection details. The following types of sampling information will be recorded on the field-sampling log sheets:

- site name
- date and time
- sample personnel
- chain-of-custody number
- sample type (grab or composite sample)
- sample media
- sample identification number
- sample analysis
- sample container requirements
- field observation notes

### **3.4.3 Sample Packaging and Shipping**

Samples were prepared for shipping using the following guidelines:

- Place properly identified sample container, with lid securely fastened, in a plastic bag (i.e., Ziploc-type bag), and seal bag.
- Place sample in a sturdy cooler that has been lined with a large plastic bag (i.e., a garbage bag). Tape drain plugs on coolers shut.

- 
- Place a temperature check indicator (provided by the laboratory) in each cooler to be shipped.
  - Pack with sufficient cushioning materials, such as bubble wrap, to minimize the possibility of the containers breaking.
  - Pack sample containers in ice to cool samples to 0 to 4°C.
  - Seal the large liner bag by taping or knotting its open end.
  - Place a signed copy of the chain-of-custody form in a large Ziploc-type bag and tape it inside the lid of the shipping cooler.
  - Close and seal the outside of shipping cooler using strapping tape. Place custody seals across the lid and body of cooler and under strapping tape to prevent tampering while in transit. No United States Department of Transportation (USDOT) marking is required.

### **3.5 LABORATORY AND DATA VALIDATION**

Tetra Tech used a laboratory accredited in the State of Maryland (TestAmerica, North Canton, Ohio) for the sample analyses. Sediment samples were analyzed for PCBs by United States Environmental Protection Agency (USEPA) Method 8082A. All data provided by the laboratory was validated for all quality assurance (QA)/quality control (QC) parameters including accuracy, precision, completeness, and comparability, in accordance with USEPA Region 3 Level M2 and IM1 protocols. In addition, oversight of the laboratory QA/QC were as proactive as possible to ensure valid data were produced during the sampling event, and laboratory methodology, method compliance, and any corrective actions were also evaluated. The full data validation report is attached as Appendix C.

---

## SECTION 4 RESULTS

During inspection activities on September 19, 2018, manhole and inlet features were recorded and photographed on the attached inspection logs (Table 4-1 and Appendix A). Little to no change was observed in the condition or features of the 27 manhole/inlets inspected since the previous (October 2017) inspection (see Table 4-1). However, two previously inaccessible inlets (IL-4 and IL-14) were accessed by dislodging the cemented-on covers to each manhole. The covers were placed back onto the inlets with no damage after inspections were complete. Inlet IL-11 remains the only inaccessible inlet (of 30 manhole and inlet features inspected) due to its cemented-on concrete lid. In addition, the inlet cover and reservoir at IL-20 and the subgrade near IL-23 were collapsed and deteriorated; therefore, these inlets were not opened.

Approximately one inch of accumulated sediment was observed in manhole MH-09, and primary and duplicate samples were collected and analysed. Figure 4-1 designates the manholes and inlets where sampling was considered and performed and illustrates polychlorinated biphenyl (PCB) Aroclors detected in September 2018.

As shown in Table 4-2 and the validated data report (Appendix C), Aroclor-1260 was the only polychlorinated biphenyl (PCB) detected in September 2018. Aroclor-1260 exceedances were detected at manhole MH-09 in both the original sample (140 milligrams per kilogram [mg/kg]) and the duplicate sample (190 mg/kg). These concentrations are more than an order of magnitude (ten times) higher than the 10 mg/kg preliminary remedial goal (PRG established for industrial exposure to Aroclor-1260 in Block E soil). These concentrations also exceed the sediment remedial goal (0.676 mg/kg) established during the sediment remedial action implemented in Dark Head Cove. Aroclor results from previous sediment samples collected at location MH-09 are compared to current results in Table 4-3.

Manhole MH-09 acts as a sump or sediment accumulation point because its inlet pipe is at a lower elevation than its outlet pipe. This configuration may be due to a historical stormwater system

---

reconfiguration or to retrofits that occurred during former factory operation. Standing water has been observed at MH-09 during previous field work (October 2017) and inspections (2016); the water level was typically observed to be at the lower edge of the outlet pipe, while the inlet pipe was submerged. Similar to past inspections, 18 inches of standing water (up to the lower edge of the outlet pipe) were observed in MH-09 during the September 2018 monitoring round.

The accumulation of sediment in MH-09 since its last cleaning in April 2018, and the Aroclor 1260 detections above screening levels in September 2018, requires continued cleaning of this manhole to prevent further migration of impacted sediment to Dark Head Cove. The next cleanout will occur in the spring 2019, with the next monitoring to be conducted later in the same year. Tetra Tech will provide documentation of the cleanout after completions including a description of the removal process and all waste characterization, handling and disposal information.



---

## SECTION 5 REFERENCES

- Lockheed Martin Corporation (Lockheed Martin), 2008. *Enterprise Operations (EO)-28 and Lockheed Martin Minimum Requirements for Intrusive Fieldwork Work Plans*.
- Lockheed Martin Corporation (Lockheed Martin), 2009. *Energy, Environment, Safety, and Health (EESH) Remediation Waste Management Procedure No: EROP-03, Revision 4* (effective April 17, 2009).
- Lockheed Martin Corporation (Lockheed Martin), 2016. *Remediation Contractor's ESH Handbook*, Revision 2, effective May 1.
- Lockheed Martin Corporation (Lockheed Martin), 2017. *Protecting the Middle River Complex Sediment Remedy from PCBs in Storm Drains*, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Letter report prepared by Lockheed Martin Corporation, Bethesda, Maryland. March.
- Lockheed Martin Corporation (Lockheed Martin), 2018a. *Block E Storm Drain Monitoring Report*, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Letter report prepared by Lockheed Martin Corporation, Bethesda, Maryland. February.
- Lockheed Martin Corporation (Lockheed Martin), 2018b. *Block E MH-09 Storm Drain Cleaning Report*, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Letter report prepared by Lockheed Martin Corporation, Bethesda, Maryland. June.
- Tetra Tech, Inc. (Tetra Tech), 2016a. *Outfall 005 Storm-Drain Plugging Technical Memorandum*, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Prepared by Tetra Tech, Inc., Germantown, Maryland for Lockheed Martin Corporation, Bethesda, Maryland. June.
- Tetra Tech, Inc. (Tetra Tech), 2016b. *Master Health and Safety Plan, Middle River Complex*, Revision 6, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Prepared by Tetra Tech, Inc., Germantown, Maryland for Lockheed Martin Corporation, Bethesda, Maryland. January.
- Tetra Tech, Inc. (Tetra Tech), 2017a. *Block E 2016 Storm Drain Assessment Report*, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Letter report prepared by Tetra Tech, Inc., Germantown, Maryland for Lockheed Martin Corporation, Bethesda, Maryland. August.

---

Tetra Tech, Inc. (Tetra Tech), 2017b. *Soil Remediation Investigation Addendum Report*, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Letter report prepared by Tetra Tech, Inc., Germantown, Maryland for Lockheed Martin Corporation, Bethesda, Maryland. February.


Tetra Tech, Inc. (Tetra Tech), 2017c. *Waste Management Plan*, Lockheed Martin Middle River Complex, 2323 Eastern Boulevard Middle River, Maryland. Prepared by Tetra Tech, Inc., Germantown, Maryland for Lockheed Martin Corporation, Bethesda, Maryland. December.

---


# FIGURES

---

**Figure 1-1 Middle River Complex Location Map**  
**Figure 2-1 Storm Drain Sediment Accumulation Monitoring Locations,  
September 2018, Block E**  
**Figure 4-1 Storm Drain Sampling Results, September 2018, Block E**



Source: Google Earth, 2013



**FIGURE 1-1**


**MIDDLE RIVER COMPLEX  
LOCATION MAP**

*Lockheed Martin Middle River Complex  
Middle River, Maryland*

DATE MODIFIED: 5/1/13

CREATED BY: MP





**FIGURE 2-1**  
**STORM DRAIN SEDIMENT ACCUMULATION**  
**MONITORING LOCATIONS, SEPTEMBER 2018**  
**BLOCK E**

**LEGEND**

- SEDIMENT MONITORING LOCATIONS, INSPECTED 10/12/17 AND 10/13/17
- STORM DRAIN OUTFALL
- STORM DRAIN MANHOLE
- ▼ STORM DRAIN CATCH BASIN INLET
- CONFIRMED STORM DRAIN LINE
- - - APPROXIMATE STORM DRAIN LINE
- ▭ TAX BLOCK


2014 aerial photograph provided by U.S. Geological Survey,

**Lockheed Martin Middle River Complex**  
**Middle River, Maryland**

0 62.5 125 Feet

DATE MODIFIED: 12/28/18      CREATED BY: JEE

**TETRA TECH**




**FIGURE 4-1**  
**STORM DRAIN SEDIMENT SAMPLING RESULTS, SEPTEMBER 2018, BLOCK E**

- LEGEND**
- SEDIMENT SAMPLE LOCATION
  - INSUFFICIENT SEDIMENT FOR SAMPLING AT THIS LOCATION
  - STORM DRAIN OUTFALL
  - STORM DRAIN MANHOLE
  - ▼ STORM DRAIN CATCH BASIN INLET
  - CONFIRMED STORM DRAIN LINE
  - - - APPROXIMATE STORM DRAIN LINE
  - ▭ TAX BLOCK

J = estimated value.  
 All results shown in milligrams per kilogram (mg/kg).  
 2014 aerial photograph provided by U.S. Geological Survey,

**Lockheed Martin Middle River Complex**  
**Middle River, Maryland**



DATE MODIFIED: 12/28/18

CREATED BY: JEE



---

# TABLES



---

**Table 4-1 Comparison of Sediment Accumulation Monitoring and Inspection Results,  
Block E Storm Drains, June 2016, October 2017, and September 2018 Inspections**

**Table 4-2 Block E Storm Drain Sediment Sampling Results, September 2018 –  
Polychlorinated Biphenyls**

**Table 4-3 Block E Manhole (MH-09) Polychlorinated Biphenyl Results, 2013-2018**

Table 4-1

Comparison of Sediment Accumulation Monitoring and Inspection Results, Block E Storm Drains  
 June 2016, October 2017, and September 2018 Inspections  
 Page 1 of 2

| Location | Depth of sediment accumulation (June 2016)                    | Depth of sediment accumulation (October 2017) | Sample collected October 2017? (designated locations) | Notes October 2017  | Depth of sediment accumulation (September 2018)                      | Sample collected September 2018? (designated locations) | Notes September 2018   |
|----------|---|---|---|---|--|---|--|
| CB-4     | No sediment   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |
| CB-6     | No sediment   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |
| CB-8     | No sediment   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |
| IL-1     | No sediment   | No sediment                                   | No  | None  | No sediment  | No  | None   |
| IL-2     | No sediment   | No sediment                                   | No  | None  | No sediment  | No  | None   |
| IL-4     | No sediment   | No sediment                                   | NA  | Metal slatted lid is cemented in place around edges. Wood debris visible at inlet bottom. | No sediment  | NA  | Metal lid removed from cement to reveal a brick-lined structure too narrow to determine piping   |
| IL-5     | <0.5 inches   | <0.5 inches                                   | NA  | None  | No sediment  | NA  | None   |
| IL-6     | No sediment   |   | NA  | None  | No sediment  | NA  | None   |
| IL-7     | <0.5 inches   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |
| IL-8     | No sediment   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |
| IL-9     | No sediment   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |
| IL-10    | >2 inches   | <0.5 inches                                   | NA  | None  | <1 inch  | NA  | None   |
| IL-11    | Cannot access inlet below lid due to cemented-on concrete lid |   |   |   |  |   |  |
| IL-12    | No sediment   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |
| IL-14    | Unable to remove lid from cover frame                         |   |   | None  | No sediment  | NA  | Lid removed revealing brick-lined structure; inlet from IL-15 and outlet to IL-13 with an additional six-inch corrugated metal pipe to the southeast |
| IL-15    | 1-3 inches  | 1-3 inches                                    | NA  | Bricks and rocks at bottom of inlet.  | 1-3 inches   | NA  | Bricks and rocks at inlet bottom.  |
| IL-16    | 1 inch  | <1 inch                                       | NA  | None  | No sediment  | NA  | None   |
| IL-17    | unknown   | 2 inches (estimated)                          | NA  | Sediment present under 3 feet standing water; depth not visible                           | Sediment present under 2 feet of standing water, depth not visible   | NA  | None   |
| IL-18    | unknown   | 2-4 inches (estimated)                        | NA  | Sediment present under 2 feet standing water; depth not visible                           | 5 inches sediment  | NA  | 27 inches of standing water  |
| IL-19    | >2 inches   | >4 inches                                     | Yes   | Significant debris inside (rubble, metal pipes, rebar, etc.)                              | Significant debris inside (rubble, metal pipes, rebar, etc.)         | NA  | None   |
| IL-20    | >6 inches   | NA  | NA  | Not accessed due to subsiding/collapsing subgrade next to inlet.                          | Not accessed due to subsiding and collapsing subgrade next to inlet. | NA  | None   |
| IL-23    | 2 inches  | NA  | NA  | Same as above   | Same as above  | NA  | None   |
| IL-24    | No sediment   | No sediment                                   | NA  | None  | No sediment  | NA  | None   |

Table 4-1

Comparison of Sediment Accumulation Monitoring and Inspection Results, Block E Storm Drains  
 June 2016, October 2017, and September 2018 Inspections  
 Page 2 of 2

| Location         | Depth of sediment accumulation (June 2016)    | Depth of sediment accumulation (October 2017) | Sample collected October 2017? (designated locations) | Notes October 2017             | Depth of sediment accumulation (September 2018) | Sample collected September 2018? (designated locations) | Notes September 2018                  |
|------------------|---|---|---|--------------------------------|---|---|---------------------------------------|
| IL-25            | No sediment                                   | No sediment                                   | NA  | None                           | No sediment                                     | NA  | None                                  |
| MH-1A            | NA  | 0.5 inch                                      | Yes; sample not analyzed <sup>1</sup>                 | None                           | <0.5 inches                                     | No  | None                                  |
| MH-04            | >6 inches                                     | >1 inch                                       | NA  | None                           | No sediment                                     | NA  | None                                  |
| MH-07            | 6 inches                                      | 2 inches                                      | NA  | None                           | 3 inches  | NA  | None                                  |
| MH-07A           | Caved-in vault; filled with debris at bottom. |   |   | None                           | Caved in vault; filled with debris              | NA  | None                                  |
| MH-09            | 2 inches                                      | 2 inches                                      | Yes   | Collected sample and duplicate | <b>1 inch</b>                                   | <b>Yes</b>  | <b>Collected sample and duplicate</b> |
| MH-10 (alt IL-3) | 0.5 inches                                    | No sediment                                   | NA  | None                           | No sediment                                     | NA  | None                                  |

NA – Not applicable or not accessible.

1- Tidal surface water from Outfall 008 inundates the system as far upgradient as MH-1A, so this manhole was eliminated from future monitoring events, and was not sampled during the current monitoring round.

Table 4-2

**Block E Storm Drain Sediment Sampling Results,  
September 2018 - Polychlorinated Biphenyls  
Lockheed Martin Middle River Complex  
Middle River, Maryland**

| Location<br>Sample ID                    | Block E<br>Preliminary<br>Remedial Goal<br>for Soil | MH-09        |               |
|--|---|--------------|---------------|
|  |   | MH-09-091918 | MH-DUP-091918 |
| Sample Date                              |   | 9/19/2018    | 9/19/2018     |
| <b>Polychlorinated biphenyls (mg/kg)</b> |   |              |               |
| Aroclor-1016                             | 10  | 2.6 U        | 12 U          |
| Aroclor-1221                             | 10  | 2.8 U        | 13 U          |
| Aroclor-1232                             | 10  | 2.7 U        | 12 U          |
| Aroclor-1242                             | 10  | 2.2 U        | 10 U          |
| Aroclor-1248                             | 10  | 2.8 U        | 13 U          |
| Aroclor-1254                             | 10  | 2.7 U        | 12 U          |
| Aroclor-1260                             | 10  | <b>140</b>   | <b>190</b>    |
| Aroclor-1262                             | 10  | 3.6 U        | 17 U          |
| Aroclor-1268                             | 10  | 2.7 U        | 12 U          |

mg/kg = milligrams per kilogram

PRG = preliminary remedial goal

Note: A dilution factor of five was used for MH-DUP-091918

**Bold font indicates a concentration that exceeds the industrial soil preliminary remedial goal.**

Table 4-3

**Block E Manhole (MH-09) Polychlorinated Biphenyl Results, 2013-2018**  
**Lockheed Martin Middle River Complex**  
**Middle River, Maryland**

| LOCATION<br>SAMPLE ID<br>SAMPLE DATE | Block E<br>Preliminary<br>Goal (Soil) | SD-181<br>SD-181-0-1<br>20131220 | E-MH09                      |                          |                            |                          |                            |
|--------------------------------------|---------------------------------------|----------------------------------|-----------------------------|--------------------------|----------------------------|--------------------------|----------------------------|
|                                      |                                       |                                  | E-SD-MH9-091216<br>20160912 | MH-09-101317<br>20171013 | MH-09-101317-D<br>20171013 | MH-09-091918<br>20180919 | MH-09-091918-D<br>20180919 |
| <b>PCBS (UG/KG)</b>                  |                                       |                                  |                             |                          |                            |                          |                            |
| AROCLOR-1016                         | 10000                                 | 2100 U                           | 290 U                       | 3100 U                   | 760 U                      | 2600 U                   | 12000 U                    |
| AROCLOR-1221                         | 10000                                 | 2800 U                           | 280 U                       | 2900 U                   | 720 U                      | 2800 U                   | 13000 U                    |
| AROCLOR-1232                         | 10000                                 | 2500 U                           | 190 U                       | 2000 U                   | 500 U                      | 2700 U                   | 12000 U                    |
| AROCLOR-1242                         | 10000                                 | 2400 U                           | 240 U                       | 2600 U                   | 630 U                      | 2200 U                   | 10000 U                    |
| AROCLOR-1248                         | 10000                                 | 1400 U                           | 210 U                       | 2200 U                   | 540 U                      | 2800 U                   | 13000 U                    |
| AROCLOR-1254                         | 10000                                 | 2100 U                           | 170 U                       | 1800 U                   | 440 U                      | 2700 U                   | 12000 U                    |
| AROCLOR-1260                         | 10000                                 | <b>420000</b>                    | <b>3400</b>                 | <b>100000 J</b>          | <b>34000 J</b>             | <b>140000</b>            | <b>190000</b>              |
| AROCLOR-1262                         | 10000                                 | NA                               | 97 U                        | 1000 U                   | 250 U                      | 3600 U                   | 17000 U                    |
| AROCLOR-1268                         | 10000                                 | NA                               | 240 U                       | 2600 U                   | 630 U                      | 2700 U                   | 12000 U                    |
| <b>TOTAL AROCLOR</b>                 | 10000                                 | <b>420000</b>                    | <b>NA</b>                   | <b>100000</b>            | <b>34000</b>               | <b>140000</b>            | <b>190000</b>              |

---

# APPENDICES

---

**Appendix A—2018 Block E Storm Drain Inspection Logs**  
**Appendix B—MH-09 Sample Log Sheet and Chain of Custody Form**  
**Appendix C—Data Validation Report**

---

# **APPENDIX A—2018 BLOCK E STORM DRAIN INSPECTION LOGS**



## Storm Drain Inspection Form

|            |                            |                                     |                                |
|------------|----------------------------|-------------------------------------|--------------------------------|
| Date/Time: | September 19, 2018 at 8:01 | Site:                               | MRC                            |
| Personnel: | Mullis                     | Location:                           | Block E                        |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 26.26                          |
| CB-08      | Outfall-006                | Pipe Material:                      | Reinforced Concrete Pipe (RCP) |

**Observations:**

Check if Present:

- Debris
- Sediment
- Other:

Concrete

Description of Observed Materials:

Photo 1:



Description:

Open inlet

Photo 2:



Description:

Pipe from CB-09 is 26"



### Storm Drain Inspection Form

Photo 3:



Description:

Appears to be 26" pipe with 5" of concrete accumulated on the bottom. Pipe goes to CB-07

Photo 4:

Description:

Notes:

Grate on one side had previously fallen into hole. Sheet metal covering area. Grate attempted to be removed from manhole but too heavy.

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 8:10 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 26.26   |
| CB-06      | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Open inlet

Photo 2:



Description:

Pipe from CB-07 is 26". Concrete has hardened on the bottom of the pipe



### Storm Drain Inspection Form

Photo 3:



Description:

Pipe to CB-05 is 26"

Photo 4:



Description:

Concrete accumulated in upstream pipe

Notes:

Large empty rectangular box for notes.

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 8:16 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 26.26   |
| CB-04      | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Inlet

Photo 2:



Description:

Brick and mortar inlet construction



### Storm Drain Inspection Form

Photo 3:



Description:

Pipe from CB-05 is 26" with about 5" of concrete on the bottom

Photo 4:



Description:

Pipe to CB-03 is 26"

Notes:

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 8:27 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 15.15   |
| IL-16      | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Open inlet

Photo 2:



Description:

15" pipe from CB-07



### Storm Drain Inspection Form

Photo 3:



Description:

15" pipe to IL-15 is blocked with brick and mortar except for a 3x4" opening through which water flows.

Photo 4:

Description:

Notes:



## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 8:36 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 15.15   |
| IL-15      | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris
- Sediment
- Other:

Description of Observed Materials:

Rock and brick in inlet

Photo 1:



Description:

Main photo

Photo 2:



Description:

Pipe to IL-14 is on top of photo



### Storm Drain Inspection Form

Photo 3:



Description:

Pipe to IL-14 has 15" diameter

Photo 4:



Description:

Upstream pipe to IL-16 has 15" diameter.

Notes:

One 2" pipe located 41" above the inflow pipe, plugged with soil.

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 8:44 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 15.15   |
| IL-14      | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Brick lined structure, inlet from IL-15, outlet to IL-13, additional inlet consisting of 6" CMP to the southeast

Photo 1:



Description:

15" RCP from IL-15

Photo 2:



Description:

6" CMP inlet from the southeast, possible just a drain



### Storm Drain Inspection Form

Photo 3:



Description:

15" RCP outlet to IL-13

Photo 4:

Description:

Notes:

Brick lined structure, inlet from IL-15, outlet to IL-13, additional inlet consisting of 6" CMP to the southeast. 2" of standing water

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 8:58 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 16.17   |
| IL-12      | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Open inlet

Photo 2:



Description:

16" pipe from IL-13



### Storm Drain Inspection Form

Photo 3:



Description:

17" pipe to IL-12A

Photo 4:

Description:

Notes:

Large empty rectangular box for notes.

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 9:03 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 16.16   |
| IL-8       | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Open inlet

Photo 2:



Description:

Pipe to IL-22 is 16"



# Storm Drain Inspection Form

Photo 3:



Description:

Pipe from IL-12A is 16".

Photo 4:

Description:

Notes:

Large empty rectangular box for notes.



## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 9:07 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): |         |
| IL-11      | Outfall-006                | Pipe Material:                      | Unknown |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Cannot see inside inlet

Photo 1:



Description:

Photo 2:

Description:



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 9:10 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 12      |
| IL-10      | Outfall-006                | Pipe Material:                      | Metal   |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Less than one inch of fine sediment accumulation, only one pipe which flows to IL-11. 9" of standing water

Photo 1:



Description:

Closed inlet

Photo 2:



Description:

Pipe to IL-11 is 12", Metal.



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 9:26 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 15      |
| IL-7       | Outfall-008                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Pipe to IL-6 is 15"

Photo 2:



Description:

Bottom of inlet is 3' below grade.



# Storm Drain Inspection Form

Photo 3:



Description:

Open inlet

Photo 4:

Description:

Notes:

## Storm Drain Inspection Form

|            |                            |                                     |                   |
|------------|----------------------------|-------------------------------------|-------------------|
| Date/Time: | September 19, 2018 at 9:36 | Site:                               | MRC               |
| Personnel: | Mullis                     | Location:                           | Block E           |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): |                   |
| IL-6       | Outfall-008                | Pipe Material:                      | Appears to be RCP |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Inaccessible for pipe measurements

Photo 2:



Description:

Brick and mortar construction



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:



## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 9:40 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 15.18   |
| IL-5       | Outfall-008                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:


Photo 1:



Description:

Pipe from IL-6 is 15"

Photo 2:



Description:

Pipe from IL-4 is 18"



# Storm Drain Inspection Form

Photo 3:



Description:

Pipe from IL-23 is 15"

Photo 4:



Description:

Open inlet

Notes:

Large empty rectangular box for notes.

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 9:42 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): |         |
| IL-23      | Outfall-006                | Pipe Material:                      | Unknown |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Inlet covered with rock/debris from recent pipe installation work.

Photo 2:



Description:

Massive erosion next to inlet where new pipes were installed.



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 9:50 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): |         |
| IL-4       | Outfall-008                | Pipe Material:                      | VCP     |

**Observations:**

Check if Present:

- Debris
- Sediment
- Other:

Description of Observed Materials:

Photo 1:



Description:

Inlet too small to determine piping

Photo 2:



Description:

Open inlet



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 10:04 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): | 18.18   |
| IL-3/MH-10 | Outfall-008                 | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Pipe to IL-2 is 20" and is flush with bottom of manhole.

Photo 2:



Description:

Pipe from IL-4 is 18", bottom of pipe flush with bottom of manhole



### Storm Drain Inspection Form

Photo 3:



Description:

15" pipe from MH-09. Bottom of pipe is 2.1' from bottom of manhole.

Photo 4:



Description:

Inlet covered with storm debris before removal of lid.

Notes:



## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 10:15 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): | 00.15   |
| MH-09      | Outfall-008                 | Pipe Material:                      | RCP     |

### Observations:

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Approximately 1" of fine sediment on bottom. Approximately 18" of standing water

Photo 1:



Description:

Open manhole

Photo 2:




Description:

Outflow pipe to MH-10/IL-3 is 15" RCP



### Storm Drain Inspection Form

Photo 3:



Description:

Fine sediment on bottom approximately 1" depth

Photo 4:

Description:

Notes:

Bottom lip of outflow pipe is 14 inches above the bottom of the manhole with the water level even with bottom lip. Inflow pipe is unknown. PCB sample collected with duplicate. See Sample Log sheet

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 10:25 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): |         |
| IL-20      | Outfall-008                 | Pipe Material:                      | Unknown |

**Observations:**

Check if Present:

- Debris
- Sediment
- Other:

Description of Observed Materials:

Inlet filled in with brick and debris

Photo 1:



Description:

Open inlet

Photo 2:



Description:

Inlet filled with rock, brick, and debris



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 10:30 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet/Outlet): | 12      |
| IL-19      | Outfall-008                 | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris
- Sediment
- Other:

Description of Observed Materials:

Photo 1:



Description:

Debris

Photo 2:



Description:

Debris



### Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

17 inches of debris and sediment. Total depth is 2.7' from top of manhole. Top of manhole is 1.2' below grade. Two pipes of estimated diameter of 12" coming from IL-18 and going to IL-20.

## Storm Drain Inspection Form

|            |                             |                                     |           |
|------------|-----------------------------|-------------------------------------|-----------|
| Date/Time: | September 19, 2018 at 10:38 | Site:                               | MRC       |
| Personnel: | Mullis                      | Location:                           | Block E   |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): |           |
| MH-7       | Outfall-008                 | Pipe Material:                      | See notes |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

21" of standing water and 3" of sediment


Photo 1:



Description:

Depth of manhole

Photo 2:



Description:

21" of standing water in manhole



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:



## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 11:16 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): |         |
| MH-7A      | Outfall-008                 | Pipe Material:                      | Unknown |

**Observations:**

Check if Present:

- Debris
- Sediment
- Other:

Description of Observed Materials:

Concrete and brick debris w/standing water.

Photo 1:



Description:

Open manhole

Photo 2:



Description:

Various concrete and metal debris



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

## Storm Drain Inspection Form

|            |                             |                                     |                      |
|------------|-----------------------------|-------------------------------------|----------------------|
| Date/Time: | September 19, 2018 at 11:21 | Site:                               | MRC                  |
| Personnel: | Mullis                      | Location:                           | Block E              |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): |                      |
| MH-4       | Outfall-008                 | Pipe Material:                      | Unknown, not visible |

**Observations:**

Check if Present:

- Debris
- Sediment
- Other:

Description of Observed Materials:

Water flowing from sheet flow at surface, pipes are blocked at least partially. Significant sediment and debris is observable, could not find pipe opening when prodding sidewalls with rod.

Photo 1:



Description:

2' diameter concrete manhole

Photo 2:



Description:

Bottom of manhole is 1.5 feet below top of manhole



### Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

Water flowing from sheet flow at surface, pipes are blocked at least partially. Significant sediment and debris is observable, could not find pipe opening when prodding sidewalls with rod.

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 11:24 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): |         |
| IL-18      | Outfall-008                 | Pipe Material:                      | Unknown |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Water is 27" high with 5" of fine sediment


Photo 1:



Description:

Open inlet

Photo 2:



Description:

Water level high



# Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 11:35 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): |         |
| IL-17      | Outfall-008                 | Pipe Material:                      | Unknown |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

22" of standing water. Cannot tell where pipes are located due to standing water

Photo 1:



Description:

Open inlet

Photo 2:



Description:

Water inside inlet



### Storm Drain Inspection Form

Photo 3:

Photo 4:

Description:

Description:

Notes:

Cannot tell where pipes are located due to standing water



## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 12:28 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): | 30.30   |
| IL-24      | Outfall-006                 | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Top pipe is 15" and comes from IL-23

Photo 2:



Description:

The lower pipe is 30" and comes from IL-9



# Storm Drain Inspection Form

Photo 3:



Description:

30" pipe to IL-25 shown

Photo 4:



Description:

Open inlet

Notes:

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 12:33 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): | 30.30   |
| IL-25      | Outfall-006                 | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Open inlet

Photo 2:



Description:

Brick and mortar inlet construction



### Storm Drain Inspection Form

Photo 3:



Description:

30" pipe to outfall-006

Photo 4:



Description:

30" pipe from IL-24

Notes:

Large empty rectangular box for notes.

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 12:36 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): | 18.18   |
| IL-2       | Outfall-008                 | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Brick and mortar inlet construction

Photo 2:



Description:

Pipe to IL-01 is 18"



# Storm Drain Inspection Form

Photo 3:



Description:

Pipe to IL-3 is 18"

Photo 4:

Description:

Notes:

Large empty rectangular box for notes.

## Storm Drain Inspection Form

|            |                             |                                     |         |
|------------|-----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 12:39 | Site:                               | MRC     |
| Personnel: | Mullis                      | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:           | Pipe Diameter (inch. Inlet.Outlet): | 18.18   |
| IL-1       | Outfall-008                 | Pipe Material:                      | VCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Brick and mortar inlet construction.

Photo 2:



Description:

Pipe from the IL-2 is 18"



### Storm Drain Inspection Form

Photo 3:



Description:

Pipe to OF-008 is 18"

Photo 4:

Description:

Notes:

Pipe from the north could not be confidently determined. Appears to range from 18-20"



## Storm Drain Inspection Form

|            |                            |                                     |          |
|------------|----------------------------|-------------------------------------|----------|
| Date/Time: | September 19, 2018 at 1:21 | Site:                               | MRC      |
| Personnel: | Mullis                     | Location:                           | Block E  |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 18.32    |
| MH-1A      | Outfall-008                | Pipe Material:                      | HDPE/RCP |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Less than half an inch of sediment, water flowing into pipe from creek and into pipe from IL-1. Not enough to collect sample

Photo 1:



Description:

New manhole lid

Photo 2:



Description:

32" HDPE outlet pipe to Dark Head Cove



# Storm Drain Inspection Form

Photo 3:



Description:

CMP inflow from IL-1

Photo 4:

Description:

Notes:

Large empty rectangular box for notes.

## Storm Drain Inspection Form

|            |                            |                                     |         |
|------------|----------------------------|-------------------------------------|---------|
| Date/Time: | September 19, 2018 at 1:56 | Site:                               | MRC     |
| Personnel: | Mullis                     | Location:                           | Block E |
| MH/IL ID:  | Storm Drain Line:          | Pipe Diameter (inch. Inlet.Outlet): | 30.30   |
| IL-9       | Outfall-006                | Pipe Material:                      | RCP     |

**Observations:**

Check if Present:

- Debris  
 Sediment  
 Other:

Description of Observed Materials:

Photo 1:



Description:

Brick and mortar construction

Photo 2:



Description:

Open inlet



### Storm Drain Inspection Form


Photo 3:



Description:

30" pipe to IL-24

Photo 4:



Description:

30" pipe from JB-1

Notes:

Large empty rectangular box for notes.

---

**APPENDIX B—MH-09 SAMPLE LOG SHEET AND CHAIN OF  
CUSTODY FORM**



# SOIL & SEDIMENT SAMPLE LOG SHEET

TETRA TECH, INC.

|                    |                    |                   |              |
|--------------------|--------------------|-------------------|--------------|
| Project Site Name: | Block E, MRC       | Sample ID No. :   | MH-09-091918 |
| Project Number:    | 11207533           | Sample Location : | MH-09        |
| Sample Type:       | Sediment           | Sampled By:       | Josh Mullis  |
| Date:              | September 19, 2018 | COC No.:          |              |

### Sampling Data

Time: 14:00

Top Depth (ft. BGS):

Bottom Depth (ft. BGS):

PID (ppm):

Composite     Grab

Description (sand, silt, clay, moisture, etc):

Coarse grained sandy gravel. Wet, odorous.

| Analysis     | Container Requirements | Preservation | Quantity |
|--------------|------------------------|--------------|----------|
| PCBs (8082A) | 4oz glass jar          | Unpres       | 1        |
| —            | —                      | —            |          |
| —            | —                      | —            |          |
| —            | —                      | —            |          |
| —            | —                      | —            |          |

### Observations / Notes / Duplicate Data

Duplicate collected MH-DUP-091918

Signature :

**Client Contact**  
 Company Name: *Tetra Tech Inc*  
 Address: *20251 Century Blvd. Ste. 200*  
 City/State/Zip: *Exton, PA, 19341*  
 Phone: *301-528-3021*  
 Fax: \_\_\_\_\_

**Project Name:** *Storm Drain Inspections*  
**Site:** *MPC Block E*  
**P.O.#:** *ASH PM*

**Regulatory Program:**  DW  NPDES  RCRA  Other: \_\_\_\_\_

**Project Manager:** *Amy McVining*  
**Tel/Fax:** *301-528-3021*

**Analysis Turnaround Time**  
 CALENDAR DAYS     WORKING DAYS  
 TAT if different from Below  
 2 weeks     STANDARD  
 1 week  
 2 days  
 1 day

**Site Contact:** *J. Phillips*      **Date:** *9/19/18*  
**Lab Contact:** *J. McFadden*      **Carrier:** *Fed Ex*

**Sampler:** \_\_\_\_\_      **COC No.:** *1* of *1*      **COCs**

**For Lab Use Only:**  
 Walk-in Client: \_\_\_\_\_  
 Lab Sampling: \_\_\_\_\_  
 Job / SDG No.: \_\_\_\_\_

**Sample Identification**

| Sample Identification              | Sample Date    | Sample Time | Sample Type (C=Comp, G=Grab) | Matrix     | # of Cont. | Filtered Sample (Y/N) | Perform MS/MSD (Y/N) | Sample Specific Notes |
|------------------------------------|----------------|-------------|------------------------------|------------|------------|-----------------------|----------------------|-----------------------|
| <i>MH-09-091918</i>                | <i>9/19/18</i> | <i>1330</i> | <i>G</i>                     | <i>SED</i> | <i>1</i>   |                       |                      |                       |
| <i>MH-00P-091918</i>               | <i>9/19/18</i> | <i>—</i>    | <i>G</i>                     | <i>SED</i> | <i>1</i>   |                       |                      |                       |
| <i>9/19/18</i>                     |                |             |                              |            |            |                       |                      |                       |
| <i>240-101687 Chain of Custody</i> |                |             |                              |            |            |                       |                      |                       |

**Preservation Used:** *1= Ice, 2= HCl, 3= H2SO4, 4=HNO3, 5=NaOH, 6= Other*

**Possible Hazard Identification:** Please List any EPA Waste Codes for the sample in the Comments Section if the lab is to dispose of the sample.  
 Non-Hazard     Flammable     Skin Irritant     Poison B     Unknown

**Special Instructions/QC Requirements & Comments:** *Sediment samples collected from Manhole-7 @ MPC Block E for Storm Drain Inspections*

**Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)**  
 Return to Client     Disposal by Lab     Archive for: \_\_\_\_\_ Months

**Custody Seal No.:** \_\_\_\_\_      **Cooler Temp. (°C):** Obs'd: \_\_\_\_\_      **Corr'd:** \_\_\_\_\_      **Therm ID No.:** \_\_\_\_\_

**Relinquished by:** *[Signature]*      **Company:** *Tetra Tech Inc*      **Date/Time:** *9/19/18 15:30*  
**Received by:** *[Signature]*      **Company:** *ppc*      **Date/Time:** *9-21-18 930*

**Relinquished by:** \_\_\_\_\_      **Company:** \_\_\_\_\_      **Date/Time:** \_\_\_\_\_  
**Received by:** \_\_\_\_\_      **Company:** \_\_\_\_\_      **Date/Time:** \_\_\_\_\_

---

# APPENDIX C—DATA VALIDATION REPORT





## TETRA TECH

## INTERNAL CORRESPONDENCE

TO: M. MARTIN                      DATE: NOVEMBER 14, 2018  
FROM: LEIGH A. CIOFANI              COPIES: DV FILE  
SUBJECT: ORGANIC DATA VALIDATION – PCB  
MRC-BLOCK E – FULL REVIEW  
SAMPLE DELIVERY GROUP (SDG) 240-101687-1  
SAMPLES: 2 / Solid / PCB  
MH-09-091918                      MH-DUP-091918

### **OVERVIEW**

The sample set for MRC-Block E, SDG 240-101687-1, consists of two (2) solid environmental samples. The samples were analyzed for polychlorinated biphenyls (PCBs). One field duplicate pair is included in this SDG: MH-09-091918 and MH-DUP-091918.

The samples were collected by Tetra Tech on September 19, 2018, and analyzed by TestAmerica. Analyses were conducted in accordance with SW-846 Method 8082A analytical and reporting protocols.

The data contained in this SDG were validated with regard to the following parameters: data completeness, holding times, initial/continuing calibrations, laboratory method blank results, surrogate spike recoveries, laboratory control sample results, internal standard recoveries, chromatographic resolution, analyte identification, field duplicate precision, analyte quantitation, and detection limits. Areas of concern with respect to data quality are listed below.

### **MAJOR PROBLEMS**

- None.

### **MINOR PROBLEMS**

- None.

### **NOTES**

Non-detected results were reported to the MDL.

Sample MH-09-091918 was analyzed at a dilution factor of 100.

Sample MH-DUP-091918 was analyzed at a dilution factor of 500.

Surrogate percent recoveries %Rs for tetrachloro-m-xylene (TCX) and decachlorobiphenyl (DCB) were greater than laboratory quality control limits for sample MH-09-091918 and 0% for MH-DUP-091918. No qualification was necessary because these samples were analyzed at dilution factors of 100 and 500, respectively.

### **EXECUTIVE SUMMARY**


**Laboratory Performance Issues:** None.

**TO: M. MARTIN**  
**DATE: 11/14/18**

**PAGE 2**  
**SDG 240-101687-1**


**Other Factors Affecting Data Quality:** None.

The data for these analyses were reviewed with reference to the USEPA "National Functional Guidelines for Organic Superfund Methods Data Review" (January 2017). The text of this report has been formulated to address only those problem areas affecting data quality.



---

Tetra Tech  
Leigh A. Ciofani  
Environmental Scientist/Data Validator



---

Tetra Tech  
Joseph A. Samchuck  
Data Validation Manager

**Attachments:**

Appendix A – Qualified Analytical Results  
Appendix B – Results as Reported by the Laboratory  
Appendix C – Support Documentation

**APPENDIX A**

**QUALIFIED ANALYTICAL RESULTS**

### Data Qualifier Definitions

The following definitions provide brief explanations of the validation qualifiers assigned to results in the data review process.

|           |   |
|-----------|---|
| <b>U</b>  | The analyte was analyzed for, but was not detected at a level greater than or equal to the level of the adjusted detection limit.   |
| <b>J</b>  | The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample (due either to the quality of the data generated because certain quality control criteria were not met, or the concentration of the analyte was below the reporting limit).   |
| <b>J+</b> | The result is an estimated quantity, but the result may be biased high.   |
| <b>J-</b> | The result is an estimated quantity, but the result may be biased low.  |
| <b>UJ</b> | The analyte was analyzed for, but was not detected. The reported detection limit is approximate and may be inaccurate or imprecise.   |
| <b>NJ</b> | The analyte has been "tentatively identified" or "presumptively" as present and the associated numerical value is the estimated concentration in the sample.  |
| <b>R</b>  | The sample result (detected) is unusable due to the quality of the data generated because certain criteria were not met. The analyte may or may not be present in the sample.   |
| <b>UR</b> | The sample result (nondetected) is unusable due to the quality of the data generated because certain criteria were not met. The analyte may or may not be present in the sample.  |
| <b>X</b>  | The sample results (including non-detects) were affected by serious deficiencies in the ability to analyze the sample and meet published method and project quality control criteria. The presence or absence of the analyte cannot be substantiated by the data provided. Acceptance or rejection of the data should be decided by the project team, but exclusion of the data is recommended. |

**Qualifier Codes:**

- A = Lab Blank Contamination
- B = Field Blank Contamination
- C = Calibration Noncompliance (i.e., % RSDs, %Ds, ICVs, CCVs, RRFs, etc.)
- C01 = GC/MS Tuning Noncompliance
- D = MS/MSD Recovery Noncompliance
- E = LCS/LCSD Recovery Noncompliance
- F = Lab Duplicate Imprecision
- G = Field Duplicate Imprecision
- H = Holding Time Exceedance
- I = ICP Serial Dilution Noncompliance
- J = ICP PDS Recovery Noncompliance; MSA's  $r < 0.995$
- K = ICP Interference - includes ICS % R Noncompliance
- L = Instrument Calibration Range Exceedance
- M = Sample Preservation Noncompliance
- N = Internal Standard Noncompliance
- N01 = Internal Standard Recovery Noncompliance Dioxins
- N02 = Recovery Standard Noncompliance Dioxins
- N03 = Clean-up Standard Noncompliance Dioxins
- O = Poor Instrument Performance (i.e., base-time drifting)
- P = Uncertainty near detection limit ( $< 2 \times$  IDL for inorganics and  $<$ CRQL for organics)
- Q = Other problems (can encompass a number of issues; i.e.chromatography,interferences, etc.)
- R = Surrogates Recovery Noncompliance
- S = Pesticide/PCB Resolution
- T = % Breakdown Noncompliance for DDT and Endrin
- U = RPD between columns/detectors  $>40\%$  for positive results determined via GC/HPLC
- V = Non-linear calibrations; correlation coefficient  $r < 0.995$
- W = EMPC result
- X = Signal to noise response drop
- Y = Percent solids  $<30\%$
- Z = Uncertainty at 2 standard deviations is greater than sample activity
- Z1 = Tentatively Identified Compound considered presumptively present
- Z2 = Tentatively Identified Compound column bleed
- Z3 = Tentatively Identified Compound aldol condensate
- Z4 = Sample activity is less than the at uncertainty at 3 standard deviations and greater than the MDC
- Z5 = Sample activity is less than the at uncertainty at 3 standard deviations and less than the MDC

|   |            |              |      |        |               |      |  |
|---|------------|--------------|------|--------|---------------|------|--|
| <b>PROJ_NO: 07533</b><br><b>SDG: 240-101687-1</b><br><b>FRACTION: PCB</b><br><b>MEDIA: SOIL</b> | NSAMPLE    | MH-09-091918 |      |        | MH-DUP-091918 |      |  |
|   | LAB_ID     | 240-101687-1 |      |        | 240-101687-2  |      |  |
|   | SAMP_DATE  | 9/19/2018    |      |        | 9/19/2018     |      |  |
|   | QC_TYPE    | NM           |      |        | FD            |      |  |
|   | UNITS      | UG/KG        |      |        | UG/KG         |      |  |
|   | PCT_SOLIDS | 84.9         |      |        | 88.7          |      |  |
|   | DUP_OF     |              |      |        | MH-09-091918  |      |  |
| PARAMETER   | RESULT     | VQL          | QLCD | RESULT | VQL           | QLCD |  |
| AROCLOR-1016  | 2600       | U            |      | 12000  | U             |      |  |
| AROCLOR-1221  | 2800       | U            |      | 13000  | U             |      |  |
| AROCLOR-1232  | 2700       | U            |      | 12000  | U             |      |  |
| AROCLOR-1242  | 2200       | U            |      | 10000  | U             |      |  |
| AROCLOR-1248  | 2800       | U            |      | 13000  | U             |      |  |
| AROCLOR-1254  | 2700       | U            |      | 12000  | U             |      |  |
| AROCLOR-1260  | 140000     |              |      | 190000 |               |      |  |
| AROCLOR-1262  | 3600       | U            |      | 17000  | U             |      |  |
| AROCLOR-1268  | 2700       | U            |      | 12000  | U             |      |  |

**APPENDIX B**

**RESULTS AS REPORTED BY THE LABORATORY**

FORM I  
PCBS ORGANICS ANALYSIS DATA SHEET

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Client Sample ID: MH-09-091918 Lab Sample ID: 240-101687-1  
 Matrix: Solid Lab File ID: P2092756.D  
 Analysis Method: 8082A Date Collected: 09/19/2018 14:30  
 Extraction Method: 3540C Date Extracted: 09/25/2018 09:30  
 Sample wt/vol: 10.05(g) Date Analyzed: 09/28/2018 03:35  
 Con. Extract Vol.: 10(mL) Dilution Factor: 100  
 Injection Volume: 1(uL) GC Column: CLP-1 (0.53mm) ID: 0.53(mm)  
 % Moisture: 15.1 GPC Cleanup: (Y/N) N  
 Analysis Batch No.: 347579 Units: ug/Kg

| CAS NO.    | COMPOUND NAME | RESULT | Q | RL   | MDL  |
|------------|---------------|--------|---|------|------|
| 12674-11-2 | Aroclor-1016  | 2600   | U | 5900 | 2600 |
| 11104-28-2 | Aroclor-1221  | 2800   | U | 5900 | 2800 |
| 11141-16-5 | Aroclor-1232  | 2700   | U | 5900 | 2700 |
| 53469-21-9 | Aroclor-1242  | 2200   | U | 5900 | 2200 |
| 12672-29-6 | Aroclor-1248  | 2800   | U | 5900 | 2800 |
| 11097-69-1 | Aroclor-1254  | 2700   | U | 5900 | 2700 |
| 11096-82-5 | Aroclor-1260  | 140000 |   | 5900 | 2600 |
| 37324-23-5 | Aroclor-1262  | 3600   | U | 5900 | 3600 |
| 11100-14-4 | Aroclor-1268  | 2700   | U | 5900 | 2700 |

| CAS NO.   | SURROGATE              | %REC | Q   | LIMITS |
|-----------|------------------------|------|-----|--------|
| 877-09-8  | Tetrachloro-m-xylene   | 130  | p X | 14-128 |
| 2051-24-3 | DCB Decachlorobiphenyl | 221  | X   | 10-132 |



FORM I  
PCBS ORGANICS ANALYSIS DATA SHEET

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Client Sample ID: MH-DUP-091918 Lab Sample ID: 240-101687-2  
 Matrix: Solid Lab File ID: P2092757.D  
 Analysis Method: 8082A Date Collected: 09/19/2018 00:00  
 Extraction Method: 3540C Date Extracted: 09/25/2018 09:30  
 Sample wt/vol: 10.44(g) Date Analyzed: 09/28/2018 03:50  
 Con. Extract Vol.: 10 (mL) Dilution Factor: 500  
 Injection Volume: 1 (uL) GC Column: CLP-1 (0.53mm) ID: 0.53 (mm)  
 % Moisture: 11.3 GPC Cleanup: (Y/N) N  
 Analysis Batch No.: 347579 Units: ug/Kg

| CAS NO.    | COMPOUND NAME | RESULT | Q | RL    | MDL   |
|------------|---------------|--------|---|-------|-------|
| 12674-11-2 | Aroclor-1016  | 12000  | U | 27000 | 12000 |
| 11104-28-2 | Aroclor-1221  | 13000  | U | 27000 | 13000 |
| 11141-16-5 | Aroclor-1232  | 12000  | U | 27000 | 12000 |
| 53469-21-9 | Aroclor-1242  | 10000  | U | 27000 | 10000 |
| 12672-29-6 | Aroclor-1248  | 13000  | U | 27000 | 13000 |
| 11097-69-1 | Aroclor-1254  | 12000  | U | 27000 | 12000 |
| 11096-82-5 | Aroclor-1260  | 190000 |   | 27000 | 12000 |
| 37324-23-5 | Aroclor-1262  | 17000  | U | 27000 | 17000 |
| 11100-14-4 | Aroclor-1268  | 12000  | U | 27000 | 12000 |

| CAS NO.   | SURROGATE              | %REC | Q | LIMITS |
|-----------|------------------------|------|---|--------|
| 877-09-8  | Tetrachloro-m-xylene   | 0    | X | 14-128 |
| 2051-24-3 | DCB Decachlorobiphenyl | 0    | X | 10-132 |

**APPENDIX C**  
**SUPPORT DOCUMENTATION**

## CASE NARRATIVE

Client: Tetra Tech, Inc.

Project: MRC Block E Storm Drains

Report Number: 240-101687-1

With the exceptions noted as flags or footnotes, standard analytical protocols were followed in the analysis of the samples and no problems were encountered or anomalies observed. In addition all laboratory quality control samples were within established control limits, with any exceptions noted below. Each sample was analyzed to achieve the lowest possible reporting limit within the constraints of the method. In some cases, due to interference or analytes present at high concentrations, samples were diluted. For diluted samples, the reporting limits are adjusted relative to the dilution required.

TestAmerica Canton attests to the validity of the laboratory data generated by TestAmerica facilities reported herein. All analyses performed by TestAmerica facilities were done using established laboratory SOPs that incorporate QA/QC procedures described in the application methods. TestAmerica's operations groups have reviewed the data for compliance with the laboratory QA/QC plan, and data have been found to be compliant with laboratory protocols unless otherwise noted below.

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in this report. Pursuant to NELAP, this report may not be reproduced, except in full, without the written approval of the laboratory.

Calculations are performed before rounding to avoid round-off errors in calculated results.

All holding times were met and proper preservation noted for the methods performed on these samples, unless otherwise detailed in the individual sections below.

All solid sample results are reported on an "as received" basis unless otherwise indicated by the presence of a % solids value in the method header.

This laboratory report is confidential and is intended for the sole use of TestAmerica and its client.

### **RECEIPT**

The samples were received on 9/21/2018 9:30 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 3.1° C.

### **POLYCHLORINATED BIPHENYLS (PCBS)**

Samples MH-09-091918 (240-101687-1) and MH-DUP-091918 (240-101687-2) were analyzed for polychlorinated biphenyls (PCBs) in accordance with EPA SW-846 Method 8082A. The samples were prepared on 09/25/2018 and analyzed on 09/28/2018.

Surrogates are added during the extraction process prior to dilution. When the sample dilution is 5X or greater, surrogate recoveries are diluted out and no corrective action is required. All of the samples in this data set analyzed for PCBs were subjected to the sulfuric acid clean-up procedure before instrumental analysis, per EPA Method 3665A.

DCB Decachlorobiphenyl and Tetrachloro-m-xylene failed the surrogate recovery criteria high for MH-09-091918 (240-101687-1). DCB Decachlorobiphenyl and Tetrachloro-m-xylene failed the surrogate recovery criteria low for MH-DUP-091918 (240-101687-2).

Samples MH-09-091918 (240-101687-1)[100X] and MH-DUP-091918 (240-101687-2)[500X] required dilution prior to analysis. The reporting limits have been adjusted accordingly.

The following samples were diluted due to abundance of target analytes: MH-09-091918 (240-101687-1) and MH-DUP-091918 (240-101687-2). As such, surrogate recoveries are below the calibration range or are not reported, and elevated reporting limits (RLs) are provided.

The Aroclors in the continuing calibration verification (CCV) met criteria; however, the Decachlorobiphenyl surrogate failed to meet criteria at -28.2%. After careful evaluation the data is reported. MH-09-091918 (240-101687-1) and MH-DUP-091918 (240-101687-2)

The following samples required a tetrabutylammonium sulfite (TBA) clean-up to reduce matrix interferences caused by sulfur: MH-09-091918 (240-101687-1) and MH-DUP-091918 (240-101687-2). Reagents: 3800824, 3792600 and 3715673.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

### **PERCENT SOLIDS**

Samples MH-09-091918 (240-101687-1) and MH-DUP-091918 (240-101687-2) were analyzed for percent solids in accordance with

# Definitions/Glossary

Client: Tetra Tech, Inc.  
Project/Site: MRC Block E Storm Drains

TestAmerica Job ID: 240-101687-1

## Qualifiers

### GC Semi VOA

| Qualifier | Qualifier Description   |
|-----------|---|
| U         | Indicates the analyte was analyzed for but not detected.  |
| X         | Surrogate is outside control limits   |
| p         | The %RPD between the primary and confirmation column/detector is >40%. The lower value has been reported. |

## Glossary

| Abbreviation   | These commonly used abbreviations may or may not be present in this report.                                 |
|----------------|---|
| α              | Listed under the "D" column to designate that the result is reported on a dry weight basis                  |
| %R             | Percent Recovery  |
| CFL            | Contains Free Liquid  |
| CNF            | Contains No Free Liquid   |
| DER            | Duplicate Error Ratio (normalized absolute difference)  |
| Dil Fac        | Dilution Factor   |
| DL             | Detection Limit (DoD/DOE)   |
| DL, RA, RE, IN | Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample |
| DLC            | Decision Level Concentration (Radiochemistry)   |
| EDL            | Estimated Detection Limit (Dioxin)  |
| LOD            | Limit of Detection (DoD/DOE)  |
| LOQ            | Limit of Quantitation (DoD/DOE)   |
| MDA            | Minimum Detectable Activity (Radiochemistry)  |
| MDC            | Minimum Detectable Concentration (Radiochemistry)   |
| MDL            | Method Detection Limit  |
| ML             | Minimum Level (Dioxin)  |
| NC             | Not Calculated  |
| ND             | Not Detected at the reporting limit (or MDL or EDL if shown)  |
| PQL            | Practical Quantitation Limit  |
| QC             | Quality Control   |
| RER            | Relative Error Ratio (Radiochemistry)   |
| RL             | Reporting Limit or Requested Limit (Radiochemistry)   |
| RPD            | Relative Percent Difference, a measure of the relative difference between two points                        |
| TEF            | Toxicity Equivalent Factor (Dioxin)   |
| TEQ            | Toxicity Equivalent Quotient (Dioxin)   |

ASTM Method D2216-80. The samples were analyzed on 09/25/2018.

No analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

# Method Summary

Client: Tetra Tech, Inc.  
Project/Site: MRC Block E Storm Drains

TestAmerica Job ID: 240-101687-1

---

---

| <b>Method</b> | <b>Method Description</b>                              | <b>Protocol</b> | <b>Laboratory</b> |
|---------------|--|-----------------|-------------------|
| 8082A         | Polychlorinated Biphenyls (PCBs) by Gas Chromatography | SW846           | TAL CAN           |
| Moisture      | Percent Moisture                                       | EPA             | TAL CAN           |
| 3540C         | Soxhlet Extraction                                     | SW846           | TAL CAN           |

**Protocol References:**

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

**Laboratory References:**

TAL CAN = TestAmerica Canton, 4101 Shuffel Street NW, North Canton, OH 44720, TEL (330)497-9396

# Sample Summary

Client: Tetra Tech, Inc.  
Project/Site: MRC Block E Storm Drains

TestAmerica Job ID: 240-101687-1

---

---

| <b>Lab Sample ID</b> | <b>Client Sample ID</b> | <b>Matrix</b> | <b>Collected</b> | <b>Received</b> |
|----------------------|-------------------------|---------------|------------------|-----------------|
| 240-101687-1         | MH-09-091918            | Solid         | 09/19/18 14:30   | 09/21/18 09:30  |
| 240-101687-2         | MH-DUP-091918           | Solid         | 09/19/18 00:00   | 09/21/18 09:30  |

TestAmerica Sacramento North Canton, OH  
 880 Riverside Parkway  
 West Sacramento, CA 95605  
 Phone: 916.373.5600 Fax:

Chain of Custody Record 240275  
 2,2 / C3.1

TestAmerica  
 THE LEADER IN ENVIRONMENTAL TESTING  
 TestAmerica Laboratories, Inc.  
 TAL-8210 (0713)

Regulatory Program:  DW  NPDES  RCRA  Other:

|  |  |  |             |   |        |                            |                        |               |  |
|--|--|--|-------------|---|--------|----------------------------|------------------------|---------------|--|
| Client Contact   |  | Project Manager: Amy McDivney  |             | Site Contact: J. Mullis   |        | Date: 9/19/18              |                        | COC No:       |  |
| Company Name: Tetra Tech Inc   |  | Tel/Fax: 301-528-3021  |             | Lab Contact: J. Metadden  |        | Carrier: FedEx             |                        | 1 of 1 COCs   |  |
| Address: 20251 Century Blvd. Ste. 200  |  | Analysis Turnaround Time   |             |   |        |                            |                        |               |  |
| City/State/Zip: Sacramento, CA, 95879  |  | <input type="checkbox"/> CALENDAR DAYS <input type="checkbox"/> WORKING DAYS<br>TAT (if different from Below)  |             |   |        |                            |                        |               |  |
| Phone: 301-528-3021  |  | <input type="checkbox"/> 2 weeks<br><input type="checkbox"/> 1 week <b>STANDARD</b><br><input type="checkbox"/> 2 days<br><input type="checkbox"/> 1 day |             |   |        |                            |                        |               |  |
| Fax:   |  | Filtered Sample (Y/N) _____<br>Perform MS / MSD (Y/N) _____<br>PCBs 5082A  |             |   |        |                            |                        |               |  |
| Project Name: Storm Drain Inspections  |  |  |             |   |        |                            |                        |               |  |
| Site: MRE Block E  |  |  |             |   |        |                            |                        |               |  |
| PO#: Ash PM  |  |  |             |   |        |                            |                        |               |  |
| Sample Identification  |  | Sample Date  | Sample Time | Sample Type (C=Comp, G=Grab)  | Matrix | # of Cont.                 | Sample Specific Notes: |               |  |
| MH-09-091918   |  | 9/19/18  | N30         | G   | SED    | 1                          | X                      |               |  |
| MH-DUP-091918  |  | 9/19/18  | —           | G   | SED    | 1                          | X                      |               |  |
| Preservation Used: 1=Ice, 2=HCl, 3=H2SO4, 4=HNO3, 5=NaOH, 6=Other  |  | 1, 1   |             |   |        |                            |                        |               |  |
| Possible Hazard Identification:<br>Are any samples from a listed EPA Hazardous Waste? Please List any EPA Waste Codes for the sample in the Comments Section if the lab is to dispose of the sample. |  |  |             | Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)   |        |                            |                        |               |  |
| <input checked="" type="checkbox"/> Non-Hazardous <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown       |  |  |             | <input type="checkbox"/> Return to Client <input checked="" type="checkbox"/> Disposal by Lab <input type="checkbox"/> Archive for _____ Months |        |                            |                        |               |  |
| Special Instructions/QC Requirements & Comments: - Sediment samples collected from Manhole-9 @ MRE Block E for Storm drain inspections   |  |  |             |   |        |                            |                        |               |  |
| Custody Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No   |  | Custody Seal No.:  |             | Cooler Temp. (°C): Obs'd:   |        | Corr'd:                    |                        | Therm ID No.: |  |
| Relinquished by: [Signature]   |  | Company: Tetra Tech Inc  |             | Date/Time: 9/20/18 15:20  |        | Received by: [Signature]   |                        | Company: TPL  |  |
| Relinquished by:   |  | Company:   |             | Date/Time:  |        | Received by:               |                        | Company:      |  |
| Relinquished by:   |  | Company:   |             | Date/Time:  |        | Received in Laboratory by: |                        | Company:      |  |

Page 147 of 148





**TestAmerica Canton Sample Receipt Form/Narrative**  
**Canton Facility**

Login # : 101687

Client TETRA TECH Site Name                      Cooler unpacked by: POP  
 Cooler Received on 9-21-18 Opened on 9-21-18

FedEx: 1<sup>st</sup> Grd  Exp  UPS  FAS  Clipper  Client Drop Off  TestAmerica Courier  Other

Receipt After-hours: Drop-off Date/Time                      Storage Location                     

TestAmerica Cooler # TA Foam Box  Client Cooler  Box  Other   
 Packing material used:  Bubble Wrap  Foam  Plastic Bag  None  Other   
 COOLANT:  Wet Ice  Blue Ice  Dry Ice  Water  None

1. Cooler temperature upon receipt  See Multiple Cooler Form  
 IR GUN# IR-8 (CF +0.9 °C) Observed Cooler Temp. 22 °C Corrected Cooler Temp. 3.1 °C  
 IR GUN #36 (CF +0.6 °C) Observed Cooler Temp.              °C Corrected Cooler Temp.              °C
2. Were tamper/custody seals on the outside of the cooler(s)? If Yes Quantity 1 Yes  No   
 -Were the seals on the outside of the cooler(s) signed & dated? Yes  No  NA   
 -Were tamper/custody seals on the bottle(s) or bottle kits (LLHg/MeHg)? Yes  No   
 -Were tamper/custody seals intact and uncompromised? Yes  No  NA
3. Shippers' packing slip attached to the cooler(s)? Yes  No   
 4. Did custody papers accompany the sample(s)? Yes  No   
 5. Were the custody papers relinquished & signed in the appropriate place? Yes  No   
 6. Was/were the person(s) who collected the samples clearly identified on the COC? Yes  No   
 7. Did all bottles arrive in good condition (Unbroken)? Yes  No   
 8. Could all bottle labels be reconciled with the COC? Yes  No   
 9. Were correct bottle(s) used for the test(s) indicated? Yes  No   
 10. Sufficient quantity received to perform indicated analyses? Yes  No   
 11. Are these work share samples? Yes  No   
 If yes, Questions 12-16 have been checked at the originating laboratory.
12. Were all preserved sample(s) at the correct pH upon receipt? Yes  No  NA  pH Strip Lot# HC849161  
 13. Were VOAs on the COC? Yes  No   
 14. Were air bubbles >6 mm in any VOA vials?  Larger than this. Yes  No  NA   
 15. Was a VOA trip blank present in the cooler(s)? Trip Blank Lot #                      Yes  No   
 16. Was a LL Hg or Me Hg trip blank present?                      Yes  No

Tests that are not checked for pH by Receiving:  
 VOAs  
 Oil and Grease  
 TOC

Contacted PM                      Date                      by                      via Verbal Voice Mail Other                     

Concerning                     

**17. CHAIN OF CUSTODY & SAMPLE DISCREPANCIES**

Samples processed by:

POP

**18. SAMPLE CONDITION**

Sample(s)                      were received after the recommended holding time had expired.  
 Sample(s)                      were received in a broken container.  
 Sample(s)                      were received with bubble >6 mm in diameter. (Notify PM)

**19. SAMPLE PRESERVATION**

Sample(s)                      were further preserved in the laboratory.  
 Time preserved:                      Preservative(s) added/Lot number(s):

## FIELD DUPLICATE PRECISION

| ORIGINAL ID  | DUP ID        | FRACTION | ANALYTE      | ORIGINAL | DUPLICATE | RL    | RPD   | RPD > 50% | ORIGINAL SAMPLE CONC >RL | DUPLICATE SAMPLE CONC >RL | DIFFERENCE >2XRL |
|--------------|---------------|----------|--------------|----------|-----------|-------|-------|-----------|--------------------------|---------------------------|------------------|
| MH-09-091918 | MH-DUP-091918 | PCB      | AROCLOR-1260 | 140000   | 190000    | 27000 | 30.30 | FALSE     | TRUE                     | TRUE                      | FALSE            |

# Method 8082A

---

Polychlorinated Biphenyls (PCBs)  
(GC) by Method 8082A

FORM II  
PCBS SURROGATE RECOVERY

Lab Name: TestAmerica Canton

Job No.: 240-101687-1

SDG No.: \_\_\_\_\_

Matrix: Solid

Level: Low

GC Column (2): CLP-1 (0.53 ID: 0.53 (mm))

| Client Sample ID | Lab Sample ID          | TCX2 #  | DCBP2 # |
|------------------|------------------------|---------|---------|
| MH-09-091918     | 240-101687-1           | 130 p X | 221 X   |
| MH-DUP-091918    | 240-101687-2           | 0 X     | 0 X     |
|                  | MB<br>240-347068/19-A  | 62      | 59      |
|                  | LCS<br>240-347068/20-A | 80      | 57      |

TCX = Tetrachloro-m-xylene  
DCBP = DCB Decachlorobiphenyl

QC LIMITS  
14-128  
10-132

# Column to be used to flag recovery values

FORM III  
PCBS LAB CONTROL SAMPLE RECOVERY

Lab Name: TestAmerica Canton Job No.: 240-101687-1

SDG No.: \_\_\_\_\_

Matrix: Solid Level: Low Lab File ID: P2092753.D

Lab ID: LCS 240-347068/20-A Client ID: \_\_\_\_\_

| COMPOUND     | SPIKE<br>ADDED<br>(ug/Kg) | LCS<br>CONCENTRATION<br>(ug/Kg) | LCS<br>%<br>REC | QC<br>LIMITS<br>REC | # |
|--------------|---------------------------|---------------------------------|-----------------|---------------------|---|
| Aroclor-1016 | 1000                      | 806                             | 81              | 47-120              |   |
| Aroclor-1260 | 1000                      | 628                             | 63              | 46-120              |   |

# Column to be used to flag recovery and RPD values

FORM IV  
PCBS METHOD BLANK SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: MB 240-347068/19-A  
 Matrix: Solid Date Extracted: 09/25/2018 09:01  
 Lab File ID: (1) P2092752.D Lab File ID: (2) P2092752.D  
 Date Analyzed: (1) 09/28/2018 02:37 Date Analyzed: (2) 09/28/2018 02:37  
 Instrument ID: (1) A2HP2 Instrument ID: (2) A2HP2  
 GC Column: (1) CLP-2 (0.53m ID: 0.53(mm)) GC Column: (2) CLP-1 (0.53m ID: 0.53(mm))

THIS METHOD BLANK APPLIES TO THE FOLLOWING SAMPLES:

| CLIENT SAMPLE ID | LAB SAMPLE ID       | DATE<br>ANALYZED 1 | DATE<br>ANALYZED 2 |
|------------------|---------------------|--------------------|--------------------|
|                  | LCS 240-347068/20-A | 09/28/2018 02:52   | 09/28/2018 02:52   |
| MH-09-091918     | 240-101687-1        | 09/28/2018 03:35   | 09/28/2018 03:35   |
| MH-DUP-091918    | 240-101687-2        | 09/28/2018 03:50   | 09/28/2018 03:50   |

FORM I  
PCBS ORGANICS ANALYSIS DATA SHEET

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Client Sample ID: \_\_\_\_\_ Lab Sample ID: MB 240-347068/19-A  
 Matrix: Solid Lab File ID: P2092752.D  
 Analysis Method: 8082A Date Collected: \_\_\_\_\_  
 Extraction Method: 3540C Date Extracted: 09/25/2018 09:01  
 Sample wt/vol: 10(g) Date Analyzed: 09/28/2018 02:37  
 Con. Extract Vol.: 10(mL) Dilution Factor: 1  
 Injection Volume: 1(uL) GC Column: CLP-1 (0.53mm) ID: 0.53 (mm)  
 % Moisture: \_\_\_\_\_ GPC Cleanup: (Y/N) N  
 Analysis Batch No.: 347579 Units: ug/Kg

| CAS NO.    | COMPOUND NAME | RESULT | Q | RL | MDL |
|------------|---------------|--------|---|----|-----|
| 12674-11-2 | Aroclor-1016  | 22     | U | 50 | 22  |
| 11104-28-2 | Aroclor-1221  | 24     | U | 50 | 24  |
| 11141-16-5 | Aroclor-1232  | 23     | U | 50 | 23  |
| 53469-21-9 | Aroclor-1242  | 19     | U | 50 | 19  |
| 12672-29-6 | Aroclor-1248  | 24     | U | 50 | 24  |
| 11097-69-1 | Aroclor-1254  | 23     | U | 50 | 23  |
| 11096-82-5 | Aroclor-1260  | 22     | U | 50 | 22  |
| 37324-23-5 | Aroclor-1262  | 31     | U | 50 | 31  |
| 11100-14-4 | Aroclor-1268  | 23     | U | 50 | 23  |

| CAS NO.   | SURROGATE              | %REC | Q | LIMITS |
|-----------|------------------------|------|---|--------|
| 877-09-8  | Tetrachloro-m-xylene   | 62   |   | 14-128 |
| 2051-24-3 | DCB Decachlorobiphenyl | 59   |   | 10-132 |

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 17:01 Calibration End Date: 09/05/2018 18:15 Calibration ID: 46822

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:      | LAB FILE ID: |
|---------|---------------------|--------------|
| Level 1 | STD005 240-343960/4 | P2090504.D   |
| Level 2 | STD01 240-343960/5  | P2090505.D   |
| Level 3 | STD02 240-343960/6  | P2090506.D   |
| Level 4 | STD05 240-343960/7  | P2090507.D   |
| Level 5 | STD1 240-343960/8   | P2090508.D   |
| Level 6 | STD15 240-343960/9  | P2090509.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R^2 OR COD | # | MIN R^2 OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|------------|---|----------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |            |   |                |
| PCB-1232 Peak 1 | 0.0180<br>0.0155 | 0.0179 | 0.0183 | 0.0166 | 0.0173 | Ave        |             | 0.0173 |    |   | 6.3     |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 2 | 0.0128<br>0.0112 | 0.0119 | 0.0130 | 0.0120 | 0.0129 | Ave        |             | 0.0123 |    |   | 5.9     |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 3 | 0.0274<br>0.0265 | 0.0278 | 0.0287 | 0.0273 | 0.0288 | Ave        |             | 0.0277 |    |   | 3.1     |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 4 | 0.0112<br>0.0109 | 0.0107 | 0.0119 | 0.0114 | 0.0120 | Ave        |             | 0.0114 |    |   | 4.6     |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 5 | 0.0038<br>0.0038 | 0.0033 | 0.0041 | 0.0038 | 0.0041 | Ave        |             | 0.0038 |    |   | 7.8     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 1 | 0.0383<br>0.0400 | 0.0433 | 0.0444 | 0.0416 | 0.0431 | Ave        |             | 0.0418 |    |   | 5.4     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 2 | 0.0579<br>0.0559 | 0.0577 | 0.0612 | 0.0571 | 0.0591 | Ave        |             | 0.0582 |    |   | 3.2     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 3 | 0.0497<br>0.0460 | 0.0474 | 0.0501 | 0.0468 | 0.0488 | Ave        |             | 0.0481 |    |   | 3.4     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 4 | 0.1131<br>0.1126 | 0.1094 | 0.1189 | 0.1150 | 0.1202 | Ave        |             | 0.1149 |    |   | 3.5     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 5 | 0.0496<br>0.0454 | 0.0484 | 0.0510 | 0.0475 | 0.0489 | Ave        |             | 0.0485 |    |   | 3.9     |      | 20.0 |          |            |   |                |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.



FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53(mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 17:01 Calibration End Date: 09/05/2018 18:15 Calibration ID: 46822

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:      | LAB FILE ID: |
|---------|---------------------|--------------|
| Level 1 | STD005 240-343960/4 | P2090504.D   |
| Level 2 | STD01 240-343960/5  | P2090505.D   |
| Level 3 | STD02 240-343960/6  | P2090506.D   |
| Level 4 | STD05 240-343960/7  | P2090507.D   |
| Level 5 | STD1 240-343960/8   | P2090508.D   |
| Level 6 | STD15 240-343960/9  | P2090509.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE             |          |          |          |           | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|----------------------|----------|----------|----------|-----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6       | LVL 2    | LVL 3    | LVL 4    | LVL 5     | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1232 Peak 1 | BNB    | Ave        | 1088589<br>31219144  | 2367379  | 4620065  | 11181220 | 20959208  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 2 | BNB    | Ave        | 771208<br>22590191   | 1567244  | 3277989  | 8083963  | 15559151  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 3 | BNB    | Ave        | 1651765<br>53537160  | 3680181  | 7221035  | 18430649 | 34841378  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 4 | BNB    | Ave        | 677465<br>22063265   | 1414444  | 3002726  | 7668418  | 14499283  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 5 | BNB    | Ave        | 231840<br>7620926    | 434392   | 1027407  | 2573991  | 4985206   | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 1 | BNB    | Ave        | 2311426<br>80807319  | 5725661  | 11179261 | 28114677 | 52098735  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 2 | BNB    | Ave        | 3489816<br>112917254 | 7625689  | 15431084 | 38595872 | 71538473  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 3 | BNB    | Ave        | 2996237<br>92877395  | 6262943  | 12616331 | 31603322 | 59091284  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 4 | BNB    | Ave        | 6820120<br>227480005 | 14466393 | 29975432 | 77665996 | 145449518 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 5 | BNB    | Ave        | 2990431<br>91733147  | 6398480  | 12847624 | 32080312 | 59213860  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 17:01 Calibration End Date: 09/05/2018 18:15 Calibration ID: 46823

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:      | LAB FILE ID: |
|---------|---------------------|--------------|
| Level 1 | STD005 240-343960/4 | P2090504.D   |
| Level 2 | STD01 240-343960/5  | P2090505.D   |
| Level 3 | STD02 240-343960/6  | P2090506.D   |
| Level 4 | STD05 240-343960/7  | P2090507.D   |
| Level 5 | STD1 240-343960/8   | P2090508.D   |
| Level 6 | STD15 240-343960/9  | P2090509.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R^2 OR COD | # | MIN R^2 OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|------------|---|----------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |            |   |                |
| PCB-1232 Peak 1 | 0.0195<br>0.0163 | 0.0206 | 0.0201 | 0.0180 | 0.0179 | Ave        |             | 0.0187 |    |   | 8.6     |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 2 | 0.0164<br>0.0129 | 0.0176 | 0.0155 | 0.0145 | 0.0143 | Ave        |             | 0.0152 |    |   | 11.0    |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 3 | 0.0301<br>0.0261 | 0.0300 | 0.0301 | 0.0287 | 0.0285 | Ave        |             | 0.0289 |    |   | 5.4     |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 4 | 0.0119<br>0.0108 | 0.0126 | 0.0114 | 0.0118 | 0.0118 | Ave        |             | 0.0117 |    |   | 5.2     |      | 20.0 |          |            |   |                |
| PCB-1232 Peak 5 | 0.0051<br>0.0051 | 0.0056 | 0.0057 | 0.0056 | 0.0055 | Ave        |             | 0.0054 |    |   | 5.1     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 1 | 0.0318<br>0.0272 | 0.0310 | 0.0318 | 0.0302 | 0.0298 | Ave        |             | 0.0303 |    |   | 5.6     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 2 | 0.0482<br>0.0423 | 0.0476 | 0.0497 | 0.0470 | 0.0460 | Ave        |             | 0.0468 |    |   | 5.4     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 3 | 0.0382<br>0.0348 | 0.0385 | 0.0398 | 0.0378 | 0.0377 | Ave        |             | 0.0378 |    |   | 4.4     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 4 | 0.0872<br>0.0797 | 0.0898 | 0.0907 | 0.0874 | 0.0860 | Ave        |             | 0.0868 |    |   | 4.5     |      | 20.0 |          |            |   |                |
| PCB-1262 Peak 5 | 0.0629<br>0.0570 | 0.0639 | 0.0657 | 0.0628 | 0.0613 | Ave        |             | 0.0622 |    |   | 4.8     |      | 20.0 |          |            |   |                |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53(mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 17:01 Calibration End Date: 09/05/2018 18:15 Calibration ID: 46823

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:      | LAB FILE ID: |
|---------|---------------------|--------------|
| Level 1 | STD005 240-343960/4 | P2090504.D   |
| Level 2 | STD01 240-343960/5  | P2090505.D   |
| Level 3 | STD02 240-343960/6  | P2090506.D   |
| Level 4 | STD05 240-343960/7  | P2090507.D   |
| Level 5 | STD1 240-343960/8   | P2090508.D   |
| Level 6 | STD15 240-343960/9  | P2090509.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE             |         |          |          |          | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|----------------------|---------|----------|----------|----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6       | LVL 2   | LVL 3    | LVL 4    | LVL 5    | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1232 Peak 1 | BNB    | Ave        | 939755<br>25969480   | 2080363 | 4050716  | 9467563  | 17285919 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 2 | BNB    | Ave        | 788214<br>20483256   | 1781521 | 3129329  | 7648324  | 13852586 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 3 | BNB    | Ave        | 1448200<br>41527132  | 3036892 | 6066615  | 15069518 | 27532728 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 4 | BNB    | Ave        | 573200<br>17183220   | 1277837 | 2290704  | 6188283  | 11392384 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1232 Peak 5 | BNB    | Ave        | 245231<br>8115941    | 561979  | 1156121  | 2949423  | 5353359  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 1 | BNB    | Ave        | 1530068<br>43389682  | 3132669 | 6409736  | 15859348 | 28823173 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 2 | BNB    | Ave        | 2321752<br>67405014  | 4812500 | 10027490 | 24694946 | 44440641 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 3 | BNB    | Ave        | 1840470<br>55410039  | 3896493 | 8021239  | 19865715 | 36451053 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 4 | BNB    | Ave        | 4200132<br>126901679 | 9090763 | 18286086 | 45959354 | 83097489 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1262 Peak 5 | BNB    | Ave        | 3028399<br>90752859  | 6463570 | 13251161 | 33018256 | 59205586 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 18:30 Calibration End Date: 09/05/2018 19:43 Calibration ID: 46830

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/10 | P2090510.D   |
| Level 2 | STD01 240-343960/11  | P2090511.D   |
| Level 3 | STD02 240-343960/12  | P2090512.D   |
| Level 4 | STD05 240-343960/13  | P2090513.D   |
| Level 5 | STD1 240-343960/14   | P2090514.D   |
| Level 6 | STD15 240-343960/15  | P2090515.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R^2 OR COD | # | MIN R^2 OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|------------|---|----------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |            |   |                |
| PCB-1242 Peak 1 | 0.0122<br>0.0119 | 0.0116 | 0.0117 | 0.0117 | 0.0113 | Ave        |             | 0.0117 |    |   | 2.4     |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 2 | 0.0214<br>0.0217 | 0.0213 | 0.0213 | 0.0215 | 0.0209 | Ave        |             | 0.0213 |    |   | 1.3     |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 3 | 0.0487<br>0.0522 | 0.0481 | 0.0484 | 0.0490 | 0.0495 | Ave        |             | 0.0493 |    |   | 3.1     |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 4 | 0.0201<br>0.0215 | 0.0198 | 0.0194 | 0.0205 | 0.0206 | Ave        |             | 0.0203 |    |   | 3.6     |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 5 | 0.0082<br>0.0083 | 0.0072 | 0.0077 | 0.0078 | 0.0079 | Ave        |             | 0.0078 |    |   | 4.8     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 1 | 0.1398<br>0.1481 | 0.1315 | 0.1343 | 0.1361 | 0.1397 | Ave        |             | 0.1382 |    |   | 4.2     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 2 | 0.1283<br>0.1363 | 0.1259 | 0.1277 | 0.1280 | 0.1304 | Ave        |             | 0.1294 |    |   | 2.8     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 3 | 0.1123<br>0.1182 | 0.1080 | 0.1103 | 0.1103 | 0.1138 | Ave        |             | 0.1121 |    |   | 3.2     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 4 | 0.0452<br>0.0466 | 0.0429 | 0.0445 | 0.0443 | 0.0452 | Ave        |             | 0.0448 |    |   | 2.7     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 5 | 0.3238<br>0.3564 | 0.3130 | 0.3234 | 0.3264 | 0.3420 | Ave        |             | 0.3308 |    |   | 4.7     |      | 20.0 |          |            |   |                |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 18:30 Calibration End Date: 09/05/2018 19:43 Calibration ID: 46830

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/10 | P2090510.D   |
| Level 2 | STD01 240-343960/11  | P2090511.D   |
| Level 3 | STD02 240-343960/12  | P2090512.D   |
| Level 4 | STD05 240-343960/13  | P2090513.D   |
| Level 5 | STD1 240-343960/14   | P2090514.D   |
| Level 6 | STD15 240-343960/15  | P2090515.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE              |          |          |           |           | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|-----------------------|----------|----------|-----------|-----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6        | LVL 2    | LVL 3    | LVL 4     | LVL 5     | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1242 Peak 1 | BNB    | Ave        | 767479<br>21084350    | 1533116  | 3090900  | 7489194   | 14532263  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 2 | BNB    | Ave        | 1352540<br>38462328   | 2807577  | 5629016  | 13822113  | 26721985  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 3 | BNB    | Ave        | 3072436<br>92643936   | 6353975  | 12803805 | 31444586  | 63475249  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 4 | BNB    | Ave        | 1271100<br>38190975   | 2613254  | 5130095  | 13134946  | 26367941  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 5 | BNB    | Ave        | 514168<br>14651433    | 953736   | 2026255  | 4995338   | 10151242  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 1 | BNB    | Ave        | 8818338<br>262723826  | 17374728 | 35534788 | 87355358  | 179044742 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 2 | BNB    | Ave        | 8097159<br>241797747  | 16629011 | 33790888 | 82183502  | 167059549 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 3 | BNB    | Ave        | 7086076<br>209773492  | 14263545 | 29181969 | 70812287  | 145782554 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 4 | BNB    | Ave        | 2850924<br>82599755   | 5669800  | 11783432 | 28449408  | 57934109  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 5 | BNB    | Ave        | 20430129<br>632364666 | 41348701 | 85594863 | 209543953 | 438308669 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 18:30 Calibration End Date: 09/05/2018 19:43 Calibration ID: 46831

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/10 | P2090510.D   |
| Level 2 | STD01 240-343960/11  | P2090511.D   |
| Level 3 | STD02 240-343960/12  | P2090512.D   |
| Level 4 | STD05 240-343960/13  | P2090513.D   |
| Level 5 | STD1 240-343960/14   | P2090514.D   |
| Level 6 | STD15 240-343960/15  | P2090515.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R^2 OR COD | # | MIN R^2 OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|------------|---|----------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |            |   |                |
| PCB-1242 Peak 1 | 0.0137<br>0.0109 | 0.0129 | 0.0138 | 0.0136 | 0.0126 | Ave        |             | 0.0129 |    |   | 8.5     |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 2 | 0.0273<br>0.0205 | 0.0258 | 0.0256 | 0.0242 | 0.0229 | Ave        |             | 0.0244 |    |   | 10.0    |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 3 | 0.0545<br>0.0438 | 0.0527 | 0.0515 | 0.0496 | 0.0486 | Ave        |             | 0.0501 |    |   | 7.5     |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 4 | 0.0222<br>0.0180 | 0.0216 | 0.0215 | 0.0206 | 0.0199 | Ave        |             | 0.0206 |    |   | 7.3     |      | 20.0 |          |            |   |                |
| PCB-1242 Peak 5 | 0.0112<br>0.0095 | 0.0114 | 0.0114 | 0.0108 | 0.0106 | Ave        |             | 0.0108 |    |   | 6.7     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 1 | 0.1131<br>0.0904 | 0.1077 | 0.1062 | 0.1014 | 0.0999 | Ave        |             | 0.1031 |    |   | 7.6     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 2 | 0.1078<br>0.0873 | 0.1038 | 0.1024 | 0.0981 | 0.0965 | Ave        |             | 0.0993 |    |   | 7.2     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 3 | 0.0934<br>0.0755 | 0.0902 | 0.0890 | 0.0848 | 0.0839 | Ave        |             | 0.0861 |    |   | 7.3     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 4 | 0.0370<br>0.0309 | 0.0372 | 0.0362 | 0.0358 | 0.0348 | Ave        |             | 0.0353 |    |   | 6.6     |      | 20.0 |          |            |   |                |
| PCB-1268 Peak 5 | 0.2557<br>0.2089 | 0.2450 | 0.2450 | 0.2351 | 0.2341 | Ave        |             | 0.2373 |    |   | 6.7     |      | 20.0 |          |            |   |                |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53(mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 18:30 Calibration End Date: 09/05/2018 19:43 Calibration ID: 46831

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/10 | P2090510.D   |
| Level 2 | STD01 240-343960/11  | P2090511.D   |
| Level 3 | STD02 240-343960/12  | P2090512.D   |
| Level 4 | STD05 240-343960/13  | P2090513.D   |
| Level 5 | STD1 240-343960/14   | P2090514.D   |
| Level 6 | STD15 240-343960/15  | P2090515.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE              |          |          |           |           | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|-----------------------|----------|----------|-----------|-----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6        | LVL 2    | LVL 3    | LVL 4     | LVL 5     | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1242 Peak 1 | BNB    | Ave        | 689115<br>17042312    | 1327340  | 2841230  | 6773328   | 12538755  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 2 | BNB    | Ave        | 1376995<br>32087228   | 2662102  | 5274838  | 12064456  | 22786220  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 3 | BNB    | Ave        | 2743712<br>68543989   | 5436998  | 10605112 | 24739906  | 48322360  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 4 | BNB    | Ave        | 1118094<br>28231146   | 2229726  | 4434823  | 10265925  | 19818324  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1242 Peak 5 | BNB    | Ave        | 562667<br>14807605    | 1171323  | 2341338  | 5388672   | 10565064  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 1 | BNB    | Ave        | 5695355<br>141417251  | 11103377 | 21886103 | 50577911  | 99334905  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 2 | BNB    | Ave        | 5431721<br>136601248  | 10703093 | 21111063 | 48929698  | 95982879  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 3 | BNB    | Ave        | 4703653<br>118116149  | 9299056  | 18334940 | 42306876  | 83448116  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 4 | BNB    | Ave        | 1862911<br>48326364   | 3837640  | 7464022  | 17851272  | 34572404  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1268 Peak 5 | BNB    | Ave        | 12877579<br>326857673 | 25260920 | 50495995 | 117318350 | 232855636 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 19:58 Calibration End Date: 09/05/2018 21:11 Calibration ID: 46838

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/16 | P2090516.D   |
| Level 2 | STD01 240-343960/17  | P2090517.D   |
| Level 3 | STD02 240-343960/18  | P2090518.D   |
| Level 4 | STD05 240-343960/19  | P2090519.D   |
| Level 5 | STD1 240-343960/20   | P2090520.D   |
| Level 6 | STD15 240-343960/21  | P2090521.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R <sup>2</sup> OR COD | # | MIN R <sup>2</sup> OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|-----------------------|---|---------------------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |                       |   |                           |
| PCB-1248 Peak 1 | 0.0111<br>0.0107 | 0.0110 | 0.0106 | 0.0107 | 0.0112 | Ave        |             | 0.0109 |    |   | 2.3     |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 2 | 0.0322<br>0.0309 | 0.0319 | 0.0308 | 0.0303 | 0.0318 | Ave        |             | 0.0313 |    |   | 2.4     |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 3 | 0.0289<br>0.0296 | 0.0287 | 0.0286 | 0.0276 | 0.0295 | Ave        |             | 0.0288 |    |   | 2.5     |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 4 | 0.0208<br>0.0234 | 0.0223 | 0.0226 | 0.0227 | 0.0240 | Ave        |             | 0.0227 |    |   | 4.7     |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 5 | 0.0141<br>0.0147 | 0.0144 | 0.0143 | 0.0142 | 0.0153 | Ave        |             | 0.0145 |    |   | 3.1     |      | 20.0 |          |                       |   |                           |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.



FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 19:58 Calibration End Date: 09/05/2018 21:11 Calibration ID: 46838

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/16 | P2090516.D   |
| Level 2 | STD01 240-343960/17  | P2090517.D   |
| Level 3 | STD02 240-343960/18  | P2090518.D   |
| Level 4 | STD05 240-343960/19  | P2090519.D   |
| Level 5 | STD1 240-343960/20   | P2090520.D   |
| Level 6 | STD15 240-343960/21  | P2090521.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE            |         |         |          |          | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|---------------------|---------|---------|----------|----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6      | LVL 2   | LVL 3   | LVL 4    | LVL 5    | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1248 Peak 1 | BNB    | Ave        | 706874<br>21200150  | 1510816 | 2987195 | 7156828  | 14214184 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 2 | BNB    | Ave        | 2042783<br>61029699 | 4377361 | 8710649 | 20243717 | 40578071 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 3 | BNB    | Ave        | 1832315<br>58462504 | 3935221 | 8082625 | 18481968 | 37610943 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 4 | BNB    | Ave        | 1322527<br>46221548 | 3062354 | 6407837 | 15205364 | 30546057 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 5 | BNB    | Ave        | 894544<br>29097330  | 1980123 | 4042784 | 9499596  | 19539488 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 19:58 Calibration End Date: 09/05/2018 21:11 Calibration ID: 46839

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/16 | P2090516.D   |
| Level 2 | STD01 240-343960/17  | P2090517.D   |
| Level 3 | STD02 240-343960/18  | P2090518.D   |
| Level 4 | STD05 240-343960/19  | P2090519.D   |
| Level 5 | STD1 240-343960/20   | P2090520.D   |
| Level 6 | STD15 240-343960/21  | P2090521.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R <sup>2</sup> OR COD | # | MIN R <sup>2</sup> OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|-----------------------|---|---------------------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |                       |   |                           |
| PCB-1248 Peak 1 | 0.0158<br>0.0119 | 0.0147 | 0.0137 | 0.0129 | 0.0117 | Ave        |             | 0.0134 |    |   | 12.0    |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 2 | 0.0359<br>0.0309 | 0.0347 | 0.0334 | 0.0318 | 0.0299 | Ave        |             | 0.0328 |    |   | 7.0     |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 3 | 0.0253<br>0.0219 | 0.0252 | 0.0239 | 0.0227 | 0.0212 | Ave        |             | 0.0234 |    |   | 7.3     |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 4 | 0.0324<br>0.0283 | 0.0317 | 0.0308 | 0.0290 | 0.0274 | Ave        |             | 0.0299 |    |   | 6.6     |      | 20.0 |          |                       |   |                           |
| PCB-1248 Peak 5 | 0.0163<br>0.0142 | 0.0160 | 0.0151 | 0.0144 | 0.0138 | Ave        |             | 0.0150 |    |   | 6.7     |      | 20.0 |          |                       |   |                           |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53(mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 19:58 Calibration End Date: 09/05/2018 21:11 Calibration ID: 46839

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/16 | P2090516.D   |
| Level 2 | STD01 240-343960/17  | P2090517.D   |
| Level 3 | STD02 240-343960/18  | P2090518.D   |
| Level 4 | STD05 240-343960/19  | P2090519.D   |
| Level 5 | STD1 240-343960/20   | P2090520.D   |
| Level 6 | STD15 240-343960/21  | P2090521.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE            |         |         |          |          | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|---------------------|---------|---------|----------|----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6      | LVL 2   | LVL 3   | LVL 4    | LVL 5    | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1248 Peak 1 | BNB    | Ave        | 772480<br>17828645  | 1544657 | 2921930 | 6558910  | 12271846 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 2 | BNB    | Ave        | 1756660<br>46488087 | 3643118 | 7147205 | 16121410 | 31503047 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 3 | BNB    | Ave        | 1238732<br>32998079 | 2641768 | 5110594 | 11511535 | 22321373 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 4 | BNB    | Ave        | 1584028<br>42593645 | 3327499 | 6578035 | 14704731 | 28852994 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1248 Peak 5 | BNB    | Ave        | 798180<br>21393247  | 1676965 | 3217865 | 7316694  | 14509999 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 21:26 Calibration End Date: 09/05/2018 22:39 Calibration ID: 46846

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/22 | P2090522.D   |
| Level 2 | STD01 240-343960/23  | P2090523.D   |
| Level 3 | STD02 240-343960/24  | P2090524.D   |
| Level 4 | STD05 240-343960/25  | P2090525.D   |
| Level 5 | STD1 240-343960/26   | P2090526.D   |
| Level 6 | STD15 240-343960/27  | P2090527.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R <sup>2</sup> OR COD | # | MIN R <sup>2</sup> OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|-----------------------|---|---------------------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |                       |   |                           |
| PCB-1221 Peak 1 | 0.0093<br>0.0075 | 0.0092 | 0.0085 | 0.0081 | 0.0081 | Ave        |             | 0.0085 |    |   | 8.1     |      | 20.0 |          |                       |   |                           |
| PCB-1221 Peak 2 | 0.0049<br>0.0045 | 0.0050 | 0.0050 | 0.0049 | 0.0049 | Ave        |             | 0.0049 |    |   | 4.1     |      | 20.0 |          |                       |   |                           |
| PCB-1221 Peak 3 | 0.0222<br>0.0185 | 0.0220 | 0.0217 | 0.0205 | 0.0200 | Ave        |             | 0.0208 |    |   | 6.9     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 1 | 0.0240<br>0.0215 | 0.0238 | 0.0232 | 0.0228 | 0.0227 | Ave        |             | 0.0230 |    |   | 4.0     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 2 | 0.0490<br>0.0459 | 0.0477 | 0.0463 | 0.0476 | 0.0486 | Ave        |             | 0.0475 |    |   | 2.6     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 3 | 0.0356<br>0.0356 | 0.0356 | 0.0353 | 0.0369 | 0.0375 | Ave        |             | 0.0361 |    |   | 2.5     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 4 | 0.0317<br>0.0307 | 0.0337 | 0.0331 | 0.0324 | 0.0324 | Ave        |             | 0.0324 |    |   | 3.2     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 5 | 0.0478<br>0.0470 | 0.0480 | 0.0492 | 0.0492 | 0.0495 | Ave        |             | 0.0485 |    |   | 2.1     |      | 20.0 |          |                       |   |                           |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 21:26 Calibration End Date: 09/05/2018 22:39 Calibration ID: 46846

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/22 | P2090522.D   |
| Level 2 | STD01 240-343960/23  | P2090523.D   |
| Level 3 | STD02 240-343960/24  | P2090524.D   |
| Level 4 | STD05 240-343960/25  | P2090525.D   |
| Level 5 | STD1 240-343960/26   | P2090526.D   |
| Level 6 | STD15 240-343960/27  | P2090527.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE             |         |          |          |          | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|----------------------|---------|----------|----------|----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6       | LVL 2   | LVL 3    | LVL 4    | LVL 5    | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1221 Peak 1 | BNB    | Ave        | 646054<br>16596251   | 1255071 | 2349512  | 5643369  | 11325683 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1221 Peak 2 | BNB    | Ave        | 344272<br>9822870    | 676093  | 1393569  | 3433232  | 6786030  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1221 Peak 3 | BNB    | Ave        | 1546515<br>40676670  | 2995051 | 6024899  | 14275272 | 27952175 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 1 | BNB    | Ave        | 1671822<br>47187529  | 3240096 | 6446756  | 15865958 | 31723662 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 2 | BNB    | Ave        | 3406727<br>100818948 | 6500878 | 12884216 | 33116238 | 67890010 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 3 | BNB    | Ave        | 2480342<br>78201890  | 4851670 | 9814861  | 25683330 | 52456713 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 4 | BNB    | Ave        | 2209053<br>67601804  | 4595417 | 9208206  | 22541339 | 45341029 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 5 | BNB    | Ave        | 3327645<br>103449119 | 6533314 | 13670878 | 34254649 | 69229118 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 21:26 Calibration End Date: 09/05/2018 22:39 Calibration ID: 46847

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/22 | P2090522.D   |
| Level 2 | STD01 240-343960/23  | P2090523.D   |
| Level 3 | STD02 240-343960/24  | P2090524.D   |
| Level 4 | STD05 240-343960/25  | P2090525.D   |
| Level 5 | STD1 240-343960/26   | P2090526.D   |
| Level 6 | STD15 240-343960/27  | P2090527.D   |

| ANALYTE         | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R <sup>2</sup> OR COD | # | MIN R <sup>2</sup> OR COD |
|-----------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|-----------------------|---|---------------------------|
|                 | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |                       |   |                           |
| PCB-1221 Peak 1 | 0.0164<br>0.0083 | 0.0136 | 0.0119 | 0.0094 | 0.0090 | Lin1       | 0.0005      | 0.0083 |    |   |         |      |      | 0.9960   |                       |   | 0.9900                    |
| PCB-1221 Peak 2 | 0.0067<br>0.0052 | 0.0066 | 0.0070 | 0.0060 | 0.0056 | Ave        |             | 0.0062 |    |   | 11.5    |      | 20.0 |          |                       |   |                           |
| PCB-1221 Peak 3 | 0.0256<br>0.0191 | 0.0244 | 0.0243 | 0.0221 | 0.0204 | Ave        |             | 0.0227 |    |   | 11.2    |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 1 | 0.0309<br>0.0233 | 0.0294 | 0.0283 | 0.0265 | 0.0251 | Ave        |             | 0.0272 |    |   | 10.3    |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 2 | 0.0421<br>0.0377 | 0.0411 | 0.0460 | 0.0422 | 0.0405 | Ave        |             | 0.0416 |    |   | 6.5     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 3 | 0.0329<br>0.0287 | 0.0334 | 0.0324 | 0.0319 | 0.0307 | Ave        |             | 0.0317 |    |   | 5.5     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 4 | 0.0366<br>0.0307 | 0.0353 | 0.0348 | 0.0336 | 0.0326 | Ave        |             | 0.0339 |    |   | 6.2     |      | 20.0 |          |                       |   |                           |
| PCB-1254 Peak 5 | 0.0431<br>0.0356 | 0.0425 | 0.0411 | 0.0392 | 0.0382 | Ave        |             | 0.0399 |    |   | 7.1     |      | 20.0 |          |                       |   |                           |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 21:26 Calibration End Date: 09/05/2018 22:39 Calibration ID: 46847

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/22 | P2090522.D   |
| Level 2 | STD01 240-343960/23  | P2090523.D   |
| Level 3 | STD02 240-343960/24  | P2090524.D   |
| Level 4 | STD05 240-343960/25  | P2090525.D   |
| Level 5 | STD1 240-343960/26   | P2090526.D   |
| Level 6 | STD15 240-343960/27  | P2090527.D   |

| ANALYTE         | IS REF | CURVE TYPE | RESPONSE            |         |         |          |          | CONCENTRATION (NG/UL) |       |       |       |       |
|-----------------|--------|------------|---------------------|---------|---------|----------|----------|-----------------------|-------|-------|-------|-------|
|                 |        |            | LVL 1<br>LVL 6      | LVL 2   | LVL 3   | LVL 4    | LVL 5    | LVL 1<br>LVL 6        | LVL 2 | LVL 3 | LVL 4 | LVL 5 |
| PCB-1221 Peak 1 | BNB    | Lin1       | 867409<br>13764313  | 1417353 | 2489148 | 4931518  | 9701642  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1221 Peak 2 | BNB    | Ave        | 355656<br>8665539   | 687574  | 1462484 | 3139842  | 5963156  | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1221 Peak 3 | BNB    | Ave        | 1349553<br>31768030 | 2550994 | 5075981 | 11610442 | 21923864 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 1 | BNB    | Ave        | 1630712<br>38836929 | 3070222 | 5911878 | 13921810 | 26881713 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 2 | BNB    | Ave        | 2221420<br>62751254 | 4287613 | 9613685 | 22190316 | 43404463 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 3 | BNB    | Ave        | 1738985<br>47761977 | 3486488 | 6765148 | 16757356 | 32873645 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 4 | BNB    | Ave        | 1930907<br>51028568 | 3688388 | 7271078 | 17659196 | 34910030 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |
| PCB-1254 Peak 5 | BNB    | Ave        | 2274609<br>59343999 | 4433768 | 8582966 | 20623493 | 40920785 | 0.0500<br>1.50        | 0.100 | 0.200 | 0.500 | 1.00  |

Curve Type Legend:

|                           |
|---------------------------|
| Ave = Average ISTD        |
| Lin1 = Linear 1/conc ISTD |

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 22:54 Calibration End Date: 09/06/2018 00:07 Calibration ID: 46854

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/28 | P2090528.D   |
| Level 2 | STD01 240-343960/29  | P2090529.D   |
| Level 3 | STD02 240-343960/30  | P2090530.D   |
| Level 4 | STD05 240-343960/31  | P2090531.D   |
| Level 5 | STD1 240-343960/32   | P2090532.D   |
| Level 6 | STD15 240-343960/33  | P2090533.D   |

| ANALYTE                | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R^2 OR COD | # | MIN R^2 OR COD |
|------------------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|------------|---|----------------|
|                        | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |            |   |                |
| PCB-1016 Peak 1        | 0.0159<br>0.0132 | 0.0147 | 0.0140 | 0.0137 | 0.0132 | Ave        |             | 0.0141 |    |   | 7.5     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 2        | 0.0280<br>0.0245 | 0.0269 | 0.0281 | 0.0260 | 0.0250 | Ave        |             | 0.0264 |    |   | 5.8     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 3        | 0.0624<br>0.0605 | 0.0602 | 0.0601 | 0.0609 | 0.0606 | Ave        |             | 0.0608 |    |   | 1.4     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 4        | 0.0256<br>0.0247 | 0.0248 | 0.0252 | 0.0251 | 0.0248 | Ave        |             | 0.0250 |    |   | 1.4     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 5        | 0.0250<br>0.0238 | 0.0253 | 0.0246 | 0.0246 | 0.0241 | Ave        |             | 0.0246 |    |   | 2.2     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 1        | 0.0333<br>0.0308 | 0.0328 | 0.0314 | 0.0316 | 0.0310 | Ave        |             | 0.0318 |    |   | 3.2     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 2        | 0.0587<br>0.0531 | 0.0555 | 0.0544 | 0.0538 | 0.0535 | Ave        |             | 0.0548 |    |   | 3.8     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 3        | 0.0608<br>0.0593 | 0.0603 | 0.0596 | 0.0593 | 0.0597 | Ave        |             | 0.0598 |    |   | 1.0     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 4        | 0.0905<br>0.0932 | 0.0906 | 0.0901 | 0.0919 | 0.0933 | Ave        |             | 0.0916 |    |   | 1.6     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 5        | 0.0426<br>0.0422 | 0.0418 | 0.0411 | 0.0422 | 0.0424 | Ave        |             | 0.0421 |    |   | 1.3     |      | 20.0 |          |            |   |                |
| Tetrachloro-m-xylene   | 0.9387<br>0.8498 | 0.8866 | 0.8646 | 0.8814 | 0.8912 | Ave        |             | 0.8854 |    |   | 3.4     |      | 20.0 |          |            |   |                |
| DCB Decachlorobiphenyl | 0.9073<br>0.7432 | 0.8658 | 0.8274 | 0.8096 | 0.7986 | Ave        |             | 0.8253 |    |   | 6.9     |      | 20.0 |          |            |   |                |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.



FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 22:54 Calibration End Date: 09/06/2018 00:07 Calibration ID: 46854

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/28 | P2090528.D   |
| Level 2 | STD01 240-343960/29  | P2090529.D   |
| Level 3 | STD02 240-343960/30  | P2090530.D   |
| Level 4 | STD05 240-343960/31  | P2090531.D   |
| Level 5 | STD1 240-343960/32   | P2090532.D   |
| Level 6 | STD15 240-343960/33  | P2090533.D   |

| ANALYTE                | IS REF | CURVE TYPE | RESPONSE             |          |          |          |           | CONCENTRATION (NG/UL) |         |        |        |        |
|------------------------|--------|------------|----------------------|----------|----------|----------|-----------|-----------------------|---------|--------|--------|--------|
|                        |        |            | LVL 1<br>LVL 6       | LVL 2    | LVL 3    | LVL 4    | LVL 5     | LVL 1<br>LVL 6        | LVL 2   | LVL 3  | LVL 4  | LVL 5  |
| PCB-1016 Peak 1        | BNB    | Ave        | 1070205<br>28147342  | 2005871  | 3940300  | 9491729  | 18424688  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 2        | BNB    | Ave        | 1880633<br>52220419  | 3674308  | 7933162  | 17997955 | 34943608  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 3        | BNB    | Ave        | 4188447<br>129063548 | 8207562  | 16937572 | 42123199 | 84611311  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 4        | BNB    | Ave        | 1721360<br>52687093  | 3385263  | 7094016  | 17387591 | 34617403  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 5        | BNB    | Ave        | 1677224<br>50821900  | 3443973  | 6933573  | 17027236 | 33615332  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 1        | BNB    | Ave        | 2237531<br>65800084  | 4473562  | 8862181  | 21853750 | 43289005  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 2        | BNB    | Ave        | 3942011<br>113190471 | 7571203  | 15331901 | 37219107 | 74632309  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 3        | BNB    | Ave        | 4082185<br>126415071 | 8225986  | 16793999 | 41034808 | 83390200  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 4        | BNB    | Ave        | 6073161<br>198778523 | 12356645 | 25403344 | 63572072 | 130299347 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 5        | BNB    | Ave        | 2862449<br>89972695  | 5705482  | 11586238 | 29185280 | 59211421  | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| Tetrachloro-m-xylene   | BNB    | Ave        | 3151127<br>120860497 | 6045104  | 12191518 | 30479123 | 62196517  | 0.00250<br>0.100      | 0.00500 | 0.0100 | 0.0250 | 0.0500 |
| DCB Decachlorobiphenyl | BNB    | Ave        | 3045816<br>105702634 | 5902830  | 11667234 | 27994488 | 55733894  | 0.00250<br>0.100      | 0.00500 | 0.0100 | 0.0250 | 0.0500 |

Curve Type Legend:

Ave = Average ISTD

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 22:54 Calibration End Date: 09/06/2018 00:07 Calibration ID: 46855

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/28 | P2090528.D   |
| Level 2 | STD01 240-343960/29  | P2090529.D   |
| Level 3 | STD02 240-343960/30  | P2090530.D   |
| Level 4 | STD05 240-343960/31  | P2090531.D   |
| Level 5 | STD1 240-343960/32   | P2090532.D   |
| Level 6 | STD15 240-343960/33  | P2090533.D   |

| ANALYTE                | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R^2 OR COD | # | MIN R^2 OR COD |
|------------------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|------------|---|----------------|
|                        | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |            |   |                |
| PCB-1016 Peak 1        | 0.0160<br>0.0140 | 0.0156 | 0.0167 | 0.0151 | 0.0138 | Ave        |             | 0.0152 |    |   | 7.6     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 2        | 0.0336<br>0.0270 | 0.0321 | 0.0309 | 0.0296 | 0.0271 | Ave        |             | 0.0301 |    |   | 8.9     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 3        | 0.0689<br>0.0593 | 0.0660 | 0.0644 | 0.0624 | 0.0588 | Ave        |             | 0.0633 |    |   | 6.2     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 4        | 0.0254<br>0.0242 | 0.0267 | 0.0269 | 0.0255 | 0.0239 | Ave        |             | 0.0254 |    |   | 4.9     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 5        | 0.0144<br>0.0130 | 0.0147 | 0.0142 | 0.0136 | 0.0129 | Ave        |             | 0.0138 |    |   | 5.3     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 1        | 0.0352<br>0.0308 | 0.0340 | 0.0328 | 0.0320 | 0.0304 | Ave        |             | 0.0325 |    |   | 5.7     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 2        | 0.0402<br>0.0345 | 0.0386 | 0.0371 | 0.0361 | 0.0344 | Ave        |             | 0.0368 |    |   | 6.2     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 3        | 0.0351<br>0.0302 | 0.0340 | 0.0329 | 0.0320 | 0.0302 | Ave        |             | 0.0324 |    |   | 6.2     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 4        | 0.0776<br>0.0715 | 0.0773 | 0.0756 | 0.0742 | 0.0712 | Ave        |             | 0.0746 |    |   | 3.7     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 5        | 0.0530<br>0.0494 | 0.0534 | 0.0522 | 0.0513 | 0.0493 | Ave        |             | 0.0514 |    |   | 3.5     |      | 20.0 |          |            |   |                |
| Tetrachloro-m-xylene   | 1.0034<br>0.8633 | 0.9790 | 0.9602 | 0.9433 | 0.8991 | Ave        |             | 0.9414 |    |   | 5.5     |      | 20.0 |          |            |   |                |
| DCB Decachlorobiphenyl | 0.7388<br>0.5754 | 0.7059 | 0.6828 | 0.6472 | 0.6160 | Ave        |             | 0.6610 |    |   | 9.1     |      | 20.0 |          |            |   |                |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
RESPONSE AND CONCENTRATION

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-2 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 22:54 Calibration End Date: 09/06/2018 00:07 Calibration ID: 46855

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/28 | P2090528.D   |
| Level 2 | STD01 240-343960/29  | P2090529.D   |
| Level 3 | STD02 240-343960/30  | P2090530.D   |
| Level 4 | STD05 240-343960/31  | P2090531.D   |
| Level 5 | STD1 240-343960/32   | P2090532.D   |
| Level 6 | STD15 240-343960/33  | P2090533.D   |

| ANALYTE                | IS REF | CURVE TYPE | RESPONSE             |         |          |          |          | CONCENTRATION (NG/UL) |         |        |        |        |
|------------------------|--------|------------|----------------------|---------|----------|----------|----------|-----------------------|---------|--------|--------|--------|
|                        |        |            | LVL 1<br>LVL 6       | LVL 2   | LVL 3    | LVL 4    | LVL 5    | LVL 1<br>LVL 6        | LVL 2   | LVL 3  | LVL 4  | LVL 5  |
| PCB-1016 Peak 1        | BNB    | Ave        | 821891<br>21498418   | 1603515 | 3477558  | 7725475  | 14303076 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 2        | BNB    | Ave        | 1725442<br>41445807  | 3299151 | 6424122  | 15121208 | 28169391 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 3        | BNB    | Ave        | 3534352<br>91220698  | 6770944 | 13413748 | 31854979 | 61049827 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 4        | BNB    | Ave        | 1305696<br>37160712  | 2743566 | 5597133  | 13004188 | 24778804 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1016 Peak 5        | BNB    | Ave        | 739868<br>19975503   | 1505563 | 2955132  | 6957335  | 13419204 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 1        | BNB    | Ave        | 1808299<br>47334758  | 3488505 | 6819748  | 16347096 | 31564422 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 2        | BNB    | Ave        | 2064583<br>53030843  | 3959223 | 7727306  | 18409167 | 35740831 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 3        | BNB    | Ave        | 1800715<br>46447486  | 3495135 | 6849829  | 16329821 | 31343810 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 4        | BNB    | Ave        | 3981169<br>109907887 | 7939480 | 15739723 | 37863019 | 73834136 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| PCB-1260 Peak 5        | BNB    | Ave        | 2720418<br>75963078  | 5484714 | 10867682 | 26185129 | 51124243 | 0.0500<br>1.50        | 0.100   | 0.200  | 0.500  | 1.00   |
| Tetrachloro-m-xylene   | BNB    | Ave        | 2574322<br>88463264  | 5025044 | 9993257  | 24082589 | 46647569 | 0.00250<br>0.100      | 0.00500 | 0.0100 | 0.0250 | 0.0500 |
| DCB Decachlorobiphenyl | BNB    | Ave        | 1895447<br>58959751  | 3623091 | 7106397  | 16522126 | 31956636 | 0.00250<br>0.100      | 0.00500 | 0.0100 | 0.0250 | 0.0500 |

Curve Type Legend:

Ave = Average ISTD

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/34 Calibration Date: 09/06/2018 00:22  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090534.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1221 Peak 1 | Ave        | 0.0085  | 0.0093 |         | 0.548       | 0.500        | 9.6  | 20.0   |
| PCB-1221 Peak 2 | Ave        | 0.0049  | 0.0056 |         | 0.574       | 0.500        | 14.8 | 20.0   |
| PCB-1221 Peak 3 | Ave        | 0.0208  | 0.0230 |         | 0.551       | 0.500        | 10.2 | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/34 Calibration Date: 09/06/2018 00:22  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090534.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1221 Peak 1 | 1.98 | 1.97      | 2.00 |
| PCB-1221 Peak 2 | 2.12 | 2.10      | 2.14 |
| PCB-1221 Peak 3 | 2.16 | 2.14      | 2.18 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/34 Calibration Date: 09/06/2018 00:22  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090534.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D  | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-----|--------|
| PCB-1221 Peak 1 | Lin1       |         | 0.0097 |         | 0.523       | 0.500        | 4.6 | 20.0   |
| PCB-1221 Peak 2 | Ave        | 0.0062  | 0.0065 |         | 0.529       | 0.500        | 5.8 | 20.0   |
| PCB-1221 Peak 3 | Ave        | 0.0227  | 0.0245 |         | 0.541       | 0.500        | 8.3 | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/34 Calibration Date: 09/06/2018 00:22  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090534.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1221 Peak 1 | 2.48 | 2.46      | 2.50 |
| PCB-1221 Peak 2 | 2.62 | 2.60      | 2.64 |
| PCB-1221 Peak 3 | 2.68 | 2.66      | 2.70 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/35 Calibration Date: 09/06/2018 00:36  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090535.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D    | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-------|--------|
| PCB-1232 Peak 1 | Ave        | 0.0173  | 0.0147 |         | 0.427       | 0.500        | -14.7 | 20.0   |
| PCB-1232 Peak 2 | Ave        | 0.0123  | 0.0115 |         | 0.469       | 0.500        | -6.1  | 20.0   |
| PCB-1232 Peak 3 | Ave        | 0.0277  | 0.0272 |         | 0.490       | 0.500        | -2.0  | 20.0   |
| PCB-1232 Peak 4 | Ave        | 0.0114  | 0.0122 |         | 0.538       | 0.500        | 7.6   | 20.0   |
| PCB-1232 Peak 5 | Ave        | 0.0038  | 0.0041 |         | 0.541       | 0.500        | 8.2   | 20.0   |



FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/35 Calibration Date: 09/06/2018 00:36  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090535.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1232 Peak 1 | 2.16 | 2.14      | 2.17 |
| PCB-1232 Peak 2 | 2.49 | 2.47      | 2.51 |
| PCB-1232 Peak 3 | 2.92 | 2.91      | 2.94 |
| PCB-1232 Peak 4 | 3.05 | 3.03      | 3.07 |
| PCB-1232 Peak 5 | 3.28 | 3.27      | 3.31 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/35 Calibration Date: 09/06/2018 00:36  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090535.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D    | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-------|--------|
| PCB-1232 Peak 1 | Ave        | 0.0187  | 0.0159 |         | 0.424       | 0.500        | -15.1 | 20.0   |
| PCB-1232 Peak 2 | Ave        | 0.0152  | 0.0158 |         | 0.519       | 0.500        | 3.8   | 20.0   |
| PCB-1232 Peak 3 | Ave        | 0.0289  | 0.0267 |         | 0.461       | 0.500        | -7.7  | 20.0   |
| PCB-1232 Peak 4 | Ave        | 0.0117  | 0.0111 |         | 0.474       | 0.500        | -5.2  | 20.0   |
| PCB-1232 Peak 5 | Ave        | 0.0054  | 0.0052 |         | 0.473       | 0.500        | -5.3  | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/35 Calibration Date: 09/06/2018 00:36  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090535.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1232 Peak 1 | 2.68 | 2.66      | 2.70 |
| PCB-1232 Peak 2 | 3.08 | 3.07      | 3.10 |
| PCB-1232 Peak 3 | 3.53 | 3.51      | 3.55 |
| PCB-1232 Peak 4 | 3.66 | 3.64      | 3.68 |
| PCB-1232 Peak 5 | 3.90 | 3.88      | 3.92 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/36 Calibration Date: 09/06/2018 00:51  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090536.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1242 Peak 1 | Ave        | 0.0117  | 0.0109 |         | 0.466       | 0.500        | -6.7 | 20.0   |
| PCB-1242 Peak 2 | Ave        | 0.0213  | 0.0203 |         | 0.475       | 0.500        | -4.9 | 20.0   |
| PCB-1242 Peak 3 | Ave        | 0.0493  | 0.0481 |         | 0.487       | 0.500        | -2.5 | 20.0   |
| PCB-1242 Peak 4 | Ave        | 0.0203  | 0.0211 |         | 0.518       | 0.500        | 3.7  | 20.0   |
| PCB-1242 Peak 5 | Ave        | 0.0078  | 0.0084 |         | 0.535       | 0.500        | 6.9  | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/36 Calibration Date: 09/06/2018 00:51  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090536.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1242 Peak 1 | 2.16 | 2.14      | 2.18 |
| PCB-1242 Peak 2 | 2.49 | 2.47      | 2.51 |
| PCB-1242 Peak 3 | 2.92 | 2.91      | 2.95 |
| PCB-1242 Peak 4 | 3.05 | 3.03      | 3.07 |
| PCB-1242 Peak 5 | 3.29 | 3.27      | 3.31 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/36 Calibration Date: 09/06/2018 00:51  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090536.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1242 Peak 1 | Ave        | 0.0129  | 0.0120 |         | 0.464       | 0.500        | -7.3 | 20.0   |
| PCB-1242 Peak 2 | Ave        | 0.0244  | 0.0248 |         | 0.508       | 0.500        | 1.5  | 20.0   |
| PCB-1242 Peak 3 | Ave        | 0.0501  | 0.0475 |         | 0.473       | 0.500        | -5.3 | 20.0   |
| PCB-1242 Peak 4 | Ave        | 0.0206  | 0.0191 |         | 0.463       | 0.500        | -7.4 | 20.0   |
| PCB-1242 Peak 5 | Ave        | 0.0108  | 0.0105 |         | 0.488       | 0.500        | -2.5 | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/36 Calibration Date: 09/06/2018 00:51  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090536.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1242 Peak 1 | 2.68 | 2.66      | 2.70 |
| PCB-1242 Peak 2 | 3.09 | 3.07      | 3.10 |
| PCB-1242 Peak 3 | 3.53 | 3.51      | 3.55 |
| PCB-1242 Peak 4 | 3.66 | 3.64      | 3.68 |
| PCB-1242 Peak 5 | 3.90 | 3.88      | 3.92 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/37 Calibration Date: 09/06/2018 01:05  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 19:58  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 21:11  
 Lab File ID: P2090537.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D    | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-------|--------|
| PCB-1248 Peak 1 | Ave        | 0.0109  | 0.0120 |         | 0.553       | 0.500        | 10.5  | 20.0   |
| PCB-1248 Peak 2 | Ave        | 0.0313  | 0.0367 |         | 0.586       | 0.500        | 17.2  | 20.0   |
| PCB-1248 Peak 3 | Ave        | 0.0288  | 0.0331 |         | 0.574       | 0.500        | 14.7  | 20.0   |
| PCB-1248 Peak 4 | Ave        | 0.0227  | 0.0277 |         | 0.611       | 0.500        | 22.3* | 20.0   |
| PCB-1248 Peak 5 | Ave        | 0.0145  | 0.0158 |         | 0.543       | 0.500        | 8.5   | 20.0   |

Average %D < 20% ✓



FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/37 Calibration Date: 09/06/2018 01:05  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 19:58  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 21:11  
 Lab File ID: P2090537.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1248 Peak 1 | 2.49 | 2.47      | 2.51 |
| PCB-1248 Peak 2 | 3.44 | 3.42      | 3.46 |
| PCB-1248 Peak 3 | 3.84 | 3.83      | 3.86 |
| PCB-1248 Peak 4 | 4.05 | 4.03      | 4.07 |
| PCB-1248 Peak 5 | 4.42 | 4.40      | 4.44 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/37 Calibration Date: 09/06/2018 01:05  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 19:58  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 21:11  
 Lab File ID: P2090537.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D    | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-------|--------|
| PCB-1248 Peak 1 | Ave        | 0.0134  | 0.0126 |         | 0.469       | 0.500        | -6.2  | 20.0   |
| PCB-1248 Peak 2 | Ave        | 0.0328  | 0.0411 |         | 0.627       | 0.500        | 25.4* | 20.0   |
| PCB-1248 Peak 3 | Ave        | 0.0234  | 0.0267 |         | 0.570       | 0.500        | 14.1  | 20.0   |
| PCB-1248 Peak 4 | Ave        | 0.0299  | 0.0372 |         | 0.621       | 0.500        | 24.3* | 20.0   |
| PCB-1248 Peak 5 | Ave        | 0.0150  | 0.0164 |         | 0.549       | 0.500        | 9.8   | 20.0   |

Average %D < 20% ↓

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/37 Calibration Date: 09/06/2018 01:05  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 19:58  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 21:11  
 Lab File ID: P2090537.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1248 Peak 1 | 3.08 | 3.07      | 3.10 |
| PCB-1248 Peak 2 | 3.53 | 3.51      | 3.55 |
| PCB-1248 Peak 3 | 4.11 | 4.10      | 4.14 |
| PCB-1248 Peak 4 | 4.53 | 4.51      | 4.55 |
| PCB-1248 Peak 5 | 5.17 | 5.15      | 5.19 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/38 Calibration Date: 09/06/2018 01:20  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090538.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D     | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|--------|--------|
| PCB-1254 Peak 1 | Ave        | 0.0230  | 0.0168 |         | 0.366       | 0.500        | -26.8* | 20.0   |
| PCB-1254 Peak 2 | Ave        | 0.0475  | 0.0470 |         | 0.494       | 0.500        | -1.2   | 20.0   |
| PCB-1254 Peak 3 | Ave        | 0.0361  | 0.0354 |         | 0.490       | 0.500        | -2.1   | 20.0   |
| PCB-1254 Peak 4 | Ave        | 0.0324  | 0.0338 |         | 0.521       | 0.500        | 4.3    | 20.0   |
| PCB-1254 Peak 5 | Ave        | 0.0485  | 0.0524 |         | 0.540       | 0.500        | 8.0    | 20.0   |

Average %D < 20% ✓

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/38 Calibration Date: 09/06/2018 01:20  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090538.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1254 Peak 1 | 3.80 | 3.78      | 3.82 |
| PCB-1254 Peak 2 | 4.42 | 4.40      | 4.44 |
| PCB-1254 Peak 3 | 4.70 | 4.68      | 4.72 |
| PCB-1254 Peak 4 | 4.88 | 4.87      | 4.90 |
| PCB-1254 Peak 5 | 5.15 | 5.13      | 5.17 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/38 Calibration Date: 09/06/2018 01:20  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090538.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1254 Peak 1 | Ave        | 0.0272  | 0.0262 |         | 0.480       | 0.500        | -4.0 | 20.0   |
| PCB-1254 Peak 2 | Ave        | 0.0416  | 0.0414 |         | 0.498       | 0.500        | -0.4 | 20.0   |
| PCB-1254 Peak 3 | Ave        | 0.0317  | 0.0321 |         | 0.507       | 0.500        | 1.4  | 20.0   |
| PCB-1254 Peak 4 | Ave        | 0.0339  | 0.0348 |         | 0.513       | 0.500        | 2.6  | 20.0   |
| PCB-1254 Peak 5 | Ave        | 0.0399  | 0.0423 |         | 0.530       | 0.500        | 5.9  | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/38 Calibration Date: 09/06/2018 01:20  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2090538.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1254 Peak 1 | 4.52 | 4.50      | 4.54 |
| PCB-1254 Peak 2 | 5.17 | 5.15      | 5.19 |
| PCB-1254 Peak 3 | 5.38 | 5.36      | 5.40 |
| PCB-1254 Peak 4 | 5.69 | 5.67      | 5.71 |
| PCB-1254 Peak 5 | 5.86 | 5.84      | 5.88 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/39 Calibration Date: 09/06/2018 01:34  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2090539.D Conc. Units: ng/uL

| ANALYTE                | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|------------------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1016 Peak 1        | Ave        | 0.0141  | 0.0150 |         | 0.530       | 0.500        | 5.9  | 20.0   |
| PCB-1016 Peak 2        | Ave        | 0.0264  | 0.0269 |         | 0.508       | 0.500        | 1.7  | 20.0   |
| PCB-1016 Peak 3        | Ave        | 0.0608  | 0.0614 |         | 0.505       | 0.500        | 1.1  | 20.0   |
| PCB-1016 Peak 4        | Ave        | 0.0250  | 0.0262 |         | 0.523       | 0.500        | 4.7  | 20.0   |
| PCB-1016 Peak 5        | Ave        | 0.0246  | 0.0255 |         | 0.520       | 0.500        | 4.0  | 20.0   |
| PCB-1260 Peak 1        | Ave        | 0.0318  | 0.0356 |         | 0.559       | 0.500        | 11.8 | 20.0   |
| PCB-1260 Peak 2        | Ave        | 0.0548  | 0.0597 |         | 0.544       | 0.500        | 8.9  | 20.0   |
| PCB-1260 Peak 3        | Ave        | 0.0598  | 0.0643 |         | 0.537       | 0.500        | 7.4  | 20.0   |
| PCB-1260 Peak 4        | Ave        | 0.0916  | 0.1022 |         | 0.558       | 0.500        | 11.5 | 20.0   |
| PCB-1260 Peak 5        | Ave        | 0.0421  | 0.0471 |         | 0.560       | 0.500        | 11.9 | 20.0   |
| Tetrachloro-m-xylene   | Ave        | 0.8854  | 0.9590 |         | 0.0271      | 0.0250       | 8.3  | 20.0   |
| DCB Decachlorobiphenyl | Ave        | 0.8253  | 0.8694 |         | 0.0263      | 0.0250       | 5.3  | 20.0   |



FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/39 Calibration Date: 09/06/2018 01:34  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2090539.D

| Analyte                | RT   | RT WINDOW |      |
|------------------------|------|-----------|------|
|                        |      | FROM      | TO   |
| PCB-1016 Peak 1        | 2.16 | 2.14      | 2.17 |
| PCB-1016 Peak 2        | 2.49 | 2.47      | 2.51 |
| PCB-1016 Peak 3        | 2.93 | 2.91      | 2.94 |
| PCB-1016 Peak 4        | 3.05 | 3.03      | 3.07 |
| PCB-1016 Peak 5        | 3.44 | 3.42      | 3.46 |
| PCB-1260 Peak 1        | 4.61 | 4.59      | 4.63 |
| PCB-1260 Peak 2        | 4.88 | 4.87      | 4.90 |
| PCB-1260 Peak 3        | 5.15 | 5.13      | 5.17 |
| PCB-1260 Peak 4        | 5.77 | 5.75      | 5.78 |
| PCB-1260 Peak 5        | 6.01 | 5.99      | 6.03 |
| Tetrachloro-m-xylene   | 1.82 | 1.80      | 1.84 |
| DCB Decachlorobiphenyl | 6.94 | 6.92      | 6.95 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/39 Calibration Date: 09/06/2018 01:34  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2090539.D Conc. Units: ng/uL

| ANALYTE                | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|------------------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1016 Peak 1        | Ave        | 0.0152  | 0.0170 |         | 0.559       | 0.500        | 11.7 | 20.0   |
| PCB-1016 Peak 2        | Ave        | 0.0301  | 0.0281 |         | 0.467       | 0.500        | -6.6 | 20.0   |
| PCB-1016 Peak 3        | Ave        | 0.0633  | 0.0634 |         | 0.501       | 0.500        | 0.1  | 20.0   |
| PCB-1016 Peak 4        | Ave        | 0.0254  | 0.0270 |         | 0.531       | 0.500        | 6.2  | 20.0   |
| PCB-1016 Peak 5        | Ave        | 0.0138  | 0.0141 |         | 0.510       | 0.500        | 2.0  | 20.0   |
| PCB-1260 Peak 1        | Ave        | 0.0325  | 0.0324 |         | 0.498       | 0.500        | -0.5 | 20.0   |
| PCB-1260 Peak 2        | Ave        | 0.0368  | 0.0394 |         | 0.535       | 0.500        | 7.1  | 20.0   |
| PCB-1260 Peak 3        | Ave        | 0.0324  | 0.0346 |         | 0.533       | 0.500        | 6.6  | 20.0   |
| PCB-1260 Peak 4        | Ave        | 0.0746  | 0.0804 |         | 0.539       | 0.500        | 7.8  | 20.0   |
| PCB-1260 Peak 5        | Ave        | 0.0514  | 0.0537 |         | 0.522       | 0.500        | 4.5  | 20.0   |
| Tetrachloro-m-xylene   | Ave        | 0.9414  | 1.036  |         | 0.0275      | 0.0250       | 10.1 | 20.0   |
| DCB Decachlorobiphenyl | Ave        | 0.6610  | 0.7011 |         | 0.0265      | 0.0250       | 6.1  | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/39 Calibration Date: 09/06/2018 01:34  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2090539.D

| Analyte                | RT   | RT WINDOW |      |
|------------------------|------|-----------|------|
|                        |      | FROM      | TO   |
| PCB-1016 Peak 1        | 2.68 | 2.66      | 2.70 |
| PCB-1016 Peak 2        | 3.09 | 3.07      | 3.10 |
| PCB-1016 Peak 3        | 3.53 | 3.51      | 3.55 |
| PCB-1016 Peak 4        | 3.66 | 3.64      | 3.68 |
| PCB-1016 Peak 5        | 3.90 | 3.88      | 3.92 |
| PCB-1260 Peak 1        | 5.35 | 5.33      | 5.37 |
| PCB-1260 Peak 2        | 5.55 | 5.53      | 5.56 |
| PCB-1260 Peak 3        | 5.94 | 5.92      | 5.96 |
| PCB-1260 Peak 4        | 6.41 | 6.39      | 6.43 |
| PCB-1260 Peak 5        | 6.71 | 6.69      | 6.73 |
| Tetrachloro-m-xylene   | 2.19 | 2.17      | 2.20 |
| DCB Decachlorobiphenyl | 7.64 | 7.63      | 7.66 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/40 Calibration Date: 09/06/2018 01:49  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090540.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D    | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-------|--------|
| PCB-1262 Peak 1 | Ave        | 0.0418  | 0.0378 |         | 0.452       | 0.500        | -9.6  | 20.0   |
| PCB-1262 Peak 2 | Ave        | 0.0582  | 0.0519 |         | 0.447       | 0.500        | -10.7 | 20.0   |
| PCB-1262 Peak 3 | Ave        | 0.0481  | 0.0430 |         | 0.447       | 0.500        | -10.6 | 20.0   |
| PCB-1262 Peak 4 | Ave        | 0.1149  | 0.1043 |         | 0.454       | 0.500        | -9.2  | 20.0   |
| PCB-1262 Peak 5 | Ave        | 0.0485  | 0.0429 |         | 0.443       | 0.500        | -11.4 | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/40 Calibration Date: 09/06/2018 01:49  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090540.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1262 Peak 1 | 4.88 | 4.86      | 4.90 |
| PCB-1262 Peak 2 | 5.26 | 5.24      | 5.28 |
| PCB-1262 Peak 3 | 5.48 | 5.46      | 5.50 |
| PCB-1262 Peak 4 | 5.77 | 5.75      | 5.78 |
| PCB-1262 Peak 5 | 6.05 | 6.03      | 6.06 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/40 Calibration Date: 09/06/2018 01:49  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090540.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1262 Peak 1 | Ave        | 0.0303  | 0.0277 |         | 0.457       | 0.500        | -8.5 | 20.0   |
| PCB-1262 Peak 2 | Ave        | 0.0468  | 0.0436 |         | 0.466       | 0.500        | -6.7 | 20.0   |
| PCB-1262 Peak 3 | Ave        | 0.0378  | 0.0351 |         | 0.465       | 0.500        | -7.0 | 20.0   |
| PCB-1262 Peak 4 | Ave        | 0.0868  | 0.0803 |         | 0.463       | 0.500        | -7.5 | 20.0   |
| PCB-1262 Peak 5 | Ave        | 0.0622  | 0.0576 |         | 0.463       | 0.500        | -7.5 | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/40 Calibration Date: 09/06/2018 01:49  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2090540.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1262 Peak 1 | 5.55 | 5.53      | 5.56 |
| PCB-1262 Peak 2 | 5.94 | 5.93      | 5.96 |
| PCB-1262 Peak 3 | 6.19 | 6.18      | 6.21 |
| PCB-1262 Peak 4 | 6.41 | 6.39      | 6.43 |
| PCB-1262 Peak 5 | 6.71 | 6.69      | 6.73 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/41 Calibration Date: 09/06/2018 02:04  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090541.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D    | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-------|--------|
| PCB-1268 Peak 1 | Ave        | 0.1382  | 0.1557 |         | 0.563       | 0.500        | 12.7  | 20.0   |
| PCB-1268 Peak 2 | Ave        | 0.1294  | 0.1653 |         | 0.639       | 0.500        | 27.7* | 20.0   |
| PCB-1268 Peak 3 | Ave        | 0.1121  | 0.1126 |         | 0.502       | 0.500        | 0.4   | 20.0   |
| PCB-1268 Peak 4 | Ave        | 0.0448  | 0.0514 |         | 0.574       | 0.500        | 14.7  | 20.0   |
| PCB-1268 Peak 5 | Ave        | 0.3308  | 0.3175 |         | 0.480       | 0.500        | -4.0  | 20.0   |

Average %D < 20% ↓



FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/41 Calibration Date: 09/06/2018 02:04  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090541.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1268 Peak 1 | 6.05 | 6.03      | 6.07 |
| PCB-1268 Peak 2 | 6.08 | 6.06      | 6.10 |
| PCB-1268 Peak 3 | 6.24 | 6.23      | 6.27 |
| PCB-1268 Peak 4 | 6.55 | 6.53      | 6.57 |
| PCB-1268 Peak 5 | 6.78 | 6.76      | 6.80 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/41 Calibration Date: 09/06/2018 02:04  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090541.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D    | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|-------|--------|
| PCB-1268 Peak 1 | Ave        | 0.1031  | 0.1177 |         | 0.571       | 0.500        | 14.2  | 20.0   |
| PCB-1268 Peak 2 | Ave        | 0.0993  | 0.1247 |         | 0.628       | 0.500        | 25.6* | 20.0   |
| PCB-1268 Peak 3 | Ave        | 0.0861  | 0.0866 |         | 0.503       | 0.500        | 0.6   | 20.0   |
| PCB-1268 Peak 4 | Ave        | 0.0353  | 0.0405 |         | 0.573       | 0.500        | 14.7  | 20.0   |
| PCB-1268 Peak 5 | Ave        | 0.2373  | 0.2264 |         | 0.477       | 0.500        | -4.6  | 20.0   |

Average %D < 20% ↓

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: ICV 240-343960/41 Calibration Date: 09/06/2018 02:04  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2090541.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1268 Peak 1 | 6.71 | 6.69      | 6.73 |
| PCB-1268 Peak 2 | 6.74 | 6.73      | 6.77 |
| PCB-1268 Peak 3 | 6.95 | 6.93      | 6.97 |
| PCB-1268 Peak 4 | 7.18 | 7.16      | 7.20 |
| PCB-1268 Peak 5 | 7.44 | 7.42      | 7.46 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/3 Calibration Date: 09/27/2018 21:05  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2092729.D Conc. Units: ng/uL

| ANALYTE                | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|------------------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1016 Peak 1        | Ave        | 0.0141  | 0.0136 |         | 0.481       | 0.500        | -3.8 | 20.0   |
| PCB-1016 Peak 2        | Ave        | 0.0264  | 0.0258 |         | 0.488       | 0.500        | -2.4 | 20.0   |
| PCB-1016 Peak 3        | Ave        | 0.0608  | 0.0607 |         | 0.500       | 0.500        | -0.0 | 20.0   |
| PCB-1016 Peak 4        | Ave        | 0.0250  | 0.0251 |         | 0.501       | 0.500        | 0.2  | 20.0   |
| PCB-1016 Peak 5        | Ave        | 0.0246  | 0.0249 |         | 0.506       | 0.500        | 1.2  | 20.0   |
| PCB-1260 Peak 1        | Ave        | 0.0318  | 0.0346 |         | 0.543       | 0.500        | 8.7  | 20.0   |
| PCB-1260 Peak 2        | Ave        | 0.0548  | 0.0579 |         | 0.528       | 0.500        | 5.7  | 20.0   |
| PCB-1260 Peak 3        | Ave        | 0.0598  | 0.0642 |         | 0.536       | 0.500        | 7.2  | 20.0   |
| PCB-1260 Peak 4        | Ave        | 0.0916  | 0.0971 |         | 0.530       | 0.500        | 6.0  | 20.0   |
| PCB-1260 Peak 5        | Ave        | 0.0421  | 0.0445 |         | 0.529       | 0.500        | 5.8  | 20.0   |
| Tetrachloro-m-xylene   | Ave        | 0.8854  | 0.8575 |         | 0.0242      | 0.0250       | -3.1 | 20.0   |
| DCB Decachlorobiphenyl | Ave        | 0.8253  | 0.8181 |         | 0.0248      | 0.0250       | -0.9 | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/3 Calibration Date: 09/27/2018 21:05  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2092729.D

| Analyte                | RT   | RT WINDOW |      |
|------------------------|------|-----------|------|
|                        |      | FROM      | TO   |
| PCB-1016 Peak 1        | 2.14 | 2.12      | 2.16 |
| PCB-1016 Peak 2        | 2.47 | 2.45      | 2.48 |
| PCB-1016 Peak 3        | 2.90 | 2.88      | 2.92 |
| PCB-1016 Peak 4        | 3.03 | 3.01      | 3.05 |
| PCB-1016 Peak 5        | 3.42 | 3.40      | 3.44 |
| PCB-1260 Peak 1        | 4.58 | 4.56      | 4.60 |
| PCB-1260 Peak 2        | 4.86 | 4.84      | 4.88 |
| PCB-1260 Peak 3        | 5.12 | 5.10      | 5.14 |
| PCB-1260 Peak 4        | 5.74 | 5.72      | 5.76 |
| PCB-1260 Peak 5        | 5.98 | 5.97      | 6.00 |
| Tetrachloro-m-xylene   | 1.81 | 1.79      | 1.82 |
| DCB Decachlorobiphenyl | 6.91 | 6.89      | 6.93 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/4 Calibration Date: 09/27/2018 21:20  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2092730.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1232 Peak 1 | Ave        | 0.0173  | 0.0172 |         | 0.498       | 0.500        | -0.5 | 20.0   |
| PCB-1232 Peak 2 | Ave        | 0.0123  | 0.0125 |         | 0.509       | 0.500        | 1.7  | 20.0   |
| PCB-1232 Peak 3 | Ave        | 0.0277  | 0.0282 |         | 0.508       | 0.500        | 1.5  | 20.0   |
| PCB-1232 Peak 4 | Ave        | 0.0114  | 0.0118 |         | 0.518       | 0.500        | 3.7  | 20.0   |
| PCB-1232 Peak 5 | Ave        | 0.0038  | 0.0043 |         | 0.559       | 0.500        | 11.9 | 20.0   |
| PCB-1262 Peak 1 | Ave        | 0.0418  | 0.0450 |         | 0.539       | 0.500        | 7.7  | 20.0   |
| PCB-1262 Peak 2 | Ave        | 0.0582  | 0.0599 |         | 0.515       | 0.500        | 2.9  | 20.0   |
| PCB-1262 Peak 3 | Ave        | 0.0481  | 0.0506 |         | 0.526       | 0.500        | 5.1  | 20.0   |
| PCB-1262 Peak 4 | Ave        | 0.1149  | 0.1219 |         | 0.531       | 0.500        | 6.2  | 20.0   |
| PCB-1262 Peak 5 | Ave        | 0.0485  | 0.0498 |         | 0.514       | 0.500        | 2.8  | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/4 Calibration Date: 09/27/2018 21:20  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 17:01  
 GC Column: CLP-1 (0.53mm) ID: 0.53(mm) Calib End Date: 09/05/2018 18:15  
 Lab File ID: P2092730.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1232 Peak 1 | 2.14 | 2.12      | 2.16 |
| PCB-1232 Peak 2 | 2.47 | 2.45      | 2.49 |
| PCB-1232 Peak 3 | 2.90 | 2.88      | 2.92 |
| PCB-1232 Peak 4 | 3.03 | 3.01      | 3.05 |
| PCB-1232 Peak 5 | 3.26 | 3.24      | 3.28 |
| PCB-1262 Peak 1 | 4.86 | 4.84      | 4.88 |
| PCB-1262 Peak 2 | 5.23 | 5.21      | 5.25 |
| PCB-1262 Peak 3 | 5.46 | 5.44      | 5.47 |
| PCB-1262 Peak 4 | 5.74 | 5.72      | 5.76 |
| PCB-1262 Peak 5 | 6.02 | 6.00      | 6.04 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/5 Calibration Date: 09/27/2018 21:34  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2092731.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1242 Peak 1 | Ave        | 0.0117  | 0.0116 |         | 0.493       | 0.500        | -1.4 | 20.0   |
| PCB-1242 Peak 2 | Ave        | 0.0213  | 0.0213 |         | 0.499       | 0.500        | -0.2 | 20.0   |
| PCB-1242 Peak 3 | Ave        | 0.0493  | 0.0495 |         | 0.502       | 0.500        | 0.3  | 20.0   |
| PCB-1242 Peak 4 | Ave        | 0.0203  | 0.0207 |         | 0.508       | 0.500        | 1.6  | 20.0   |
| PCB-1242 Peak 5 | Ave        | 0.0078  | 0.0085 |         | 0.545       | 0.500        | 9.0  | 20.0   |
| PCB-1268 Peak 1 | Ave        | 0.1382  | 0.1417 |         | 0.512       | 0.500        | 2.5  | 20.0   |
| PCB-1268 Peak 2 | Ave        | 0.1294  | 0.1330 |         | 0.514       | 0.500        | 2.7  | 20.0   |
| PCB-1268 Peak 3 | Ave        | 0.1121  | 0.1147 |         | 0.512       | 0.500        | 2.3  | 20.0   |
| PCB-1268 Peak 4 | Ave        | 0.0448  | 0.0462 |         | 0.515       | 0.500        | 3.1  | 20.0   |
| PCB-1268 Peak 5 | Ave        | 0.3308  | 0.3426 |         | 0.518       | 0.500        | 3.6  | 20.0   |



FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/5 Calibration Date: 09/27/2018 21:34  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 18:30  
 GC Column: CLP-1 (0.53mm) ID: 0.53(mm) Calib End Date: 09/05/2018 19:43  
 Lab File ID: P2092731.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1242 Peak 1 | 2.14 | 2.12      | 2.16 |
| PCB-1242 Peak 2 | 2.47 | 2.45      | 2.48 |
| PCB-1242 Peak 3 | 2.90 | 2.88      | 2.92 |
| PCB-1242 Peak 4 | 3.03 | 3.01      | 3.05 |
| PCB-1242 Peak 5 | 3.26 | 3.24      | 3.28 |
| PCB-1268 Peak 1 | 6.02 | 6.00      | 6.04 |
| PCB-1268 Peak 2 | 6.05 | 6.03      | 6.07 |
| PCB-1268 Peak 3 | 6.22 | 6.20      | 6.24 |
| PCB-1268 Peak 4 | 6.52 | 6.50      | 6.54 |
| PCB-1268 Peak 5 | 6.76 | 6.74      | 6.78 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/6 Calibration Date: 09/27/2018 21:49  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 19:58  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 21:11  
 Lab File ID: P2092732.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1248 Peak 1 | Ave        | 0.0109  | 0.0111 |         | 0.508       | 0.500        | 1.6  | 20.0   |
| PCB-1248 Peak 2 | Ave        | 0.0313  | 0.0312 |         | 0.498       | 0.500        | -0.5 | 20.0   |
| PCB-1248 Peak 3 | Ave        | 0.0288  | 0.0288 |         | 0.499       | 0.500        | -0.1 | 20.0   |
| PCB-1248 Peak 4 | Ave        | 0.0227  | 0.0230 |         | 0.507       | 0.500        | 1.5  | 20.0   |
| PCB-1248 Peak 5 | Ave        | 0.0145  | 0.0156 |         | 0.538       | 0.500        | 7.7  | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/6 Calibration Date: 09/27/2018 21:49  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 19:58  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 21:11  
 Lab File ID: P2092732.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1248 Peak 1 | 2.46 | 2.45      | 2.48 |
| PCB-1248 Peak 2 | 3.42 | 3.40      | 3.43 |
| PCB-1248 Peak 3 | 3.82 | 3.80      | 3.84 |
| PCB-1248 Peak 4 | 4.02 | 4.00      | 4.04 |
| PCB-1248 Peak 5 | 4.39 | 4.37      | 4.41 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/7 Calibration Date: 09/27/2018 22:03  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2092733.D Conc. Units: ng/uL

| ANALYTE         | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D   | MAX %D |
|-----------------|------------|---------|--------|---------|-------------|--------------|------|--------|
| PCB-1221 Peak 1 | Ave        | 0.0085  | 0.0084 |         | 0.495       | 0.500        | -1.1 | 20.0   |
| PCB-1221 Peak 2 | Ave        | 0.0049  | 0.0054 |         | 0.552       | 0.500        | 10.3 | 20.0   |
| PCB-1221 Peak 3 | Ave        | 0.0208  | 0.0211 |         | 0.506       | 0.500        | 1.3  | 20.0   |
| PCB-1254 Peak 1 | Ave        | 0.0230  | 0.0239 |         | 0.520       | 0.500        | 4.0  | 20.0   |
| PCB-1254 Peak 2 | Ave        | 0.0475  | 0.0538 |         | 0.566       | 0.500        | 13.2 | 20.0   |
| PCB-1254 Peak 3 | Ave        | 0.0361  | 0.0409 |         | 0.566       | 0.500        | 13.2 | 20.0   |
| PCB-1254 Peak 4 | Ave        | 0.0324  | 0.0360 |         | 0.556       | 0.500        | 11.3 | 20.0   |
| PCB-1254 Peak 5 | Ave        | 0.0485  | 0.0545 |         | 0.562       | 0.500        | 12.3 | 20.0   |

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCV 240-347579/7 Calibration Date: 09/27/2018 22:03  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 21:26  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/05/2018 22:39  
 Lab File ID: P2092733.D

| Analyte         | RT   | RT WINDOW |      |
|-----------------|------|-----------|------|
|                 |      | FROM      | TO   |
| PCB-1221 Peak 1 | 1.97 | 1.95      | 1.99 |
| PCB-1221 Peak 2 | 2.10 | 2.08      | 2.12 |
| PCB-1221 Peak 3 | 2.14 | 2.12      | 2.16 |
| PCB-1254 Peak 1 | 3.78 | 3.76      | 3.79 |
| PCB-1254 Peak 2 | 4.39 | 4.38      | 4.41 |
| PCB-1254 Peak 3 | 4.67 | 4.65      | 4.69 |
| PCB-1254 Peak 4 | 4.86 | 4.84      | 4.87 |
| PCB-1254 Peak 5 | 5.12 | 5.10      | 5.14 |

FORM VII  
PCBS CONTINUING CALIBRATION DATA

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCVIS 240-347579/28 Calibration Date: 09/28/2018 03:06  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2092754.D Conc. Units: ng/uL

| ANALYTE                | CURVE TYPE | AVE RRF | RRF    | MIN RRF | CALC AMOUNT | SPIKE AMOUNT | %D     | MAX %D |
|------------------------|------------|---------|--------|---------|-------------|--------------|--------|--------|
| PCB-1016 Peak 1        | Ave        | 0.0141  | 0.0136 |         | 0.482       | 0.500        | -3.6   | 20.0   |
| PCB-1016 Peak 2        | Ave        | 0.0264  | 0.0259 |         | 0.490       | 0.500        | -2.1   | 20.0   |
| PCB-1016 Peak 3        | Ave        | 0.0608  | 0.0612 |         | 0.504       | 0.500        | 0.7    | 20.0   |
| PCB-1016 Peak 4        | Ave        | 0.0250  | 0.0251 |         | 0.501       | 0.500        | 0.2    | 20.0   |
| PCB-1016 Peak 5        | Ave        | 0.0246  | 0.0249 |         | 0.507       | 0.500        | 1.4    | 20.0   |
| PCB-1260 Peak 1        | Ave        | 0.0318  | 0.0288 |         | 0.453       | 0.500        | -9.4   | 20.0   |
| PCB-1260 Peak 2        | Ave        | 0.0548  | 0.0451 |         | 0.412       | 0.500        | -17.7  | 20.0   |
| PCB-1260 Peak 3        | Ave        | 0.0598  | 0.0488 |         | 0.407       | 0.500        | -18.5  | 20.0   |
| PCB-1260 Peak 4        | Ave        | 0.0916  | 0.0679 |         | 0.371       | 0.500        | -25.9* | 20.0   |
| PCB-1260 Peak 5        | Ave        | 0.0421  | 0.0314 |         | 0.373       | 0.500        | -25.3* | 20.0   |
| Tetrachloro-m-xylene   | Ave        | 0.8854  | 0.8639 |         | 0.0244      | 0.0250       | -2.4   | 20.0   |
| DCB Decachlorobiphenyl | Ave        | 0.8253  | 0.5927 |         | 0.0180      | 0.0250       | -28.2* | 20.0   |

Average Aroclor-1260 %D < 20% ✓

FORM VII  
PCBS CONTINUING CALIBRATION RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Lab Sample ID: CCVIS 240-347579/28 Calibration Date: 09/28/2018 03:06  
 Instrument ID: A2HP2 Calib Start Date: 09/05/2018 22:54  
 GC Column: CLP-1 (0.53mm) ID: 0.53(mm) Calib End Date: 09/06/2018 00:07  
 Lab File ID: P2092754.D

| Analyte                | RT   | RT WINDOW |      |
|------------------------|------|-----------|------|
|                        |      | FROM      | TO   |
| PCB-1016 Peak 1        | 2.14 | 2.12      | 2.16 |
| PCB-1016 Peak 2        | 2.47 | 2.45      | 2.49 |
| PCB-1016 Peak 3        | 2.90 | 2.88      | 2.92 |
| PCB-1016 Peak 4        | 3.03 | 3.01      | 3.05 |
| PCB-1016 Peak 5        | 3.42 | 3.40      | 3.44 |
| PCB-1260 Peak 1        | 4.58 | 4.56      | 4.60 |
| PCB-1260 Peak 2        | 4.86 | 4.84      | 4.88 |
| PCB-1260 Peak 3        | 5.12 | 5.10      | 5.14 |
| PCB-1260 Peak 4        | 5.74 | 5.72      | 5.76 |
| PCB-1260 Peak 5        | 5.99 | 5.97      | 6.00 |
| Tetrachloro-m-xylene   | 1.81 | 1.79      | 1.83 |
| DCB Decachlorobiphenyl | 6.91 | 6.89      | 6.93 |

FORM VIII  
PCBS INTERNAL STANDARD AREA AND RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Sample No.: STD05 240-343960/31 Date Analyzed: 09/05/2018 23:38  
 Instrument ID: A2HP2 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm)  
 Lab File ID (Standard): P2090531.D Heated Purge: (Y/N) N  
 Calibration ID: 46854

|                               | BNB              |          | AREA # | RT # | AREA # | RT # | AREA # | RT # |
|-------------------------------|------------------|----------|--------|------|--------|------|--------|------|
|                               | AREA #           | RT #     |        |      |        |      |        |      |
| INITIAL CALIBRATION MID-POINT | 69160257         | 1.24     |        |      |        |      |        |      |
| UPPER LIMIT                   | 138320514        | 1.74     |        |      |        |      |        |      |
| LOWER LIMIT                   | 34580129         | 0.74     |        |      |        |      |        |      |
| LAB SAMPLE ID                 | CLIENT SAMPLE ID |          |        |      |        |      |        |      |
| ICV 240-343960/34             |                  | 69996158 | 1.24   |      |        |      |        |      |
| ICV 240-343960/35             |                  | 70872449 | 1.24   |      |        |      |        |      |
| ICV 240-343960/36             |                  | 71939380 | 1.24   |      |        |      |        |      |
| ICV 240-343960/37             |                  | 71193944 | 1.24   |      |        |      |        |      |
| ICV 240-343960/38             |                  | 73907578 | 1.24   |      |        |      |        |      |
| ICV 240-343960/39             |                  | 66883623 | 1.24   |      |        |      |        |      |
| ICV 240-343960/40             |                  | 76651910 | 1.24   |      |        |      |        |      |
| ICV 240-343960/41             |                  | 75022062 | 1.24   |      |        |      |        |      |
| CCVIS 240-347579/28           |                  | 76953042 | 1.22   |      |        |      |        |      |

BNB = 1-Bromo-2-nitrobenzene

Area Limit = 50%-200% of internal standard area  
 RT Limit = ± 0.5 minutes of internal standard RT

# Column used to flag values outside QC limits



FORM VIII  
PCBS INTERNAL STANDARD AREA AND RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Sample No.: STD05 240-343960/31 Date Analyzed: 09/05/2018 23:38  
 Instrument ID: A2HP2 GC Column: CLP-2 (0.53mm) ID: 0.53 (mm)  
 Lab File ID (Standard): P2090531.D Heated Purge: (Y/N) N  
 Calibration ID: 46855

|                               | BNB              |          | AREA # | RT # | AREA # | RT # |
|-------------------------------|------------------|----------|--------|------|--------|------|
|                               | AREA #           | RT #     |        |      |        |      |
| INITIAL CALIBRATION MID-POINT | 51060536         | 1.38     |        |      |        |      |
| UPPER LIMIT                   | 102121072        | 1.88     |        |      |        |      |
| LOWER LIMIT                   | 25530268         | 0.88     |        |      |        |      |
| LAB SAMPLE ID                 | CLIENT SAMPLE ID |          |        |      |        |      |
| ICV 240-343960/34             |                  | 52492474 | 1.38   |      |        |      |
| ICV 240-343960/35             |                  | 53366179 | 1.38   |      |        |      |
| ICV 240-343960/36             |                  | 53641456 | 1.38   |      |        |      |
| ICV 240-343960/37             |                  | 53643191 | 1.38   |      |        |      |
| ICV 240-343960/38             |                  | 54443317 | 1.38   |      |        |      |
| ICV 240-343960/39             |                  | 49479088 | 1.38   |      |        |      |
| ICV 240-343960/40             |                  | 56082802 | 1.38   |      |        |      |
| ICV 240-343960/41             |                  | 55428685 | 1.38   |      |        |      |
| CCV 240-347579/4              |                  | 74699749 | 1.22   |      |        |      |

BNB = 1-Bromo-2-nitrobenzene

Area Limit = 50%-200% of internal standard area  
 RT Limit = ± 0.5 minutes of internal standard RT

# Column used to flag values outside QC limits

FORM VIII  
PCBS INTERNAL STANDARD AREA AND RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Sample No.: CCV 240-347579/3 Date Analyzed: 09/27/2018 21:05  
 Instrument ID: A2HP2 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm)  
 Lab File ID (Standard): P2092729.D Heated Purge: (Y/N) N  
 Calibration ID: 46854

|                     | BNB              |          | AREA # | RT # | AREA # | RT # |
|---------------------|------------------|----------|--------|------|--------|------|
|                     | AREA #           | RT #     |        |      |        |      |
| 12/24 HOUR STD      | 76961041         | 1.22     |        |      |        |      |
| UPPER LIMIT         | 153922082        | 1.72     |        |      |        |      |
| LOWER LIMIT         | 38480521         | 0.72     |        |      |        |      |
| LAB SAMPLE ID       | CLIENT SAMPLE ID |          |        |      |        |      |
| CCV 240-347579/4    |                  | 74699749 | 1.22   |      |        |      |
| CCV 240-347579/5    |                  | 74234498 | 1.22   |      |        |      |
| CCV 240-347579/6    |                  | 75058992 | 1.22   |      |        |      |
| CCV 240-347579/7    |                  | 78893104 | 1.22   |      |        |      |
| MB 240-347068/19-A  |                  | 84661391 | 1.22   |      |        |      |
| LCS 240-347068/20-A |                  | 77228010 | 1.22   |      |        |      |

BNB = 1-Bromo-2-nitrobenzene

Area Limit = 50%-200% of internal standard area  
 RT Limit = ± 0.5 minutes of internal standard RT

# Column used to flag values outside QC limits

FORM VIII  
PCBS INTERNAL STANDARD AREA AND RETENTION TIME SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Sample No.: CCVIS 240-347579/28 Date Analyzed: 09/28/2018 03:06  
 Instrument ID: A2HP2 GC Column: CLP-1 (0.53mm) ID: 0.53 (mm)  
 Lab File ID (Standard): P2092754.D Heated Purge: (Y/N) N  
 Calibration ID: 46854

|                | BNB              |          |        |      |        |      |
|----------------|------------------|----------|--------|------|--------|------|
|                | AREA #           | RT #     | AREA # | RT # | AREA # | RT # |
| 12/24 HOUR STD | 76953042         | 1.22     |        |      |        |      |
| UPPER LIMIT    | 153906084        | 1.72     |        |      |        |      |
| LOWER LIMIT    | 38476521         | 0.72     |        |      |        |      |
| LAB SAMPLE ID  | CLIENT SAMPLE ID |          |        |      |        |      |
| 240-101687-1   | MH-09-091918     | 81212604 | 1.22   |      |        |      |
| 240-101687-2   | MH-DUP-091918    | 82503179 | 1.22   |      |        |      |

BNB = 1-Bromo-2-nitrobenzene

Area Limit = 50%-200% of internal standard area  
 RT Limit = ± 0.5 minutes of internal standard RT

# Column used to flag values outside QC limits

FORM X  
IDENTIFICATION SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Client Sample ID: MH-09-091918 Lab Sample ID: 240-101687-1  
 Instrument ID (1): A2HP2 Instrument ID (2): A2HP2  
 Date Analyzed (1): 09/28/2018 03:35 Date Analyzed (2): 09/28/2018 03:35  
 GC Column (1): CLP-2 (0.53mm ID: 0.53(mm)) GC Column (2): CLP-1 (0.53mm ID: 0.53(mm))

| ANALYTE      | COL | PEAK | RT   | RT WINDOW |      | CONCENTRATION |        | RPD  |
|--------------|-----|------|------|-----------|------|---------------|--------|------|
|              |     |      |      | FROM      | TO   | PEAK          | MEAN   |      |
| Aroclor-1260 | 1   | 1    | 5.30 | 5.28      | 5.32 | 133000        | 120000 | 15.1 |
|              |     | 2    | 5.50 | 5.48      | 5.52 | 148000        |        |      |
|              |     | 3    | 5.89 | 5.88      | 5.91 | 106000        |        |      |
|              |     | 4    | 6.36 | 6.34      | 6.38 | 117000        |        |      |
|              |     | 5    | 6.66 | 6.64      | 6.68 | 106000        |        |      |
|              | 2   | 1    | 4.58 | 4.56      | 4.60 | 150000        | 140000 |      |
|              |     | 2    | 4.86 | 4.84      | 4.88 | 163000        |        |      |
|              |     | 3    | 5.12 | 5.10      | 5.14 | 156000        |        |      |
|              |     | 4    | 5.74 | 5.72      | 5.76 | 114000        |        |      |
|              |     | 5    | 5.98 | 5.97      | 6.00 | 127000        |        |      |

FORM X  
IDENTIFICATION SUMMARY

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Client Sample ID: MH-DUP-091918 Lab Sample ID: 240-101687-2  
 Instrument ID (1): A2HP2 Instrument ID (2): A2HP2  
 Date Analyzed (1): 09/28/2018 03:50 Date Analyzed (2): 09/28/2018 03:50  
 GC Column (1): CLP-2 (0.53mm ID: 0.53(mm)) GC Column (2): CLP-1 (0.53mm ID: 0.53(mm))

| ANALYTE      | COL | PEAK | RT   | RT WINDOW |      | CONCENTRATION |        | RPD |
|--------------|-----|------|------|-----------|------|---------------|--------|-----|
|              |     |      |      | FROM      | TO   | PEAK          | MEAN   |     |
| Aroclor-1260 | 1   | 1    | 5.30 | 5.28      | 5.32 | 194000        | 170000 | 8.5 |
|              |     | 2    | 5.50 | 5.48      | 5.52 | 208000        |        |     |
|              |     | 3    | 5.89 | 5.88      | 5.91 | 147000        |        |     |
|              |     | 4    | 6.36 | 6.34      | 6.38 | 162000        |        |     |
|              |     | 5    | 6.66 | 6.64      | 6.68 | 143000        |        |     |
|              | 2   | 1    | 4.58 | 4.56      | 4.60 | 195000        | 190000 |     |
|              |     | 2    | 4.86 | 4.84      | 4.88 | 205000        |        |     |
|              |     | 3    | 5.12 | 5.10      | 5.14 | 210000        |        |     |
|              |     | 4    | 5.74 | 5.72      | 5.76 | 152000        |        |     |
|              |     | 5    | 5.99 | 5.97      | 6.00 | 167000        |        |     |

|                                 |                        |
|---------------------------------|------------------------|
| SAMPLE IDENTIFICATION           | MH-09-091918           |
| COMPOUND                        | AROCLOR-1260           |
| AVERAGE CONCENTRATION           | 1.21                   |
| DILUTION FACTOR                 | 100                    |
| VOLUME FINAL EXTRACT (ml)       | 10                     |
| WEIGHT OF SAMPLE (g)            | 10.05                  |
| PERCENT SOLIDS                  | 0.849                  |
| CONCENTRATION =                 | <b>141954.68</b> µg/Kg |
| GC COLUMN 1                     |                        |
| RESPONSE 1                      | 66189345               |
| RESPONSE 2                      | 123589206              |
| RESPONSE 3                      | 129324619              |
| RESPONSE 4                      | 144538185              |
| RESPONSE 5                      | 74070439               |
| RESPONSE FACTOR 1               | 0.0318                 |
| RESPONSE FACTOR 2               | 0.0548                 |
| RESPONSE FACTOR 3               | 0.0598                 |
| RESPONSE FACTOR 4               | 0.0916                 |
| RESPONSE FACTOR 5               | 0.0421                 |
| INTERNAL STANDARD RESPONSE      | 81212604               |
| INTERNAL STANDARD CONCENTRATION | 0.05                   |
| CONCENTRATION 1                 | 1.28                   |
| CONCENTRATION 2                 | 1.39                   |
| CONCENTRATION 3                 | 1.33                   |
| CONCENTRATION 4                 | 0.97                   |
| CONCENTRATION 5                 | 1.08                   |
| AVERAGE (µg/L)                  | 1.21                   |

FORM I  
PCBS ORGANICS ANALYSIS DATA SHEET

Lab Name: TestAmerica Canton Job No.: 240-101687-1  
 SDG No.: \_\_\_\_\_  
 Client Sample ID: MH-09-091918 Lab Sample ID: 240-101687-1  
 Matrix: Solid Lab File ID: P2092756.D  
 Analysis Method: 8082A Date Collected: 09/19/2018 14:30  
 Extraction Method: 3540C Date Extracted: 09/25/2018 09:30  
 Sample wt/vol: 10.05 (g) Date Analyzed: 09/28/2018 03:35  
 Con. Extract Vol.: 10 (mL) Dilution Factor: 100  
 Injection Volume: 1 (uL) GC Column: CLP-1 (0.53mm) ID: 0.53 (mm)  
 % Moisture: 15.1 GPC Cleanup: (Y/N) N  
 Analysis Batch No.: 347579 Units: ug/Kg

| CAS NO.    | COMPOUND NAME | RESULT | Q | RL   | MDL  |
|------------|---------------|--------|---|------|------|
| 12674-11-2 | Aroclor-1016  | 2600   | U | 5900 | 2600 |
| 11104-28-2 | Aroclor-1221  | 2800   | U | 5900 | 2800 |
| 11141-16-5 | Aroclor-1232  | 2700   | U | 5900 | 2700 |
| 53469-21-9 | Aroclor-1242  | 2200   | U | 5900 | 2200 |
| 12672-29-6 | Aroclor-1248  | 2800   | U | 5900 | 2800 |
| 11097-69-1 | Aroclor-1254  | 2700   | U | 5900 | 2700 |
| 11096-82-5 | Aroclor-1260  | 140000 | ✓ | 5900 | 2600 |
| 37324-23-5 | Aroclor-1262  | 3600   | U | 5900 | 3600 |
| 11100-14-4 | Aroclor-1268  | 2700   | U | 5900 | 2700 |

| CAS NO.   | SURROGATE              | %REC | Q   | LIMITS |
|-----------|------------------------|------|-----|--------|
| 877-09-8  | Tetrachloro-m-xylene   | 130  | p X | 14-128 |
| 2051-24-3 | DCB Decachlorobiphenyl | 221  | X   | 10-132 |

TestAmerica Canton  
 Target Compound Quantitation Report

Data File: \\ChromNA\Canton\ChromData\A2HP2\20180927-80319.b\PCB2756.D  
 Lims ID: 240-101687-B-1-A  
 Client ID: MH-09-091918  
 Sample Type: Client  
 Inject. Date: 28-Sep-2018 03:35:47 ALS Bottle#: 56 Worklist Smp#: 30  
 Injection Vol: 1.0 uL Dil. Factor: 100.0000  
 Sample Info: 240-0080319-030  
 Operator ID: Instrument ID: A2HP2  
 Method: \\ChromNA\Canton\ChromData\A2HP2\20180927-80319.b\PCB2 IS.m  
 Limit Group: GC 8082A IS  
 Last Update: 28-Sep-2018 06:58:25 Calib Date: 06-Sep-2018 00:07:27  
 Integrator: Falcon  
 Quant Method: Internal Standard Quant By: Initial Calibration  
 Last ICal File: \\ChromNA\Canton\ChromData\A2HP2\20180905-79561.b\PCB2756.D  
 Column 1 : Det: GC ECD1A  
 Column 2 : Det: GC ecd2b  
 Process Host: XAWRK021

First Level Reviewer: hassl Date: 28-Sep-2018 06:53:07

| Col | RT (min.) | Exp RT (min.) | Dlt RT (min.) | Response | OnCol Amt ng/ul | Flags |
|-----|-----------|---------------|---------------|----------|-----------------|-------|
|-----|-----------|---------------|---------------|----------|-----------------|-------|

S 1 Polychlorinated biphenyls, Total

1 1.000 ND

\* 2 1-Bromo-2-nitrobenzene

|   |       |       |        |          |        |
|---|-------|-------|--------|----------|--------|
| 1 | 1.223 | 1.224 | -0.001 | 81212604 | 0.0500 |
| 2 | 1.356 | 1.356 | 0.000  | 50056333 | 0.0500 |

\$ 3 Tetrachloro-m-xylene

|   |       |       |       |        |          |
|---|-------|-------|-------|--------|----------|
| 1 | 1.806 | 1.806 | 0.000 | 374737 | 0.000261 |
| 2 | 2.151 | 2.150 | 0.001 | 563493 | 0.000598 |

RPD = 78.59

4 PCB-1221

|   |       |  |  |  |    |
|---|-------|--|--|--|----|
| 1 | 1.967 |  |  |  | ND |
| 1 | 2.100 |  |  |  |    |
| 1 | 2.136 |  |  |  |    |
| 2 | 2.442 |  |  |  |    |
| 2 | 2.580 |  |  |  |    |
| 2 | 2.639 |  |  |  |    |



Data File: \\ChromNA\Canton\ChromData\A2HP2\20180927-80319.b\P2092756.D

| Col        | RT (min.) | Exp RT (min.) | Dlt RT (min.) | Response | OnCol Amt ng/ul | Flags |
|------------|-----------|---------------|---------------|----------|-----------------|-------|
| 6 PCB-1232 |           |               |               |          |                 |       |
| 1          |           | 2.136         |               |          | ND              | U     |
| 1          |           | 2.466         |               |          |                 |       |
| 1          |           | 2.902         |               |          |                 |       |
| 1          |           | 3.026         |               |          |                 |       |
| 1          |           | 3.261         |               |          |                 |       |
| 2          |           | 2.639         |               |          |                 |       |
| 2          |           | 3.039         |               |          |                 |       |
| 2          |           | 3.485         |               |          |                 |       |
| 2          |           | 3.615         |               |          |                 |       |
| 2          |           | 3.853         |               |          |                 |       |
| 5 PCB-1016 |           |               |               |          |                 |       |
| 1          |           | 2.137         |               |          | ND              | U     |
| 1          |           | 2.466         |               |          |                 |       |
| 1          |           | 2.903         |               |          |                 |       |
| 1          |           | 3.028         |               |          |                 |       |
| 1          |           | 3.416         |               |          |                 |       |
| 2          |           | 2.639         |               |          |                 |       |
| 2          |           | 3.040         |               |          |                 |       |
| 2          |           | 3.486         |               |          |                 |       |
| 2          |           | 3.615         |               |          |                 |       |
| 2          |           | 3.854         |               |          |                 |       |
| 7 PCB-1242 |           |               |               |          |                 |       |
| 1          |           | 2.137         |               |          | ND              | U     |
| 1          |           | 2.465         |               |          |                 |       |
| 1          |           | 2.902         |               |          |                 |       |
| 1          |           | 3.027         |               |          |                 |       |
| 1          |           | 3.261         |               |          |                 |       |
| 2          |           | 2.639         |               |          |                 |       |
| 2          |           | 3.040         |               |          |                 |       |
| 2          |           | 3.485         |               |          |                 |       |
| 2          |           | 3.615         |               |          |                 |       |
| 2          |           | 3.854         |               |          |                 |       |
| 8 PCB-1248 |           |               |               |          |                 |       |
| 1          |           | 2.464         |               |          | ND              | U     |
| 1          |           | 3.415         |               |          |                 |       |
| 1          |           | 3.818         |               |          |                 |       |
| 1          |           | 4.023         |               |          |                 |       |
| 1          |           | 4.393         |               |          |                 |       |
| 2          |           | 3.038         |               |          |                 |       |
| 2          |           | 3.482         |               |          |                 |       |
| 2          |           | 4.066         |               |          |                 |       |
| 2          |           | 4.474         |               |          |                 |       |
| 2          |           | 5.115         |               |          |                 |       |

Data File: \\ChromNA\Canton\ChromData\A2HP2\20180927-80319.b\P2092756.D

| Col | RT (min.) | Exp RT (min.) | Dlt RT (min.) | Response | OnCol Amt ng/ul | Flags |
|-----|-----------|---------------|---------------|----------|-----------------|-------|
|-----|-----------|---------------|---------------|----------|-----------------|-------|

|            |  |       |  |  |    |   |
|------------|--|-------|--|--|----|---|
| 9 PCB-1254 |  |       |  |  |    | U |
| 1          |  | 3.775 |  |  | ND |   |
| 1          |  | 4.394 |  |  |    |   |
| 1          |  | 4.673 |  |  |    |   |
| 1          |  | 4.855 |  |  |    |   |
| 1          |  | 5.120 |  |  |    |   |
| 2          |  | 4.469 |  |  |    |   |
| 2          |  | 5.115 |  |  |    |   |
| 2          |  | 5.330 |  |  |    |   |
| 2          |  | 5.641 |  |  |    |   |
| 2          |  | 5.811 |  |  |    |   |

|                           |       |       |        |           |        |   |
|---------------------------|-------|-------|--------|-----------|--------|---|
| 10 PCB-1260               |       |       |        |           |        | M |
| 1                         | 4.578 | 4.579 | -0.001 | 66189345  | 1.28   | M |
| 1                         | 4.856 | 4.857 | -0.001 | 123589206 | 1.39   | M |
| 1                         | 5.119 | 5.120 | -0.001 | 129324619 | 1.33   | M |
| 1                         | 5.739 | 5.740 | -0.001 | 144538185 | 0.9715 |   |
| 1                         | 5.984 | 5.985 | -0.001 | 74070439  | 1.08   |   |
| Average of Peak Amounts = |       |       |        |           | 1.21   | ✓ |
| 2                         | 5.299 | 5.300 | -0.001 | 36981151  | 1.14   |   |
| 2                         | 5.496 | 5.497 | -0.001 | 46554027  | 1.26   |   |
| 2                         | 5.893 | 5.894 | -0.001 | 29381011  | 0.9055 |   |
| 2                         | 6.362 | 6.363 | -0.001 | 74625107  | 1.00   |   |
| 2                         | 6.663 | 6.663 | 0.000  | 46485379  | 0.9027 |   |
| Average of Peak Amounts = |       |       |        |           | 1.04   |   |

RPD = 15.06

|             |  |       |  |  |    |   |
|-------------|--|-------|--|--|----|---|
| 11 PCB-1262 |  |       |  |  |    | U |
| 1           |  | 4.856 |  |  | ND |   |
| 1           |  | 5.231 |  |  |    |   |
| 1           |  | 5.455 |  |  |    |   |
| 1           |  | 5.738 |  |  |    |   |
| 1           |  | 6.018 |  |  |    |   |
| 2           |  | 5.496 |  |  |    |   |
| 2           |  | 5.894 |  |  |    |   |
| 2           |  | 6.145 |  |  |    |   |
| 2           |  | 6.361 |  |  |    |   |
| 2           |  | 6.661 |  |  |    |   |

|             |  |       |  |  |    |   |
|-------------|--|-------|--|--|----|---|
| 12 PCB-1268 |  |       |  |  |    | U |
| 1           |  | 6.019 |  |  | ND |   |
| 1           |  | 6.052 |  |  |    |   |
| 1           |  | 6.218 |  |  |    |   |
| 1           |  | 6.519 |  |  |    |   |
| 1           |  | 6.756 |  |  |    |   |
| 2           |  | 6.659 |  |  |    |   |
| 2           |  | 6.697 |  |  |    |   |
| 2           |  | 6.903 |  |  |    |   |
| 2           |  | 7.134 |  |  |    |   |
| 2           |  | 7.393 |  |  |    |   |

|                              |       |       |        |        |          |
|------------------------------|-------|-------|--------|--------|----------|
| \$ 13 DCB Decachlorobiphenyl |       |       |        |        |          |
| 1                            | 6.910 | 6.911 | -0.001 | 592409 | 0.000442 |
| 2                            | 7.595 | 7.597 | -0.002 | 170427 | 0.000258 |

RPD = 52.72

FORM VI  
PCBS BY INTERNAL STANDARD - INITIAL CALIBRATION DATA  
CURVE EVALUATION

Sample Calculation - Page 6

Lab Name: TestAmerica Canton Job No.: 240-101687-1 Analy Batch No.: 343960

SDG No.: \_\_\_\_\_

Instrument ID: A2HP2 GC Column: CLP-1 (0.53 ID: 0.53 (mm)) Heated Purge: (Y/N) N

Calibration Start Date: 09/05/2018 22:54 Calibration End Date: 09/06/2018 00:07 Calibration ID: 46854

Calibration Files:

| LEVEL:  | LAB SAMPLE ID:       | LAB FILE ID: |
|---------|----------------------|--------------|
| Level 1 | STD005 240-343960/28 | P2090528.D   |
| Level 2 | STD01 240-343960/29  | P2090529.D   |
| Level 3 | STD02 240-343960/30  | P2090530.D   |
| Level 4 | STD05 240-343960/31  | P2090531.D   |
| Level 5 | STD1 240-343960/32   | P2090532.D   |
| Level 6 | STD15 240-343960/33  | P2090533.D   |

| ANALYTE                | RRF              |        |        |        |        | CURVE TYPE | COEFFICIENT |        |    | # | MIN RRF | %RSD | #    | MAX %RSD | R^2 OR COD | # | MIN R^2 OR COD |
|------------------------|------------------|--------|--------|--------|--------|------------|-------------|--------|----|---|---------|------|------|----------|------------|---|----------------|
|                        | LVL 1<br>LVL 6   | LVL 2  | LVL 3  | LVL 4  | LVL 5  |            | B           | M1     | M2 |   |         |      |      |          |            |   |                |
| PCB-1016 Peak 1        | 0.0159<br>0.0132 | 0.0147 | 0.0140 | 0.0137 | 0.0132 | Ave        |             | 0.0141 |    |   | 7.5     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 2        | 0.0280<br>0.0245 | 0.0269 | 0.0281 | 0.0260 | 0.0250 | Ave        |             | 0.0264 |    |   | 5.8     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 3        | 0.0624<br>0.0605 | 0.0602 | 0.0601 | 0.0609 | 0.0606 | Ave        |             | 0.0608 |    |   | 1.4     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 4        | 0.0256<br>0.0247 | 0.0248 | 0.0252 | 0.0251 | 0.0248 | Ave        |             | 0.0250 |    |   | 1.4     |      | 20.0 |          |            |   |                |
| PCB-1016 Peak 5        | 0.0250<br>0.0238 | 0.0253 | 0.0246 | 0.0246 | 0.0241 | Ave        |             | 0.0246 |    |   | 2.2     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 1        | 0.0333<br>0.0308 | 0.0328 | 0.0314 | 0.0316 | 0.0310 | Ave        |             | 0.0318 |    |   | 3.2     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 2        | 0.0587<br>0.0531 | 0.0555 | 0.0544 | 0.0538 | 0.0535 | Ave        |             | 0.0548 |    |   | 3.8     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 3        | 0.0608<br>0.0593 | 0.0603 | 0.0596 | 0.0593 | 0.0597 | Ave        |             | 0.0598 |    |   | 1.0     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 4        | 0.0905<br>0.0932 | 0.0906 | 0.0901 | 0.0919 | 0.0933 | Ave        |             | 0.0916 |    |   | 1.6     |      | 20.0 |          |            |   |                |
| PCB-1260 Peak 5        | 0.0426<br>0.0422 | 0.0418 | 0.0411 | 0.0422 | 0.0424 | Ave        |             | 0.0421 |    |   | 1.3     |      | 20.0 |          |            |   |                |
| Tetrachloro-m-xylene   | 0.9387<br>0.8498 | 0.8866 | 0.8646 | 0.8814 | 0.8912 | Ave        |             | 0.8854 |    |   | 3.4     |      | 20.0 |          |            |   |                |
| DCB Decachlorobiphenyl | 0.9073<br>0.7432 | 0.8658 | 0.8274 | 0.8096 | 0.7986 | Ave        |             | 0.8253 |    |   | 6.9     |      | 20.0 |          |            |   |                |

Note: The M1 coefficient is the same as Ave RRF for an Ave curve type.

TestAmerica Canton

Data File: \\ChromNA\Canton\ChromData\A2HP2\20180927-80319.b\P2092756.D

Injection Date: 28-Sep-2018 03:35:47

Instrument ID: A2HP2

Operator ID:

Lims ID: 240-101687-B-1-A

Lab Sample ID: 240-101687-1

Worklist Smp#: 30

Client ID: MH-09-091918

Injection Vol: 1.0 uL


Dil. Factor: 100.0000

ALS Bottle#: 56


Method: PCB2 IS

Limit Group: GC 8082A IS

Y Scaling: Method Defined: Set to Absolute Y Value



Y Scaling: Method Defined: Set to Absolute Y Value



TestAmerica Canton

Data File: \\ChromNA\Canton\ChromData\A2HP2\20180927-80319.b\P2092757.D

Injection Date: 28-Sep-2018 03:50:12

Instrument ID: A2HP2

Operator ID:

Lims ID: 240-101687-B-2-A

Lab Sample ID: 240-101687-2

Worklist Smp#: 31

Client ID: MH-DUP-091918

Injection Vol: 1.0 uL


Dil. Factor: 500.0000

ALS Bottle#: 57

Method: PCB2 IS

Limit Group: GC 8082A IS

Y Scaling: Method Defined: Set to Absolute Y Value



Y Scaling: Method Defined: Set to Absolute Y Value

